

**AMENDMENT NO. 4 FEBRUARY 2010
TO
IS 11833 : 1986 SPECIFICATION FOR DRY POWDER FIRE
EXTINGUISHER FOR METAL FIRES**

(Page 9, clause 11.1) — Substitute the following for the existing:

“Each extinguisher body shall be painted either with epoxy powder coating or synthetic enamel paint. The shade shall be ‘Fire Red’ or ‘Post Office Red’ conforming to Shades No. 536 or 538 of IS 5.

NOTES

1 Whenever epoxy powder coating is applied on the external surface of mild steel body for anti-corrosive treatment, synthetic enamel paint coating is not required.

2 The body of extinguisher shall be of good finish, clear of all burrs and sharp edges.”

(CED 22)

Reprography Unit, BIS, New Delhi, India