

AMENDMENT NO. 1 FEBRUARY 2005
TO
IS 4886 : 1991 FIRE SAFETY OF INDUSTRIAL
BUILDINGS: TEA FACTORIES — CODE OF PRACTICE
(First Revision)

[Page 6, clause 12.1(b)(ii)] — Substitute 'CO₂ squeeze grip type (see IS 2878)' for 'BCF 1.2 kg and 5 kg (see IS 11108 : 1984)'.

(CED 36)

Reprography Unit, BIS, New Delhi, India