

AMENDMENT NO. 1 AUGUST 2026
TO
IS 4990 : 2024 PLYWOOD FOR CONCRETE SHUTTERING WORKS —
SPECIFICATION
(Fourth Revision)

(Foreword, fifth and sixth para) — Delete.

(Page 2, clause 6.6, line 6) — Substitute ‘Glue line protection (GLP) treatment for shuttering plywood with retention requirements as per 10.11.’ for ‘with retention of not less than 12 kg/m³.’

(Page 6, clause 10.11) — Substitute the following for existing:

‘10.11 Plywood shall be treated as per 6.6. The retention requirement for plywood for concrete shall be classified based on preservative treatment:

<i>Sl No.</i>	<i>Type of Plywood</i>	<i>Designation</i>	<i>Preservative Treatment Category</i>	<i>Preservative Retention, kg/m³</i>	<i>Service Life</i>
(1)	(2)	(3)	(4)	(5)	(6)
i)	Plywood for concrete shuttering work (plain)	CS	With glue line protection (GLP)	0	Single time use
			With preservative treatment	4	Upto 1 year
				6	Upto 2 years
ii)	Plywood for concrete shuttering work with polymer coating (coated)	CSC	With preservative treatment	0	Single time use with Glue line protection (GLP)
				4	Usage beyond single time
iii)	Plywood for concrete shuttering work with suitable overlay (film faced)	CSFF	Not applicable	—	—

[Page 6, clause 10.12(b)] — Substitue the following for existing:

‘b) Formaldehyde Class $E_2 \leq 30$ mg/100 g of oven-dry sample.’

(Page 6, clause 11) — Delete.

[Page 6, clause 12.1(g)] — Substitute the following for the existing:

‘Mention whether the plywood is with or without preservative treatment, if treated, specify the preservative chemical used.’

(Page 7, clause 13, last sentence) — Delete.

(CED 20)

Price Group 1
BIS, Publication, New Delhi