

AMENDMENT NO. 3 SEPTEMBER 1984
TO
IS:5120-1977 TECHNICAL REQUIREMENTS FOR ROTODYNAMIC
SPECIAL PURPOSE PUMPS
(First Revision)

Alteration

[Page 44, clause 17.6, (see also Amendment No. 1)] -
Substitute the following for the existing:

'17.6 *Casing* - Casing shall be of robust construction and tested to withstand a hydrostatic test pressure of 1.5 times the maximum discharge pressure experienced by the pump casing or diffuser bowl. All other components under pressure namely, column pipe, discharge elbow shall also be tested at same pressure.

NOTE 1 - The maximum pressure experienced by casing or diffuser bowl is the sum total of maximum inlet pressure and maximum differential pressure generated by pump. The maximum pressure of a pump with maximum inlet suction pressure of 0.5 kg/cm^2 and developing maximum head of 4.0 kg/cm^2 , the maximum pressure experienced by casing will be $4.0 + 0.5 = 4.5 \text{ kg/cm}^2$. Hence the hydrostatic test pressure should be equal to $1.5 \times 4.5 = 6.75 \text{ kg/cm}^2$.

NOTE 2 = In case of suction lift, the test shall be conducted based on maximum total head developed by pump.'