

AMENDMENT NO. 1 SEPTEMBER 1993
TO
IS 6272 : 1987 SPECIFICATION FOR INDUSTRIAL
COOLING FANS (MAN COOLERS)

(First Revision)

(Page 9, clause 9.1) — Add the following sub-clause after 9.1:

‘9.1.1 For compliance with requirements of this standard, the values of total air delivery shall not be less than those specified in Table 2. In case higher values of air delivery is declared by the manufacturer (see 10.1.2) the observed results, expressed as the percentage of the values declared by the manufacturer shall not be less than 90 percent of the declared values. Similarly for any values of fan speed declared by the manufacturer (see 10.1.2) observed results expressed as the percentage of the values declared by the manufacturer shall not be more than 10 percent or less than 90 percent of the declared value. The actual input when measured shall not exceed the declared value by more than 10 percent subject to the condition that the observed value shall in no case exceed the specified value given in Table 2.’

[Page 14, clause 11.9(c)] — Substitute the following for the existing entries:

‘11.9 (c) 0.60 for fans having an input of 1.0 kw or less than 0.70 for fans having input above 1.0 kw in case of 3-phase fans.’

(ETD 5)

Reprography Unit, BIS, New Delhi, India