

AMENDMENT NO. 1 MARCH 1991
TO
IS 6530 : 1972 CODE OF PRACTICE FOR LAYING
OF ASBESTOS CEMENT PRESSURE PIPES

(Page 6, *clause 4.1.1*) — Substitute the following for the existing clause:

‘4.1.1 Width — The net trench width inside any shuttering which may be used should be sufficient to permit the pipe and joints to be properly bedded and to facilitate adequate compaction of the initial fill, particularly around the underside of the pipe. The recommended net width at bedding level is $D + 0.4$ m for pipes of nominal diameter up to 500 mm, and $D + 0.6$ m for pipes of nominal diameter exceeding 500 mm, D being the external diameter of the pipe in metres. The minimum width of the trench at bedding level should be 0.6 m for trench depths up to 1.5 m and 0.8 m for greater depths. If special equipment is required to mount the joints, it may be necessary to widen the trench at these points.’

(Page 7, *clause 4.2.9*) — Substitute the following for the existing clause:

‘4.2.9 The bed of the trench shall be excavated to the pipe grades so that uniform support is assured for the full length of the pipes by providing even bedding as shown in Fig. 2C.’