

**AMENDMENT NO. 1 OCTOBER 1997
TO
IS 6533 (PART 1) : 1989 DESIGN AND CONSTRUCTION
OF STEEL CHIMNEY — CODE OF PRACTICE
PART 1 MECHANICAL ASPECT**

(First Revision)

(Page 15, clause B-1.1) — Substitute the following for the existing formula:

$$H = \left[\frac{AMFD}{8 CV} \right]^{\frac{5}{4}}$$

Modify the definition given for parameter D under the above formula as:

D = diameter of stack at the exit of the Chimney in m.

(CED 7)

Reprography Unit, BIS, New Delhi, India