

**AMENDMENT NO. 1 MARCH 2012
TO
IS 655 : 2006 AIR DUCTS — SPECIFICATION**

(Second Revision)

(Page 2, clause 5.1.1) — Substitute ‘Grade 350’ for ‘Class 4’ and ‘Grade 275’ for ‘Class 3’.

(MED 03)

Reprography Unit, BIS, New Delhi, India