

AMENDMENT NO. 1 MAY 1988
TO
IS : 778-1984 SPECIFICATION FOR COPPER ALLOY
GATE, GLOBE AND CHECK VALVES FOR
WATERWORKS PURPOSES

(Fourth Revision)

(Page 4, clause 1.1) — Add the following after clause 1.1:

‘1.2 This standard may be used for other fluids if so desired by the purchaser. However, physical and chemical testing shall be done for the same fluids.’

[Page 5, clause 5.2(a), lines 4 and 5] — Substitute ‘Scooping of the material from the face of the gate shall be permissible up to an extent that the reduced thickness of the gate due to scooping shall not be less than the value specified in Table 4 for minimum thickness of body’ for ‘and in which no material has been removed from the surface of the gate’.

(Page 7, Table 1):

a) *Sl No. (vii), col 3 :*

1) Substitute ‘Cast iron*’ for ‘Cast iron’.

2) Add the following foot-note marked with ‘*’ mark at the end of the table:

‘*Steel, aluminium alloy, zinc alloy and non-metallic material may be permitted if required by the purchaser.’

b) *Sl No. (ix), col 3* — Add the following after (b) :

‘c) Any other equally efficient packing material suitable for cold water.’

(Page 8, clause 7.1.3.1) — Substitute the following for the existing clause :

‘7.1.3.1 Screwed bodies shall have female parallel threads unless taper threads are specified by the purchaser. Threads shall be according to IS : 554-1975*. Other types of threads may be provided if specified by the purchaser. The minimum length of threaded portion in screwed end valves shall be as given in Table 2. The threads at the start shall be chamfered to at least 1 mm. Ample space shall be provided between the end of the assembled pipe and any internal obstruction.’

(Page 9, clause 7.1.4.1) — Add the following after the first sentence :

‘Flange dimensions other than specified may be permitted if required by the purchaser.’

(Page 9, Table 3) :

a) *Sl No. (V to IX), col 4* — Substitute ‘+ 3.0’ for the existing positive tolerance on thickness of flanges.

b) *Col 5, ‘heading’* — Substitute ‘BOLT’ for ‘BELT’.

(Page 12, clause 7.7.1, first sentence) — Substitute the following for the existing first sentence :

‘The guides if provided (see 7.1.5) shall ensure that the seating surfaces of the wedge do not touch those of the body until near the point of closure.’

(Page 14, clause 8.2) — Substitute the following for the existing clause :

‘8.2 Minimum flat to flat size shall be as given in Table 5.’

(Page 14, Table 5) — Substitute the following for the existing table:

TABLE 5 MINIMUM FLAT TO FLAT SIZE FOR BOTH CLASS 1 AND CLASS 2 VALVES

NOMINAL SIZE OF VALVE	All dimensions in millimetres.										
	8	10	15	20	25	32	40	50	65	80	100
FLAT TO FLAT SIZE	18	22	26	32	39	49	55	68	85	98	127

(Page 16, Table 9, col 2, against Gate valves) :

a) Substitute the following for the existing :

‘i) Screwed in or screwed on bonnet integral seat’

‘ii) Screwed in or screwed on bonnet renewable seat’

b) Delete the following :

‘iii) Screwed-on bonnet integral seats’

‘iv) Screwed-on bonnet renewable seats’

and entries given against them.

c) Renumber ‘(v)’ as ‘(iii)’.

[Page 16, Table 9, col 2, against Globe valves and lift check valves (straight)] — Substitute for following for the existing :

‘i) Screwed in or screwed on bonnet integral seat’

‘ii) Screwed in or screwed on bonnet renewable seat’

(Page 17, Table 10, col 2) — Substitute the following for the existing :

‘i) Screwed in or screwed on bonnet integral seat’

‘ii) Screwed in or screwed on bonnet renewable seat’

[Page 18, Table 11, col 7, against Globe valves and lift check valves (straight), and (i) Screwed-in bonnet integral seat] — Substitute ‘110’ for ‘100’.

(Page 20, clause 9.4, first sentence) — Substitute the following for the existing sentence:

‘Back seat test pressure shall be same as for seat test (see 9.5).’

(Page 22, clause 12.4, line 1) — Delete ‘above 50 mm size’.

(BDC 3)