

AMENDMENT NO. 1 NOVEMBER 1995
TO
IS 779 : 1994 WATER METERS (DOMESTIC TYPE) —
SPECIFICATION

(Sixth Revision)

(Page 1, clause 3.10) — Add the following sub-clauses after 3.10:

‘3.10.1 *Single Jet Meter* — In this meter the water arrives and impacts at a tangent to the turbine which is why the inlet and outlet connections of the meter are offset from the axis of the meter. The body works as the measuring chamber.

3.10.2 *Multi Jet Meter* — In this meter water arrives through a distribution box generally called impeller chamber which makes up the measurement chamber. This box has a number of holes, tangential to the turbine around its periphery which allows water to impact upon the turbine.’

(Page 2, clause 6.1, second para) — Substitute the following for the existing:

‘Materials to be used in the manufacture of the body and component parts of water meters shall be as given in Annex B.’

(Page 2, sub-clause 6.1.1) — Delete.

(Page 2, clause 7.1, line 9) — Substitute ‘shall’ for ‘should not’.

(Page 4, Table 2, col 4 and 5) — In col 4 insert ‘a’ and in col 5 insert ‘b’ at the end of the column headings.

(Page 5, clause 10.1, lines 4 and 5) — Substitute ‘IS 6784 : 1995’ for ‘IS 6784 : 1984’.

(Page 5, clause 10.2, line 2) — Substitute ‘IS 6784 : 1995’ for ‘IS 6784 : 1984’.

(Page 5, clause 10.3, line 2) — Substitute ‘IS 6784 : 1995’ for ‘IS 6784 : 1984’.

(Page 5, clause 11.1, line 2) — Substitute ‘IS 6784 : 1995’ for ‘IS 6784 : 1984’.

(Page 5, clause 11.2, line 4) — Substitute ‘IS 6784 : 1995’ for ‘IS 6784 : 1984’.

Amend No. 1 to IS 779 : 1994

(*Page 7, sub-clause 12.4.4, line 2*) — Substitute 'IS 6784 : 1995' for 'IS 6784 : 1984'.

(*Page 7, clause 12.5, line 2*) — Substitute 'IS 6784 : 1995' for 'IS 6784 : 1984'.

(*Page 7, Annex A*) — Substitute 'IS 2267 : 1995 Polystyrene moulding and extrusion materials (*second revision*)' for 'IS 2267 : 1972' and 'IS 6784 : 1995 Methods for performance testing of water meter (domestic type) (*second revision*)' for 'IS 6784 : 1984'.

(*Page 8, Annex B*) — Against 'Measuring chamber' add 'Plastics (High impact polystyrene conforming to IS 2267 : 1995 /ABS/Acetal co-polymer)'.

(*Page 9, Annex B*) — Against 'Dial' add 'Plastics (High impact polystyrene conforming to IS 2267 : 1995/Acrylic/Acetal co-polymer)'.

(CED 3)