

AMENDMENT NO. 3 AUGUST 1999
TO
IS 779 : 1994 WATER METERS
(DOMESTIC TYPE) — SPECIFICATION
(Sixth Revision)

[*Foreword, para 3, item (c)*] — Substitute the following for the existing:

- c) Depending upon the metrological characteristics, Class A and Class B water meters have been introduced, based on ISO 4064 (Part 1) and EEC Council Directive.'

(*Page 1, clause 5*) — Substitute the following for the existing matter:

"Based on the maximum verification scale interval (see 8.3) and metrological characteristics (see 11), meters have been classified as Class 'A' and Class 'B'."

(*Page 3, clause 8.3*) — Substitute the following for the existing matter:

"Verification scale interval for Class 'A' and Class 'B' meters shall be as given in Table 1.

Table 1 Verification Scale Interval

Meter Size	Maximum Value of Verification Scale Interval, litres	
	Class A	Class B
15	0.2	0.2
20	0.5	0.2
25	1.0	0.5
40	2.0	1.0
50	2.0	2.0

(*Page 5, Table 3*) — Delete col 2 and col 5 along with their contents and renumber the columns accordingly.

(CED 3)

Reprography Unit, BIS, New Delhi, India