

AMENDMENT NO. 2 NOVEMBER 1994
TO
IS 781 : 1984 SPECIFICATION FOR CAST COPPER
ALLOY SCREW DOWN BIB TAPS AND STOP VALVES
FOR WATER SERVICES

(Third Revision)

[*Page 10, clause 9.1 (see also Amendment No. 1)*] — Substitute the following for the existing:

‘Every bib tap and stop valve complete with its components shall be tested in closed position under an hydraulic pressure of 1.5 MPa (minimum) maintained at that pressure for a period of at least 2 minutes during which it shall neither leak nor sweat.’

(CED 3)

Reprography Unit, BIS, New Delhi, India