

## **Amend No. 2 to IS 783 : 1985**

( *Page 26, clause 15.4.3* ) — Add the following new clause after the clause:

**'15.4.4 *Specials* — For water mains, sewer lines and irrigation works, certain fittings and specials are required for curves, bends, branches, manholes, air valves blow-offs and connection to main line valves and other pipes. The specials shall be in accordance to IS 784 : 2001\* and IS 7322 : 1985†. Concrete pipes are manufactured as per standard length, the length of specials may vary as per site conditions.'**

( *Page 27, footnote* ) — Insert the following new footnotes:

**'\*Prestressed concrete pipes (including specials) - Specification (*second revision*).**

**†Specification for specials for steel cylinder reinforced concrete pipes (*first revision*)'**

( *Page 65, last sentence of Example 1* ) — Substitute the following for the existing sentence:

**'It follows from Table 2 of IS 458 : 2003\* that 900 mm NP2 class pipe which has a 0.25 mm crack test load of 22.80 kN/m is suitable'**

( *Page 65, footnote* ) — Substitute the following for the existing footnote:

**'\*Specification for precast concrete pipes (with and without reinforcements) (*fourth revision*)'**

[ *Page 66, last sentence of Example 2(a)* ] — Substitute the following for the existing sentence:

**'It follows from Table 2 of IS 458 : 2003\* that a 450 mm NP2 class pipe which has a 0.25 mm crack load of 16.18 kN/m is suitable.'**

[ *Page 66, Example 2, sub-para (b)* ] — Substitute 'IS 458 : 2003\*' for 'IS : 458 - 1971\*'. .

( *Page 66, footnote* ) — Substitute the following for the existing footnote:

**'\* Specification for precast concrete pipes (with and without reinforcements) (*fourth revision*).'**

( *Page 67, Example 3, penultimate sentence* ) — Substitute the following for the existing sentence:

**'It follows from the above that 450 mm NP2 class pipe will be obviously inadequate and 450 mm NP3 class reinforced pipe (Table 3 and 5 of IS 458 : 2003\*) with 0.25 mm cracking load of 21.56 kN/m or 450 mm NP3 class unreinforced pipe (Table 4 of IS 458 : 2003\*) with ultimate load of 21.56 kN/m will have to be used.'**

**Amend No. 2 to IS 783 : 1985**

( Page 67, *footnotes* ) — Insert the following footnote:

*\*Precast concrete pipes (with and without reinforcements) (fourth revision).\**

[ Page 68, *Example 4, sub-para (b), last sentence* ] — Substitute the following for the existing sentence:

'It follows from Table 2 of IS 458 : 2003\* that a 600 mm diameter NP2 class pipe which has a 0.25 mm crack load of 18.88 kN/m will be suitable'.

( Page 68, *footnote* ) — Substitute the following for the existing footnote:

*\*Specification for precast concrete pipes (with and without reinforcements) (fourth revision) \**

( Page 70, *Example 6, last sentence* ) — Substitute the following for the existing :

'It follows from Tables 6 and 8 of IS 458 : 2003\* that a 800 mm diameter NP4 class pipe which has a 0.25 mm crack load of 59.3 kN/m will be suitable; alternatively it follows from Table 7 of IS 458 : 2003\* that 800 mm diameter NP4 class unreinforced pipe which has ultimate load of 59.3 kN/m will also be suitable.

( Page 70, *footnote* ) — Substitute the following for the existing footnote:

*\*Specification for precast concrete pipes (with and without reinforcements) (fourth revision) \**

( Page 71, *Example 7* ) — Substitute 'From Tables 6, 7 and 8 of IS 458 : 2003\* the 0.25 mm crack load / ultimate load respectively for 1 600 mm diameter reinforced / unreinforced pipe as applicable is 119.6 kN/m' for 'From Table 4 of IS : 458 - 1971\* the 0.25 mm cracking load for 1 600 mm dia pipe is 119.6 kN/m'.

( Page 71, *footnote* ) — Substitute the following for the existing footnote:

*\*Specification for precast concrete pipes (with and without reinforcements) (fourth revision) \**

[ Page 73, *Example 8(b), last para* ] — Substitute the following for the existing para:

'It follows from Table 2 of IS 458 : 2003\* that a 300 mm NP2 class pipe which has a 0.25 mm crack load of 13.48 kN/m will not be suitable. However, 300 mm diameter NP3 class pipe (Tables 3 and 5 of IS 458 : 2003\*) with a 0.25 mm crack load of 15.50 kN/m will be suitable; alternatively 300 mm diameter NP3 class unreinforced pipe (Table 4 of IS 458 : 2003\*) with ultimate load of kN/m will also be suitable.'

**Amend No. 2 to IS 783 : 1985**

( *Page 73, footnote* ) — Substitute the following for the existing footnote:

**‘\*Specification for precast concrete pipes (with and without reinforcements) (*fourth revision*).’**

( *Page 74, Example 9, last sentence* ) — Substitute ‘Tables 6, 7 and 8 of IS 458 : 2003\*’ for ‘Table 4 of IS : 458 - 1971\*’.

( *Page 74, footnote* ) — Substitute the following for the existing footnote:

**‘\*Specification for precast concrete pipes (with and without reinforcements) (*fourth revision*).’**

( *Page 75, Example 10, last para* ) — Substitute the following for the existing para:

**‘It follows from Tables 6 and 8 of IS 458 : 2003\* that a 800 mm diameter NP4 class reinforced pipe which has a 0.25 mm crack load of 59.3 kN/m will be suitable: alternatively it follows from Table 7 of IS 458 : 2003\* that 800 mm diameter NP4 class unreinforced pipe which has ultimate load of 59.3 kN/m will also be suitable.’**

( *Page 75, footnote* ) — Substitute the following for the existing footnote:

**‘\*Specification for precast concrete pipes (with and without reinforcements) (*fourth revision*).’**