

AMENDMENT NO. 1 MARCH 2024
TO
IS 802 (PART 1/SECTION 1) : 2015 USE OF STRUCTURAL STEEL IN OVERHEAD
TRANSMISSION LINE TOWERS — CODE OF PRACTICE
PART 1 MATERIALS, LOADS AND DESIGN STRENGTHS
SECTION 1 MATERIALS AND LOADS
(Fourth Revision)

[Page 2, clause **6.1(a)(3)**, Note] — Substitute the following for the existing:

‘NOTE — In the selection of suspension tower either (2) above or a combination of (1) and (3) may be followed.’

(Page 3, clause **8.1**, para 1, line 1) — Substitute ‘Figure 1 of Part 6/Sec 1 of National Building Code of India 2016 (NBC 2016)’ for ‘Figure 1’.

(Page 3, clause **8.1**, para 2, line 1) — Delete ‘(see Fig. 1)’.

(Page 3, clause **8.1**, Note 1) — Substitute ‘Part 6/Sec 1 of National Building Code of India 2016 (NBC 2016)’ for ‘IS 875 (Part 3)’.

(Page 4, Fig. 1) — Delete.

(Page 5, clause **9.1.1**) — Substitute the following for the existing:

‘Component of F_{wt} in:

Transverse direction $F_{wt\ TRANS} = P_d * (1 + 0.2 \sin^2 2\theta) (A_{eT} * C_{dT} * \cos \theta) G_T$

Longitudinal direction $F_{wt\ LONGI} = P_d * (1 + 0.2 \sin^2 2\theta) (A_{eL} * C_{dL} * \sin \theta) G_T$

(Page 5, clause **9.1.2**, last line) — Substitute ‘Fig. 3’ for ‘Fig. 2’.

(Page 6, clause **9.2**, description of $\sin^2 \Omega$, line 3 and 4) — Substitute ‘ $\sin^2 \Omega_1$, $\sin^2 \Omega_2$ and $\sin^2 \Omega_3$ ’ for ‘ $\sin^2 \Omega_1$, $\sin^2 \Omega$ and $\sin^2 \Omega$ ’.

[Page 10, clause **12.1.2.1(b)(1)**, first sentence, line 4] — Insert the following at the end:

‘for 75 percent of full wind pressure.’

[Page 11, clause **12.1.2.1(b)(2)**, last line] — Insert the following at the end:

‘for 75 percent of full wind pressure at everyday temperature.’

[Page 13, clause **12.3.2** (b)] — Insert the following at the starting of the clause:

‘For tension towers,’.

(Page 15, Annex A) — Substitute ‘IS 875 (Part 3) : 2015’ for ‘IS 875 (Part 3) : 2014’.

Price Group 1

Amendment No. 1 to IS 802 (Part 1/Sec 1) : 2015

(Page 15, Annex A) — Insert the following at the end:

<i>IS No.</i>	<i>Title</i>
SP 7 (Part 6/Sec 1) : 2016	National building code of India 2016: Part 6 Structural design, Section 1 Loads, forces and effects

(Third Cover, line 4) — Substitute ‘b) IEC 60826 : 2003 Design criteria of overhead transmission lines’
for ‘b) IEC 60050-826 International electro-technical vocabulary — Part 826: Electrical installations’.

(CED 07)

Publication, BIS, New Delhi