

AMENDMENT NO. 1 MARCH 2025
TO
IS 802 (PART 1/SECTION 2) : 2016 USE OF STRUCTURAL STEEL IN OVERHEAD
TRANSMISSION LINE TOWERS — CODE OF PRACTICE
PART 1 MATERIALS, LOADS AND DESIGN STRENGTHS
SECTION 2 DESIGN STRENGTHS
(Fourth Revision)

[Page 4, clause **6.3(a) and (b)**] — Substitute the following for the existing:

- | | | |
|-----|--|---------|
| ‘a) | Leg members, ground wire support peak members and lower members of the cross arms in compression | : 120 |
| b) | Other members carrying computed stresses (such as bracings) | : 200’. |

(CED 07)

Price Group 1
Publication, BIS, New Delhi