

AMENDMENT NO. 1 AUGUST 1992
TO
IS 802 (Part 2) : 1978 CODE OF PRACTICE FOR USE
OF STRUCTURAL STEEL IN OVERHEAD
TRANSMISSION LINE TOWERS
PART 2 FABRICATION, GALVANIZING, INSPECTION AND
PACKING

(Page 7, clause 5.9, line 3) — Substitute 'SP 6 (Part 1) : 1964' for 'SP 6 (1) : 1969'.

(Page 8, clause 6.3, line 2) — Substitute ' ± 2 mm and ± 1 mm respectively' for ' ± 0.5 mm'.

(Page 8, clause 6.4, line 1) — Substitute ' ± 2 mm' for ' ± 1.6 mm'.

(Page 8, clause 6.5, line 2) — Substitute ' ± 1 mm' for ' ± 0.5 mm'.

(CED 7)

Reprography Unit, BIS, New Delhi, India