

AMENDMENT NO. 2 JULY 2009
TO
IS 902 : 1992 SUCTION HOSE COUPLINGS FOR FIRE
FIGHTING PURPOSES — SPECIFICATION

(*Third Revision*)

(Page 4, Table 2) — Substitute the following for the existing:

Nominal Size of Coupling	Male Coupling								Nut for Female Coupling			
	Dia <i>E</i> (Toler- ance ± 0.4)	Dia <i>F</i> (Toler- ance ± 0.8)	Dia <i>G</i> (Toler- ance ± 0.8)	Dia <i>S1</i> (Toler- ance $+ 0.40$ $- 0.00$)	Dia <i>M</i> (Toler- ance ± 0.8)	<i>P1</i> (Toler- ance ± 0.8)	Dia <i>R</i> (Toler- ance ± 0.8)	Thick- ness <i>t</i> (<i>Min</i> ± 0.8)	Dia <i>K</i> (Toler- ance $+ 0.40$ $- 0.00$)	Dia <i>N</i> (Toler- ance ± 1)	<i>P</i> (Toler- ance ± 1)	Dia <i>S1</i> (Toler- ance ± 1)
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	(13)
75	77.80	71.40	89	69.9	95	140	19	4	93.70	110	170	114
100	103.2	96.80	114	95.3	121	165	24	4	119.10	137	187	143
140	141.3	134.9	152	133.4	159	203	24	4	157.20	175	235	181