

**AMENDMENT NO. 2 JANUARY 2001
TO
IS 937 : 1981 SPECIFICATION FOR WASHERS FOR
WATER FITTINGS FOR FIRE FIGHTING PURPOSES**

(*Second Revision*)

(*Page 3, clause 2.1*) — Substitute the following for the existing:

‘Rubber — Where rubber is used for washers, it shall conform to requirement of hardness as applicable to Type 3 of IS 5382 : 1985 and also acid and alkali resistant (*see Note*).

NOTE — When a piece of 25 mm cut from any portion is dipped in 20 percent sulphuric acid/5 percent sodium hydroxide solution for 30 minutes, there shall be no sign of corrosion/damage.’

(CED 22)

Reprography Unit, BIS, New Delhi, India