

AMENDMENT NO. 1 MAY 1989
TO
IS : 941 - 1985 SPECIFICATION FOR
BLOWER AND EXHAUSTER FOR FIRE
FIGHTING

(Second Revision)

(Page 4, Table 1) — Insert the following Note at the end:

"NOTE — Where it is possible to have electric supply, in place of petrol engine given at Sl No. (v) 3-phase induction motor according to IS : 325 - 1978 'Specification for three-phase inductor motors (fourth revision)' of capacity 2.2 kW with or without flameproof enclosures [see IS : 2148-1981 'Specification for flameproof enclosures of electrical apparatus (second revision)'] shall be used."

(BDC 22)