

**AMENDMENT NO. 2 MARCH 1993
TO
IS 941 : 1985 SPECIFICATION FOR BLOWER AND
EXHAUSTER FOR FIRE FIGHTING**

(Second Revision)

[Page 4, Table 1, Sl No. (v)] — Substitute the following for the existing matter:

(1)	(2)	(3)	(4)
v)	a) Petrol engine of capacity 2.5 kW with 3 litre petrol tank; or	—	IS : 7347 — 1974‡
	b) Lightweight diesel engine of capacity 3.23 kW	—	IS 10001 : 1981¶

¶Performance requirements for constant speed compression ignition (diesel) engine for general purposes (up to 20 kW).'