

AMENDMENT NO. 1 JULY 1991
TO
IS 8794 : 1988 SPECIFICATION FOR CAST IRON
DETACHABLE JOINTS FOR USE WITH
ASBESTOS CEMENT PRESSURE PIPES

(First Revision)

(Page 2, clause 4.2, line 2) — Substitute '3.3' for '4.3'.


(Page 2, clause 4.2, line 4) — Substitute '4.1' for '5.1'.

(Page 2, clause 6.3, line 3) — Substitute '7.15 kg/dm³' for '7.15 kg/cm³'.

(Page 4, Table 1) — Substitute the following for the existing values of *D_o*, 'Outside Dia of Flange', col 7 (from *DN* 350 to *DN* 600) and *C* 'Bolt Circle Dia', col 9 (from *DN* 350 to *DN* 600):

NOMINAL DIA <i>DN</i>	OUTSIDE DIA OF FLANGE <i>D_o</i>	BOLT CIRCLE DIA <i>C</i>
(1)	(7)	(9)
350	448.0 463.5 479.5 496.5	452.0 467.5 483.0 500.5
400	503.5 522.5 540.5 559.5	508.5 527.5 545.0 564.5
450	556.5 576.5 596.5 617.5	561.5 581.5 601.5 622.5
500	622.0 642.0 664.0 686.0	628.0 648.0 670.0 692.0
600	742.0 768.0 793.0 822.0	748.0 774.9 799.0 828.0

(Page 6, Table 3) — Substitute the following figure for the existing figure:



(Page 6, Table 4) — Substitute the following values for the existing values from DN 350 to DN 600:

NOMINAL DIA DN	MASS OF JOINT (APPROXIMATE, EXCLUDING RUBBER RING AND BOLTS) IN kg FOR CLASS				
	5	10	15	20	25
(1)	(2)	(3)	(4)	(5)	(6)
350	24.7	24.7	26.5	29.2	31.5
400	29.7	29.7	31.4	35.1	38.5
450	34.5	34.5	38.0	41.1	45.1
500	50.0	50.0	54.1	59.7	64.0
600	78.2	78.2	84.8	91.8	100.5

(MTD 6)