

AMENDMENT NO. 2 OCTOBER 1996
TO
IS 8794 : 1988 SPECIFICATION FOR CAST IRON
DETACHABLE JOINTS FOR USE WITH ASBESTOS
CEMENT PRESSURE PIPES

(First Revision)

(Page 2, clause 6.3) — Substitute the following for the existing clause>

'6.3 The mass of joints (excluding rubber rings and bolts), calculated by taking density of iron as 7.15 kg/dm^3 , are given in Table 4. The permissible tolerance on specified mass of joints shall be ± 8 percent'.

(Page 6, Table 4) — Delete the word 'Approximate' wherever appearing in the table.

(MTD 6)

Reprography Unit, BIS, New Delhi, India