

AMENDMENT NO. 2 FEBRUARY 1974
TO
IS : 5978-1970 CODE OF PRACTICE FOR DESIGN OF
WOOD POLES FOR OVERHEAD POWER AND
TELECOMMUNICATION LINES

Alterations

(*Page 4, clause 3.1, equation against 'Le'*) — Substitute
' ($Le = Lf - Lg + 0.3 \text{ m}$) ' for ' ($Le = Lf - Lg$) '.

(*Page 6, clause 8.1*)

a) *Line 2* — Substitute ' IS : 5613 (Part I/Sec 1)-1970* ' for ' IS : 802 (Part I)-1967* '.

b) *Foot-note with (*) mark* — Substitute the following for the existing foot-note:

' *Code of practice for design, installation and maintenance of overhead power lines: Part I Lines up to and including 11 kV, Section 1 Design. '

(BDC 9)

Reprography Unit, BIS, New Delhi, India