

AMENDMENT NO. 1 JANUARY 1976

TO

**IS:6056-1970 SPECIFICATION FOR JOINTED
WOOD POLES FOR OVERHEAD POWER AND
TELECOMMUNICATION LINES**

Alteration

***(Page 6, Table 1, col 1, third entry) -
Substitute '7.5 and 8' for '8'.***

Addendum

***(Page 5, clause 4.2) - Add the
following at the end:***

***'For poles of intermediate length in
Table 1, the circumference given for
the next larger pole shall be used.'***

(BDC 9)

Reprography Unit, ISI, New Delhi