

AMENDMENT NO. 1 AUGUST 1974
TO
IS : 6162 (Part II) - 1971 SPECIFICATION FOR
PAPER COVERED ALUMINIUM
CONDUCTORS
PART II RECTANGULAR CONDUCTORS

Alterations

(Page 4, clause 3.1)

- a) *Line 2* — Substitute '15 to 35°C' *for* '10 to 40°C'.
- b) *Lines 2 and 3* — Substitute 'relative humidity range of 45 to 75 percent' *for* 'relative humidity not greater than 85 percent'.

(ETDC 33)