

AMENDMENT NO. 2 NOVEMBER 1975
TO
IS : 6162 (PART II)-1971 SPECIFICATION FOR
PAPER COVERED ALUMINIUM CONDUCTORS
PART II RECTANGULAR CONDUCTORS

Alterations

(Page 4, clause 23, line 2) — Delete the words 'width or'.

(Pages 7 and 8, clause 7.3) — Substitute the following for the existing clause:

"7.3 Measuring Method

7.3.1 Overall Dimensions — Measurements shall be made of the smaller dimension of the covered conductor at three positions not less than 100 mm apart. The measurements shall be made on completely straight parts of the wire. The measurement shall include at least one overlap.

Where the larger dimension of the covered conductor is greater than the diameter of the micrometer spindle, measurements shall be made at the centre of the wire.

The average of the three results shall be reported as the 'overall thickness'.

7.3.2 Conductor Dimensions — The covering shall be removed by any method which does not damage the conductor for the three positions used for measurements in 7.3.1 and the conductor dimension measured at these positions.

The average of the three results shall be reported as 'conductor thickness'.

7.3.3 Increase in Dimensions Due to Paper Covering — The difference between the overall thickness and the conductor thickness shall be reported as the 'increase in thickness'.

NOTE — The measurement across the larger dimension is under consideration."