

AMENDMENT NO. 3 AUGUST 1978
TO
IS : 6162 (Part II)-1971 SPECIFICATION FOR
PAPER COVERED ALUMINIUM
CONDUCTORS

PART II RECTANGULAR CONDUCTORS

Addendum

(Page 8, clause 8.1) — Add the following new clauses after 8.1:

'8.2 The test voltage may also be calculated by applying the formula as given below, since sometimes it is difficult to judge accurately the values from Fig. 3:

$$\log V_{10} = 1.544 + 0.8 \log t_{10}$$

where

V = proof voltage in kV, and

t = increase in dimension in mm due to covering.

NOTE — This formula is limited for the value of ' t ' up to and including 5.080 mm.

8.2.1 In cases of disputes, the calculated value of proof voltage by the empirical formula shall prevail.'

(ETDC 33)