

AMENDMENT NO. 1 APRIL 1997
TO
IS 10162 : 1982 SPECIFICATION FOR SPACERS
AND SPACER DAMPERS FOR TWIN HORIZONTAL
BUNDLE CONDUCTORS

(Page 11, clause 5.17) — Insert the following after the first sentence:

'A 80 meter test span shall be erected at a tension equivalent to every day tension (12 % of U.T.S. of Conductor). The spacer damper shall be placed at a position between 0.825 to 0.670 times the test span from the excited end.'

(ET37)

Reprography Unit, BIS, New Delhi, India