

AMENDMENT NO. 1 DECEMBER 2006
TO
IS 10297 : 1982 CODE OF PRACTICE FOR DESIGN
AND CONSTRUCTION OF FLOORS AND ROOFS
USING PRECAST REINFORCED/PRESTRESSED
CONCRETE RIBBED OR CORED SLAB UNITS

(Page 3, clause 0.4) — Insert the following clause at the end:

‘0.5 All standards, whether given herein above or cross-referred to in the main text of this standard, are subject to revision. The parties to agreement based on this standard are encouraged to investigate the possibility of applying the most recent editions of the standards.’

(Page 4, clause 2.1, Note) — Substitute the following for the existing note:

‘NOTES

1 The units with nominal width of minimum 300 mm may also be used in residential buildings.

2 As the size of the slab panel units depends on the handling equipment and the design method notwithstanding the size given in 2.1, any other size may be used.’

(Page 6, clause 4.4.3) — Insert the following note after first para:

‘NOTE – For non-circular core sections, the top thickness d_1 should be checked for local bending.’

[Page 7, clause 6.1(a)] — Substitute ‘15 mm’ for ‘12 mm’ and ‘20 mm’ for ‘15 mm’.

(Page 9, clause 7.1) — Substitute the following for the existing first sentence:

“The concrete mix used shall be minimum of M20 grade in accordance with IS 456 : 2000 ‘Code of practice for plain and reinforced concrete (*fourth revision*)’. However for prestressed concrete units, higher strength grade of concrete is required in accordance with IS 1343 : 1980 ‘Code of practice for prestressed concrete (*first revision*)’.”

Amend No. 1 to IS 10297 : 1982

(Page 11, clause 11.5) — Insert the following at the end:

“However the provisions of IS 1893 (Part 1) : 2002 ‘Criteria for earthquake resistant design of structures: Part 1 General provisions and buildings (*fifth revision*)’ and IS 4326 : 1993 ‘Code of practice for earthquake resistant design and construction of buildings (*second revision*)’ for earthquake resistance shall be required to be taken care of.”

(CED 51)

Reprography Unit, BIS, New Delhi, India