

AMENDMENT NO. 1 MAY 2002
TO
IS 371 : 1999 CEILING ROSES — SPECIFICATION
(Third Revision)

(Page 4, clause **12.1**) — Substitute the following for the existing:

'12.1 All ceiling roses shall be provided with an earthing terminal as specified in **13**. The earthing terminals shall be visibly distinguishable.'

(ET 14)

Reprography Unit, BIS, New Delhi, India

(Page 7, clause **13.8.2**, para 5, line 2) — Substitute '10 N' for '10 h'.

(Page 7, clause **13.8.3**, para 1) — Substitute the following for the existing para:

'13.8.3 For screwless terminals designed for use with both rigid and flexible conductors, compliance shall be checked with insulated conductors having cross-sectional area as specified is **13.1**.'

(Page 8, clause **14.1.1**, line 3) — Substitute '0.03' for '0.30'.

(Page 9, clause **16.2**, para 1, line 2) — Substitute '**8.1**' for '**7.1**'.

(Page 9, clause **16.2**, para 1, line 4) - Substitute '10 mm' for '10 mm²'.