

**AMENDMENT NO. 2 NOVEMBER 2002
TO
IS 371 : 1999 CEILING ROSES — SPECIFICATION
(Third Revision)**

(Page 1, clause 2.1, Reference to IS 5133) — Delete.

(Page 1, clause 2.1) — Insert the following reference at the end:

'IS 14772 : 2000 Enclosures for accessories for household and similar fixed electrical installation.'

(Page 1, clause 3.3) — Substitute the following for the existing:

'3.3 Semi-Recessed or Flush-Type Ceiling Rose

A ceiling rose intended for mounting with its base partially or completely sunk into a small circular conduit box or other suitable enclosure complying with IS 14772.'

(Page 4, clause 9.6.1, line 4) — Substitute the word 'licence' for the word 'license'.

(Page 4, clause 10.3, line 2) — Delete the repeat word 'of'.

(Page 4, clause 11.1.1, line 3) — Substitute ')' for ','.

(Page 5, Table 1, col 4, row 7) — Substitute '1.80' for '1.80'.

(Page 7, clause 13.8.2, para 5, line 2) — Substitute '10 N' for '10 h'.

(Page 7, clause 13.8.3, para 1) — Substitute the following for the existing para:

'13.8.3 For screwless terminals designed for use with both rigid and flexible conductors, compliance shall be checked with insulated conductors having cross-sectional area as specified is **13.1.**'

(Page 8, clause 14.1.1, line 3) — Substitute '0.03' for '0.30'.

(Page 9, clause 16.2, para 1, line 2) — Substitute '**8.1**' for '**7.1**'.

(Page 9, clause 16.2, para 1, line 4) - Substitute '10 mm' for '10 mm²'.

Amend No. 2 to IS 371 : 1999

(Page 9, clause **16.2**, para 3, line 2) - Substitute '0.75 mm²' for '0.75 mm'.

(Page 9, clause **16.2**, para 4, line 1) — Substitute 'cables or cords' for 'cables of cords'.

(Page 10, clause **17.2**, para 3, line 2) — Substitute 'polyamide' for 'polymide'.

(Page 10, clause **17.2**, para 4) — Substitute the following for the existing matter:

'The design of the apparatus is such that a force of 1.9 N to 2 N is applied to the face of the striking elements to maintain the pendulum in a horizontal position.'

[Page 12, clause **17.2(a)**, line 3] — Substitute 'axis' for 'exist'.

(Page 13, clause **18.3**, para 3) — Substitute the following for the existing para:

'The test shall be made in a heating cabinet at a temperature of $125 \pm 2^\circ \text{C}$.'

(Page 13, clause **18.4**, line 4) — Substitute '**18.3**' for '**17.3**'.

[Page 13, clause **19.2(a)**, line 4] — Substitute '850°C' for '85°C'.

[Page 13, clause **19.2(b)**, line 5] — Substitute '850°C' for '85°C'.

(Page 13, clause **19.2**, para 2, line 2) — Substitute the word 'ceiling rose' for 'switch'.

(Page 13, clause **19.2**, Note 1, line 7) — Substitute the word 'pinewood' for 'painedwood'.

(Page 14, clause **19.3**, para 3, line 2) — Substitute the word 'ammonium' for 'aluminium'

(Page 14, clause **19.3**, para 3, third sentence) — Substitute the following for the existing sentence:

'The drops shall have a volume of $20 \pm 3 \text{ mm}^3$ and shall fall from a height of $35 \pm 5 \text{ mm}$.'

[Page 15, clause **20.1.1(b)**] — Substitute the following for the existing matter:

'five times for nuts and other screws.'

[Page 16, Table 3, col 2, Sl No. (iii), line 6] — Substitute 'hygroscopic' for 'hydroscopic'.

Amend No. 2 to IS 371 : 1999

(*Page 17, clause 22.2.1, para 2, line 3*) — Substitute the word 'degreasing' for 'decreasing'.

(*Page 17, clause 22.2.1, para 2, line 5*) — Substitute the word 'ammonium' for 'aluminium'.

(*Page 17, clause 23.1.2, line 2*) — Substitute '6.3' for '6.4'.

(ET 14)