

AMENDMENT NO. 4 MARCH 2007
TO
IS 371 : 1999 CEILING ROSES — SPECIFICATION

(Third Revision)

(Page 3, clause 1.1, line 5) — Substitute 'current of 6A only' for 'current does not exceed 6A'

(Page 5, clause 7.2) — Substitute the following for the existing clause:

'7.2 Ceiling roses shall have a rated current of 6A only'.

(ET 14)

Reprography Unit, BIS, New Delhi, India