

AMENDMENT NO. 2 DECEMBER 2005
TO
IS 398 (PART 5) : 1992 ALUMINIUM CONDUCTOR
FOR OVERHEAD TRANSMISSION PURPOSES —
SPECIFICATION

PART 5 ALUMINIUM CONDUCTORS — GALVANIZED STEEL —
REINFORCED FOR EXTRA HIGH VOLTAGE (400 kV AND ABOVE)
(first Revision)

[Page 3, clause 10.6, Table 5 (see also Amendment No. 1)] — Substitute the following for the existing clause:

10.6 For the purpose of calculation of mass and resistance, stranding constants given in Table 5 are to be used.

Tables Stranding Constant
(Clause 10.6)

No. of Wires in Conductor		Stranding Constant		
		Mass		Electrical Resistance
Aluminium	Sttel	Aluminium	Steel	
(1)	(2)	(3)	(4)	(5)
42	7	43.053	7.045	0.024 406
54	7	55.43	7.045	0.019 009

(ET 37)