

CODE ANALYSIS - CASA FAMILIA

BUILDING TYPE A

(FBC 2017 WITH ALL SUPPLEMENTS)

OCCUPANCIES = R2 (NEW APARTMENTS BLDG.) WITH INCIDENTAL STORAGE & INDUSTRIAL, ORDINARY HAZARD, INCIDENTAL USES

CONSTRUCTION TYPE = V-A (ORDINARY HAZARD)

SPRINKLER ☒ (S13R) NO SPRINKLER ☐

HEIGHTS / STORIES / BUILDING AREA

TABLE 504.3 / 504.4 / 506.2

TABLES	NEW RESIDENTIAL	
	ALLOWED	PROVIDED
HEIGHT (ROOF)	60'-0"	29'-4"
HIGHEST POINT	---	39'-5"
STORIES	4	3
BUILDING FOOTPRINT (ALL OCCUPANCIES)	12,000 SF	9,984.72 SF

THIS BUILDING IS TYPE V-A CONSTRUCTION. AS SUCH, ALL BUILDINGS ELEMENTS LISTED ABOVE SHALL BE NON-COMBUSTIBLE MATERIAL EXCEPT AS ALLOWED BY THE FBC 2017 SECTION 603. *FIRE-RETARDANT-TREATED WOOD* SHALL BE PERMITTED IN NONBEARING PARTITIONS WITH *FIRE-RESISTANCE RATING* IS 2 HOURS OR LESS AND NONBEARING *EXTERIOR WALLS* WHERE NO FIRE RATING IS REQUIRED. ALL THERMAL AND ACOUSTICAL INSULATION, OTHER THAN FOAM PLASTICS, SHALL HAVE A *FLAME SPREAD INDEX* OF NOT MORE THAN 25. SEE FBC 2017 SECTION 603 FOR MORE DETAILS AND EXCEPTIONS.

BUILDING TYPE B

(FBC 2017 WITH ALL SUPPLEMENTS)

OCCUPANCIES = R2 (NEW APARTMENTS BLDG.) WITH INCIDENTAL STORAGE & INDUSTRIAL, ORDINARY HAZARD, INCIDENTAL USES

CONSTRUCTION TYPE = V-A (ORDINARY HAZARD)

SPRINKLER ☒ (S13R) NO SPRINKLER ☐

HEIGHTS / STORIES / BUILDING AREA

TABLE 504.3 / 504.4 / 506.2

TABLES	NEW RESIDENTIAL	
	ALLOWED	PROVIDED
HEIGHT (ROOF)	60'-0"	29'-4"
HIGHEST POINT	---	39'-5"
STORIES	4	3
BUILDING FOOTPRINT (ALL OCCUPANCIES)	12,000 SF	9,984.72 SF

THIS BUILDING IS TYPE V-A CONSTRUCTION. AS SUCH, ALL BUILDINGS ELEMENTS LISTED ABOVE SHALL BE NON-COMBUSTIBLE MATERIAL EXCEPT AS ALLOWED BY THE FBC 2017 SECTION 603. *FIRE-RETARDANT-TREATED WOOD* SHALL BE PERMITTED IN NONBEARING PARTITIONS WITH *FIRE-RESISTANCE RATING* IS 2 HOURS OR LESS AND NONBEARING *EXTERIOR WALLS* WHERE NO FIRE RATING IS REQUIRED. ALL THERMAL AND ACOUSTICAL INSULATION, OTHER THAN FOAM PLASTICS, SHALL HAVE A *FLAME SPREAD INDEX* OF NOT MORE THAN 25. SEE FBC 2017 SECTION 603 FOR MORE DETAILS AND EXCEPTIONS.

COMMUNITY CENTER

(FBC 2017 WITH ALL SUPPLEMENTS)

OCCUPANCIES = A3 (NEW MIX USE BLDG.) ASSEMBLY OCCUPANCY WITH BUSINESS, STORAGE, AND INDUSTRIAL, SPECIAL PURPOSE ORDINARY HAZARD ACCESSORY USE.

CONSTRUCTION TYPE = V-B (ORDINARY HAZARD)

SPRINKLER ☒ (S13R) NO SPRINKLER ☐

HEIGHTS / STORIES / BUILDING AREA

TABLE 504.3 / 504.4 / 506.2

TABLES	NEW RESIDENTIAL	
	ALLOWED	PROVIDED
HEIGHT (ROOF)	60'-0"	15'-0"
HIGHEST POINT	---	34'-0"
STORIES	2	1
BUILDING FOOTPRINT (ALL OCCUPANCIES)	24,000 SF	11,073.88 SF

THIS BUILDING IS TYPE V-B CONSTRUCTION. AS SUCH, ALL BUILDINGS ELEMENTS LISTED ABOVE SHALL BE NON-COMBUSTIBLE MATERIAL EXCEPT AS ALLOWED BY THE FBC 2017 SECTION 603. *FIRE-RETARDANT-TREATED WOOD* SHALL BE PERMITTED IN NONBEARING PARTITIONS WITH *FIRE-RESISTANCE RATING* IS 2 HOURS OR LESS AND NONBEARING *EXTERIOR WALLS* WHERE NO FIRE RATING IS REQUIRED. ALL THERMAL AND ACOUSTICAL INSULATION, OTHER THAN FOAM PLASTICS, SHALL HAVE A *FLAME SPREAD INDEX* OF NOT MORE THAN 25. SEE FBC 2017 SECTION 603 FOR MORE DETAILS AND EXCEPTIONS.

FIRE RESISTANT RATING OF BLDG. ELEMENTS (TABLE 601)				
BUILDING ELEMENTS	REQUIRED FIRE RATING		PROVIDED FIRE RATING	
	BLDG: A/B	COMM.	BLDG: A/B	COMM.
PRIMARY STRUCTURAL FRAME	1	0	1	1
BEARING WALLS				
INTERIOR	1	0	1	0
EXTERIOR	1	0	1	1
NON-BEARING EXTERIOR WALLS	SEE TABLE 602 BELOW			
NON-BEARING INTERIOR WALLS/PARTITIONS	0	0	0	0
FLOOR CONSTRUCTION	1	0	2	N/A
ROOF CONSTRUCTION	1	0	1	1

FIRE RESISTANT RATING REQUIREMENTS FOR EXTERIOR WALLS BASED ON FIRE SEPARATION (TABLE 602) FIRE SEPARATION VARIES. REFER TO CIVIL PLANS. WORST CONDITION SHOWN BETWEEN COMM. CENTER & BLDG. A							
BUILDING	FIRE SEPARATION			REQUIRED FIRE RATING		PROVIDED FIRE RATING	
	BLDG A	BLDG B	COMM.	R2	A3	R2	A3
NORTH WALL	540'-9"	540'-9"	401'-9"	0	0	1	1
SOUTH WALL	58'-5"	56'-9"	192'-5"	0	0	1	1
WEST WALL	44'-6"	46'-11"	46'-11"	0	0	1	1
EAST WALL	46'-11"	73'-2"	46'-11"	0	0	1	1

BUILDING SETBACKS	GROUND THRU 3RD LEVEL		
	BLDG A	BLDG B	COMM.
NORTH WALL	540' - 9" MIN.	540' - 9" MIN.	401' - 9" MIN.
SOUTH WALL	34' - 0" MIN.	25' - 2" MIN.	192' - 5" MIN.
WEST WALL	44' - 6" MIN.	357' - 4" MIN.	204' - 7" MIN.
EAST WALL	386' - 0" MIN.	73' - 2" MIN.	233' - 6" MIN.

MAXIMUM AREAS OF EXTERIOR OPENING. (TABLE 705.8) FIRE SEPARATION VARIES. REFER TO CIVIL PLANS. WORST CONDITION SHOWN BETWEEN COMM. CENTER & BLDG. A.					
WALL	FIRE SEPARATION			UNPROTECTED	PROTECTED
	BLDG A	BLDG B	COMM.		
NORTH WALL	540'-9"	540'-9"	401'-9"	NL*	NL*
SOUTH WALL	58'-5"	56'-9"	192'-5"	NL*	NL*
WEST WALL	44'-6"	46'-11"	46'-11"	NL*	NL*
EAST WALL	46'-11"	73'-2"	46'-11"	NL*	NL*
* NOT PERMITTED *NOT LIMIT					

INCIDENTAL USE		
AREAS	REQUIRED	PROVIDED
STORAGE ROOMS OVER 100 S.F.	1 HOUR OR PROVIDE AUTO-FIRE EXTINGUISHER SYSTEM	1 HOUR WITH 20 MIN. SELF-CLOSING DOOR
WASTE COLLECTION ROOM	1 HOUR WITH 3/4 HOUR SELF-CLOSING DOOR	1 HOUR WITH 3/4 HOUR SELF-CLOSING DOOR (TC VESTIBULES) 2 HOUR WITH 1 1/2 HOUR SELF-CLOSING DOOR (TRASH ROOM)
ELECTRICAL ROOMS	2 HOUR WITH 1 1/2 HOUR SELF-CLOSING DOOR	2 HOUR WITH 1 1/2 HOUR SELF-CLOSING DOOR 2ND DOOR REQ'D IF OVER 800 AMPS

NOTE:
WHEN CONFLICTS EXIST BETWEEN APPLICABLE **ACCESSIBILITY CODES, STANDARDS AND GUIDELINES** THE CODES, STANDARDS AND GUIDELINES PROVIDING THE GREATER DEGREE OF ACCESSIBILITY TAKE PRECEDENCE.

THESE CONSTRUCTION DOCUMENTS ARE COMPLIANT WITH THE ADA ACCESSIBILITY GUIDELINES (ADAAG) AND UNIFORM FEDERAL ACCESSIBILITY STANDARDS (UFAS), WHERE APPLICABLE".

AMENITIES PLUMBING FIXTURE COUNT														
(TABLE 403.1 FPC-PLUMBING - A3 ASSEMBLY)														
TYPE	LEVEL	SPACE / ROOM	S.F.	OCCUP. FACTOR	TOTAL OCCUP.	TOTAL OCCUP. PER SEX	MALE URINALS	WATER CLOSETS		LAVATORIES		UNISEX RESTROOM	FOUNTAIN	SERVICE SINK
								MALE	FEMALE	MALE	FEMALE			
INTERIOR AMENITIES (FOR RESIDENTS ONLY)	Ground Floor	GREAT ROOM	875	1/15 NET	58	29								
	Ground Floor	OFFICE LOBBY	263	1/15 NET	18	9								
	Ground Floor	AP OFFICE	332	1/100 GRS	3	2								
	Ground Floor	CONF. ROOM	230	1/100 GRS	2	1								
	Ground Floor	CF OFFICE	155	1/100 GRS	2	1								
	Ground Floor	UCO OFFICE	304	1/100 GRS	3	2								
	Ground Floor	BREAK ROOM	111	1/15 NET	7	4								
	Ground Floor	MOVIE ROOM	485	1/15 NET	32	16	-	-	-	-	-	-	-	-
	Ground Floor	GAME ROOM	426	1/11 GRS	39	19								
	Ground Floor	GYM	526	1/50 GRS	11	5								
	Ground Floor	ART STUDIO	319	1/20 NET	16	8								
	Ground Floor	MULTI-PURPOSE ROOM	1,703	1/15 NET	114	57								
	Ground Floor	KITCHENETTE	762	1/15 NET	51	25								
	Ground Floor	INTERNET CAFÉ	302	1/100 GRS	3	2								
	Ground Floor	OFFICE	144	1/100 GRS	1	1								
	SUBTOTAL		-	-	360	180	-	1	3	1	1	-	1	1

EXTERIOR AMENITIES (FOR RESIDENTS ONLY)	Ground Floor	POOL (*)	1,950	1/50 GRS	39	20								
	Ground Floor	POOL DECK (*) (MORE THAN 3 TIMES THE SIZE OF THE POOL: 4,197- (1,950 x 3) = -1,653	4,197	-	-	-								
		CALCULATED POOL DECK AREA	0	1/15 GRS	0	0								
	SUBTOTAL				39	20	1	1	1	1	1	-	1	-
TOTAL					399	199	1	2	4	2	2	-	2	1
PROJECT TOTAL REQUIRED							1	2	4	2	2	-	2	1
PROJECT TOTAL PROVIDED							2	4	5	4	4	1	2	1
(*) PER FLORIDA BUILDING CODE - BUILDING SECT.454.1.6.1 AND 454.1.6.1.1														

EGRESS WIDTH (SPRINKLERED BLDG.)		
	STAIR (IN/OCCUP.)	OTHER EGRESS COMPONENTS (IN/OCCUP.)
FFPC 7.3.3.1	0.3	0.2
FBC 1005.3	0.3	0.2
FBC 1005.3.1.1 - 1005.3.2.1	0.2	0.15
IN BUILDINGS EQUIPPED THROUGHOUT WITH AN AUTOMATIC SPRINKLER SYSTEM INSTALLED AND AN EMERGENCY VOICE/ALARM COMMUNICATION SYSTEM IN ACCORDANCE WITH SECTION 907.5.2.2		

TRAVEL DISTANCE (SPRINKLERED BLDG.)			
OCCUP.	MAX. TRAVEL DIST. PERMITTED	MAX. COMMON PATH	DEAD-END LIMIT
R2	325'-0" 200'-0" - UNIT DOOR TO EXIT 250'-0" - FROM REMOTE POINT INSIDE UNIT (FBC)	50'-0" 125'-0" - IN UNIT DOOR & CORRIDOR 50'-0" - OUTSIDE UNIT 125'-0" - INCLUDING TRAVEL WITHIN UNIT AND CORRIDOR. (FBC)	50'-0"
A3	250'-0"	75'-0" (LESS THEN 50 OCCP.) 20'-0" (MORE THEN 50 OCCP.)	20'-0"
U	300'-0"		50'-0"

THE LENGTH OF DEAD END IN CORRIDORS SHALL NOT EXCEED 50 FT. IN FULLY SPRINKLERED BLDG. - FBC 2017 1020.4

CORRIDORS FIRE RATING (TABLE 1020.1)
A3 - (SPRINKLER) >30 OCCUP.= 0HR.

ROOF STRUCTURES
(TOWER, SPIRES, NON-HABITABLE STORAGE, OTHER ROOF STRUCT.)

MAXIMUM HEIGHT 20' ABOVE.

ROOF ASSEMBLIES
(AS PER 2017 FBC TABLE 1505.1)
TYPE OF CONSTRUCTION =
TYPE V-A / V-B
MIN. ROOF COVERING
CLASSIFICATION =
CLASS B / C

WALL PROJECTIONS (705.2.2)
PROJECTIONS FROM WALLS ON TYPE III / IV / V CONSTRUCTION SHALL BE OF ANY APPROVED MATERIALS.

APPLICABLE CODES & FUNDING
* PROJECT TO USE PRIVATE AND GOVERNMENT FUNDING.
* FLORIDA BUILDING CODE 2017 (6TH EDITION)
* FLORIDA FIRE PREVENTION CODE (2015 EDITION)
USED FOR FIRE REVIEW.
* BUILDING CLASSIFIED AS RESIDENTIAL OCCUPANCY PER SECTION 6.1.8.3 PER NFPA 101, LIFE SAFETY CODE, FL 2018 ED.
* FLORIDA BUILDING CODE 2017 (6TH EDITION)
ACCESSIBILITY & 2010 D.O.J - ADA STANDARDS FOR ACCESSIBLE DESIGN

INTERIOR WALLS AND CEILING FINISH REQUIRED AND PROVIDED (SPRINKLER BLDG.) FBC 2017 - TABLE 803.11 AND NFPA 101			
GROUP	VERTICAL EXITS & PASSAGEWAYS	CORRIDORS AND ENCLOSURE FOR EXIT ACCESS STAIRWAYS & RAMPS	ROOMS AND ENCLOSED SPACES
A3	B	B	C
R2	C	C	C
U	NO RESTRICTIONS	NO RESTRICTIONS	NO RESTRICTIONS
INTERIOR WALL AND CEILING FINISH SHALL HAVE A FLAME SPREAD INDEX NOT GREATER THAN THAT SPECIFIED IN TABLE 803.11 FOR THE GROUP AND LOCATION DESIGNATED. INTERIOR WALL AND CEILING FINISH MATERIALS TESTED IN ACCORDANCE WITH NFPA 288 AND MEETING THE ACCEPTANCE CRITERIA OF SECTION 803.1.2.1, SHALL BE PERMITTED TO BE USED WHERE A CLASS A CLASSIFICATION IN ACCORDANCE WITH ASTM E84 OR UL 723 IS REQUIRED.			

FLOOR AREA BREAKDOWN

BUILDING AREA PER FBC 2017

BLDG. TYPE A	LEVEL	GROSS AREA (SF)*
	GROUND FLOOR	9,879.66 SF
	2ND FLOOR	9,984.72 SF
	3RD FLOOR	9,965.32 SF
	TOTAL AREA UNDER ROOF	29,829.70 SF
BLDG. TYPE B	LEVEL	GROSS AREA (SF)*
	GROUND FLOOR	9,879.66 SF
	2ND FLOOR	9,984.72 SF
	3RD FLOOR	9,965.32 SF
	TOTAL AREA UNDER ROOF	29,829.70 SF
COMMUNITY CENTER	LEVEL	GROSS AREA (SF)*
	GROUND FLOOR	11,073.88 SF
	TOTAL AREA UNDER ROOF	11,073.88 SF
*BALCONIES & CARPORTS NOT INCLUDED.		

UNIT TYPE BREAKDOWN

UNITS		UNIT QUANTITY PER FLOOR										GRAND TOTAL
		BUILDING A					BUILDING B					
		TYPE "A"			TYPE "B"		TYPE "A"			TYPE "B"		
		A1	A2 FA	A3	B1	B2 FA	A1	A2 FA	A3	B1	B2 FA	
FLOOR	NET S.F.	712 SF	713 SF	679 SF	1,023 SF	1,023 SF	712 SF	713 SF	679 SF	1,023 SF	1,023 SF	-
	GROSS S.F.	780 SF	786 SF	780 SF	1133 SF	1114 SF	780 SF	786 SF	780 SF	1133 SF	1114 SF	-
GROUND		4	1	0	1	1	4	1	0	1	1	14
2ND		5	1	1	1	1	5	1	1	1	1	18
3RD		5	1	1	1	1	5	1	1	1	1	18
TOTAL TYPE		14	3	2	3	3	14	3	2	3	3	50
		25			6		19			6		

UNIT BREAKDOWN FEATURE LEGEND

FA: FULLY ACCESSIBLE UNIT

HEARING & VISION IMPAIRED (*SEE PLAN FOR LOCATION)

UNITS NOTES

- ALL UNITS MUST COMPLY WITH FHA GUIDELINES. REFER TO SHEET A-6.06.
- 5% OF ALL UNITS SHALL BE FULLY ACCESSIBLE UNITS, AND ADDITIONAL 2% OF THE UNITS SHALL BE HEARING & VISION IMPAIRED UNITS TO COMPLY WITH SECTION 504 OF REHABILITATION ACT OF 1973. REFER TO SHEET A-6.05/A-6.05A.
- RESIDENTIAL UNITS ARE PROVIDED BY ENTITIES SUBJECT TO HUD SECTION 504 REGULATIONS AND SHALL COMPLY WITH 233.2 FBCA

FULLY ACCESSIBLE & HEARING IMPAIRED UNITS

20% OF 50 UNITS = 10 FULLY ACCESSIBLE UNITS 12 PROVIDED

10% OF 50 UNITS = 5 HEARING & VISION IMPAIRED UNITS 6 PROVIDED

- UNITS NOTES**
- ALL UNITS MUST COMPLY WITH FHA GUIDELINES. REFER TO SHEET A-6.06.
 - 5% OF ALL UNITS SHALL BE FULLY ACCESSIBLE UNITS, AND ADDITIONAL 2% OF THE UNITS SHALL BE HEARING & VISION IMPAIRED UNITS TO COMPLY WITH SECTION 504 OF REHABILITATION ACT OF 1973. REFER TO SHEET A-6.05/A-6.05A.
 - RESIDENTIAL UNITS ARE PROVIDED BY ENTITIES SUBJECT TO HUD SECTION 504 REGULATIONS AND SHALL COMPLY WITH 233.2 FBCA
- FULLY ACCESSIBLE & HEARING IMPAIRED UNITS**
- 20% OF 50 UNITS = 10 FULLY ACCESSIBLE UNITS
12 PROVIDED
10% OF 50 UNITS = 5 HEARING & VISION IMPAIRED UNITS
6 PROVIDED

REVISIONS		
Rev #	Revision Description	Date
1	Bldg Review Cmt	09/30/20
2	County Comments	11/20/20
3	County Comments	01/08/21
7	Pre-con RFIs/Coord.	05/03/24
10	Coord./Bulletin #6	09/20/24

SEAL:

THIS DRAWINGS IS THE PROPERTY OF CORWIL ARCHITECTS INC. UNLESS OTHERWISE PROVIDED FOR BY CONTRACT, THE CONTENTS OF THIS DRAWINGS ARE CONFIDENTIAL AND SHALL NOT BE TRANSMITTED TO ANY OTHER PARTY EXCEPT AS AGREED TO BY THE ARCHITECT/ENGINEERS.

DATE: 5-18-2020
JOB No.: 2019-20
DRAWN BY:MA,CM,JM,JW,FG
APPR BY: AMC
PRINTED: 11/13/2024

A-0.02



CORWIL ARCHITECTS
4210 LAGUNA ST. CORAL GABLES FL 33146
LIC.NO. AA-C002151 T.305.448.7383

PROJECT:



10951 SW 84th ST,
MIAMI-DADE, FLORIDA 33173

OWNER:



161 NW 6th ST, Ste. 102