

SOP-17: Reflux Pump P-204 Maintenance Procedure

Document Type: Standard Operating Procedure (SOP)

Target Equipment: P-204 (Reflux Pump, Crude Distillation Unit)

Last Reviewed: January 2025 (Overdue for review)

1. PREPARATION:

Ensure LOTO is applied to P-204 electrical breaker as per OISD-STD-189 Rule 12.1.

2. MECHANICAL SEAL REPLACEMENT:

Remove coupling guard. Detach the pump casing. Remove the mechanical seal assembly.

Install new mechanical seal. NOTE: Use Graphite Grade A gaskets for all flange connections.

3. REASSEMBLY:

Reattach the casing and tighten bolts to 120 Nm. Reinstall the coupling guard securely.

Failure to reinstall the guard is a violation of Factory Act Section 41.

4. TESTING:

Remove LOTO. Start pump P-204 and monitor bearing temperature for 30 minutes. If temperature exceeds 85°C, shut down immediately.