DC3S: Telemetry-Reliability-Weighted Conformal Safety Shield for Battery Dispatch under Degraded Mixed Telemetry

Pratik Niroula
Minnesota State University, Mankato
CIT (Major), Mathematics (Minor)
pratik.niroula@mnsu.edu

Abstract

Battery storage dispatch under degraded telemetry exposes a critical safety gap: when sensor readings are delayed, dropped, or corrupted, uncertainty estimates become miscalibrated and optimization solvers issue unsafe commands. We introduce DC^{3}S (Detect–Calibrate–Constrain–Certify–Shield), a conformal safety shield that scores telemetry reliability at each control step, inflates prediction intervals via a Reliability-Adaptive Conformal Certification (RAC-Cert) law, projects candidate dispatch actions into the feasible safe set, and emits an auditable certificate. Evaluated on a CPSBench harness covering four fault dimensions (dropout, delay-jitter, spikes, out-of-order) across Germany (OPSD, 17,377 rows) and three US balancing authorities (EIA-930 MISO/PJM/ERCOT, ∼13,500 rows each), DC^{3}S achieves **zero true-SOC violations** with a 2.8% intervention rate while the deterministic baseline violates at 3.9% with P95 severity of 333 MWh. Cost-side, DC^{3}S-wrapped dispatch yields 7.11% cost savings, 0.30% carbon reduction, and 6.13% peak shaving on DE; stochastic value of the stochastic solution is positive in both regions (DE VSS = 2,708.61, US VSS = 297,092.71). A nine-row ablation with Wilcoxon signed-rank gates isolates RAC-Cert inflation as the critical safety component. All quantitative claims are locked to versioned run artifacts and validated by an automated claim-consistency checker.

Keywords: conformal prediction, battery dispatch, safety shield, telemetry reliability, robust optimization, cyber-physical systems, uncertainty quantification

1 Introduction

Grid-scale battery energy storage systems (BESS) are increasingly used to absorb renewable variability, shift energy across time, and reduce peak demand. In practice, however, battery dispatch is not driven by clean textbook state variables. It is driven by mixed telemetry: sensor feeds, delayed SCADA-style measurements, derived state estimates, and occasionally corrupted or reordered packets. When those inputs degrade, forecast intervals become miscalibrated and downstream optimization can generate actions that are numerically feasible on observed state while unsafe on the true battery state [17, 18, 19].

This paper studies that failure mode directly. Rather than treating telemetry quality as a separate monitoring concern, we treat it as an input to uncertainty calibration and safe control. The core argument is narrow but operationally important: if telemetry reliability deteriorates, the controller should widen uncertainty sets, solve against those widened sets, repair unsafe candidate actions, and preserve a step-level audit record of what it did and why.

1.1 Operational Motivation

GridPulse is built as a closed decision loop:

Forecast → Optimize → Dispatch → Measure → Monitor.

Prediction quality alone is not enough in that loop. A forecasting model can have strong RMSE while still inducing poor dispatch if its interval calibration is weak under degraded measurements, if the optimizer is exposed to the wrong uncertainty set, or if no shield exists

between the numerical optimizer and the physical battery. DC^{3}S is motivated by that end-to-end control gap rather than by point forecasting alone.

1.2 Research Questions

RQ1 Can one architecture maintain strong forecasting quality across DE and multi-region US regimes while exposing uncertainty in a dispatch-usable form?

RQ2 Does uncertainty-aware dispatch provide measurable value relative to deterministic dispatch under locked run artifacts?

RQ3 Which parts of the shield are actually responsible for safety: telemetry scoring, interval inflation, or action repair?

RQ4 Why do direct cost and peak improvements differ so sharply across DE and US even when stochastic value remains positive in both regions?

1.3 Contributions

1. **Telemetry-aware conformal control wrapper.** We implement RAC-Cert, a reliability-adaptive conformal inflation law that converts telemetry degradation, drift signals, and sensitivity probes into wider dispatch intervals.
2. **Safe dispatch and certification path.** We combine robust dispatch, action repair, and per-step certificate emission in one executable runtime loop.
3. **Locked empirical evidence.** We report zero-violation safety under telemetry faults together with region-scoped decision-impact and stochastic-value artifacts tied to run IDs.
4. **Governance as a bounded contribution.** We treat run manifests, claim matrices, and validator gates as part of the scientific object for this paper, while explicitly not claiming a new general theory of reproducibility [20].

1.4 Contribution Boundary

The main scientific contribution of this thesis is not a deep new conformal theorem. It is the coupling of telemetry reliability, uncertainty inflation, safe dispatch repair, and empirical truth-state safety evaluation inside one auditable control loop. The formal result in this paper is therefore positioned as a supporting correctness proposition: it justifies that monotone inflation cannot reduce marginal coverage relative to the base interval, but it is not presented as the primary novelty claim.

1.5 Paper Roadmap

Sections 2–4 position the work and define the dispatch setting. Sections 5 and 6 describe the forecasting, calibration, and shield mechanics. Sections 7–10 present the empirical evidence, baseline diagnosis, and regime analysis. Sections 11–14 close with governance, validity, limitations, and conclusion. The appendices collect replication commands, artifact inventory, and operational failure modes.

2 Related Work

2.1 Conformal Prediction and Time-Series Calibration

Conformal prediction provides finite-sample prediction sets under exchangeability [1, 2]. Conformalized quantile regression (CQR) wraps quantile models with calibration residuals to produce intervals with stronger practical sharpness [3]. Adaptive conformal inference extends this logic to shifting environments by updating effective miscoverage online [4], and time-series-specific adaptive conformal work studies temporal dependence more explicitly [5]. Beyond exchangeability, weighted and generalized conformal formulations relax the classical assumptions and clarify when coverage guarantees degrade or must be localized [6].

DC^{3}S inherits this literature but differs in a specific way: the calibration mechanism is not driven only by residual history. It is explicitly modulated by telemetry reliability signals and dispatched into a control loop where interval width changes action feasibility, not just forecast reporting.

2.2 Robust, Stochastic, and Risk-Averse Dispatch

Robust optimization provides the language for worst-case hedging inside prescribed uncertainty sets [7, 8]. Stochastic programming gives the standard VSS and EVPI quantities used to quantify the value of uncertainty-aware planning [9]. CVaR formulations provide a practical linearization for tail-risk management in sampled-scenario problems [10]. In the BESS domain, Rosewater et al. [11] show that risk-averse model predictive control can improve storage behavior when model uncertainty is treated explicitly.

DC^{3}S is closest to this risk-aware BESS-dispatch line, but its target failure mode is more specific: uncertainty sets that are miscalibrated because telemetry is degraded, delayed, or stale at the instant of control.

2.3 Safety Shields and Runtime Monitors

Shielding methods restrict the action space so that unsafe commands are prevented before execution [12, 14]. Model-predictive shielding brings those ideas closer to control and optimization [13]. Runtime verification literature formalizes monitoring and post-hoc checking of execution traces against safety properties [16], and simple runtime fallback architectures show how safe modes can be used when advanced controllers are no longer trustworthy [15].

DC^{3}S combines these ideas at dispatch time. It does not merely monitor a trace or switch to a backup controller. It scores telemetry quality, modifies the optimizer's uncertainty interface, repairs unsafe actions, and emits a certificate that records the full safety-relevant context of the step.

2.4 Telemetry Reliability and CPS Fault Models

Industrial-control and CPS security literature already makes clear that dropout, delay, spike injection, and reordered observations are ordinary failure modes rather than pathological corner cases [17]. Anomaly-detection literature gives the statistical vocabulary for staleness, spikes, and outlier behavior [18]. BESS review work further motivates why those failures matter physically: mismanaged state estimates and unsafe charge/discharge commands can damage storage assets and undermine grid-support value [19].

2.5 Governance and Reproducibility

This paper makes a bounded governance claim: locked metrics, run-scoped provenance, and validator gates are treated as a first-class part of the publication artifact. That narrower claim is aligned with the reproducibility standards discussed by Pineau et al. [20], but it is not presented as a new general governance framework.

3 Background, Preliminaries, and System Context

3.1 GridPulse System Context

GridPulse is implemented as a forecast-to-dispatch stack whose main layers are data preparation, forecasting, uncertainty calibration, optimization, monitoring, and API/dashboard serving. DC^{3}S sits at the dispatch boundary: it receives observed telemetry and forecast intervals, widens those intervals when telemetry quality or drift risk deteriorates, and prevents physically unsafe commands from reaching the battery.



Figure 1: GridPulse architecture with DC^{3}S at the dispatch boundary. The shield consumes telemetry quality, forecast intervals, and optimizer output before command execution.

Table 1: Component-to-code map for the main thesis surfaces.

Layer	Purpose	Primary paths
Data pipeline	Region features, splits, and profile locks	`src/gridpulse/data_pipeline/`, `src/gridpulse/pipeline/run.py`
Forecasting	GBM and deep-baseline train/predict flows	`src/gridpulse/forecasting/`
Uncertainty	Conformal, adaptive, and residual calibration	`src/gridpulse/forecasting/uncertainty/conformal.py`
Optimization	Deterministic, robust, and baseline dispatch	`src/gridpulse/optimizer/`
DC3S	Reliability, drift, shield, certificate, state	`src/gridpulse/dc3s/`
Monitoring	Drift checks and retraining logic	`src/gridpulse/monitoring/`
API + dashboard	Runtime routes and operator-facing inspection	`services/api/`, `frontend/`

3.2 Component-to-Code Map

3.3 Artifact Contracts and Profile Lock

The thesis uses a locked profile family rather than free-floating report values. The main artifact interfaces are: dashboard metrics (`data/dashboard/de_metrics.json`, `data/dashboard/us_metrics.json`), dashboard profiles (`data/dashboard/de_stats.json`, `data/dashboard/us_stats.json`, `data/dashboard/manifest.json`), impact summaries (`reports/impact_summary.csv`, `reports/eia930/impact_summary.csv`), stochastic summaries (`reports/research_metrics_de.csv`, `reports/research_metrics_us.csv`), and publication tables under `reports/publication/`. Any manuscript claim that depends on those interfaces is treated as invalid unless it can be traced back to one of them.

3.4 Dataset Scope

The canonical dataset lock is summarized in Table 2. DE covers 17,377 hourly rows from OPSD, and the canonical US dashboard profile used by the locked manuscript covers 13,638 hourly rows from EIA-930 MISO. The release-family assets additionally document PJM and ERCOT so that the conference variant can discuss multi-BA US evidence without changing the canonical thesis lock.

Table 2: Dataset summary for publication protocol and benchmark scope.

Dataset Key	Dataset	Country	Start
DE	Germany (OPSD)	DE	2018-10-07
DE	Germany (OPSD)	DE	2018-10-07
DE	Germany (OPSD)	DE	2018-10-07
US_MISO	USA (EIA-930 MISO)	US	2024-07-01
US_MISO	USA (EIA-930 MISO)	US	2024-07-01
US_MISO	USA (EIA-930 MISO)	US	2024-07-01
US_PJM	USA (EIA-930 PJM)	US	2024-07-01
US_PJM	USA (EIA-930 PJM)	US	2024-07-01
US_PJM	USA (EIA-930 PJM)	US	2024-07-01
US_ERCOT	USA (EIA-930 ERCOT)	US	2024-07-01
US_ERCOT	USA (EIA-930 ERCOT)	US	2024-07-01
US_ERCOT	USA (EIA-930 ERCOT)	US	2024-07-01

3.5 Pipeline Architecture and Runtime Interfaces

The GridPulse pipeline follows a strict stage ordering that determines how data flows through the system. Each stage has a well-defined interface contract:

1. **Ingestion**: Raw time-series loading from OPSD (DE) or EIA-930 (US). Required columns include timestamp, load, wind generation, and solar generation. Schema validation checks for duplicate timestamps, temporal gaps, missingness percentage, and negative values before proceeding.
2. **Temporal feature construction**: Hour-of-day, day-of-week, month, season (1=winter through 4=fall), weekend indicator, and daylight flag. These features are deterministic and leakage-free.
3. **Domain feature construction**: Ramp features (Δ_{1h}, Δ_{24h}) for load, wind, and solar capture recent momentum. Peak-period flags (`is_morning_peak` for hours 7–10, `is_evening_peak` for hours 17–21) encode tariff-relevant operating periods. Holiday features (pre/post/current) capture demand-regime shifts.

4. **Lag and rolling features**: For each target, lags at 1, 24, and 168 hours plus rolling mean and standard deviation at 24-hour and 168-hour windows. This is where the tabular representation captures the sequential structure that deep models would otherwise learn from raw sequences.

5. **Price and carbon signal construction**: Synthetic signals based on time-of-day and seasonality patterns when market data is unavailable. These are engineering proxies, as noted in Section 13.

6. **Split and profile lock**: Temporal train/test splits with the 24-hour gap. Profile lock metadata is written to `data/dashboard/manifest.json` to freeze the evidence base.

7. **Forecasting and calibration**: GBM/LSTM/TCN training with CQR calibration on held-out calibration slices.

8. **Dispatch and certification**: DC^{3}S-wrapped optimization with per-step certificate emission to DuckDB.

The interface between stages 6 and 7 is particularly important: the profile lock ensures that any model trained after the lock uses the same feature schema, split boundaries, and target definitions. The interface between stages 7 and 8 is where RAC-Cert converts forecast intervals into dispatch-usable uncertainty sets.

3.6 Truth vs. Observed State

The most important background distinction in this paper is between true and observed state:

- $\mathrm{SOC}_t^{\mathrm{obs}}$ is what the controller sees after telemetry degradation.
- $\mathrm{SOC}_t^{\mathrm{true}}$ is the physical state used for safety evaluation.

That split is what allows the benchmark to expose hidden safety failures. A controller can look safe if evaluated only on observed state while simultaneously violating the true battery envelope.

4 Problem Formulation

4.1 Dispatch Setting

At each time step t, the controller observes telemetry $\tilde{\mathbf{z}}_t \in \mathbb{R}^d$ containing load, wind, solar, price, and battery state signals, and chooses a dispatch action $a_t \in \mathcal{A}$. A degradation operator $\mathcal{D}$ maps clean telemetry $\mathbf{z}_t$ to observed telemetry $\tilde{\mathbf{z}}_t = \mathcal{D}(\mathbf{z}_t)$ through dropout, delay, spikes, or reordering.

Definition 1 (Telemetry degradation)**.** *A degradation operator $\mathcal{D} : \mathbb{R}^d \to \mathbb{R}^d$ introduces one or more of: random zeroing, time shift, additive outlier injection, or permutation of the recent telemetry window.*

4.2 Battery Dynamics and Feasible Set

The true SOC evolves as

$$\mathrm{SOC}_{t+1}^{\mathrm{true}} = \mathrm{SOC}_t^{\mathrm{true}} + \frac{\eta_c[a_t]^+ - [a_t]^-/\eta_d}{E_{\max}}\Delta t, \tag{1}$$

where η_c and η_d are charge/discharge efficiencies and $E_{\max}$ is rated capacity. The feasible action set enforces SOC, power, and ramp limits:

$$\mathcal{A}_t = \big\{a \in [-P_{\max}, P_{\max}] : \mathrm{SOC}^{\min} \le \mathrm{SOC}_{t+1}^{\mathrm{true}}(a) \le \mathrm{SOC}^{\max}, \tag{2}$$

4.3 Objective

Dispatch balances energy cost, carbon, peak exposure, and throughput degradation:

$$\min_{a_{1:T}} \sum_{t=1}^{T} \lambda_c c_t a_t + \lambda_g g_t [a_t]^+ + \lambda_p \max(0, L_t + a_t - P_{\mathrm{cap}}) + \lambda_d |a_t|. \tag{3}$$

This is a pragmatic engineering objective, not a claim of complete market realism. The thesis interprets it as a comparative decision objective under locked artifacts rather than as a perfect representation of every settlement rule.

4.4 Calibration Gap

Base conformal prediction constructs intervals $\hat{C}_t(\alpha)$ targeting coverage $1-\alpha$. Under telemetry degradation, conformity scores shift because the model is no longer seeing the same

input quality that supported the original calibration. The resulting failure mode is

$$\Pr\Big(Y_t \in \hat{C}_t(\alpha) \mid \mathcal{D} \text{ active}\Big) < 1 - \alpha. \tag{4}$$

DC^{3}S is designed to close that gap operationally by widening intervals when telemetry quality and drift signals indicate that the base interval is no longer trustworthy enough for dispatch.

4.5 Baseline Policies

Three baseline notions appear throughout the thesis:

1. **B1**: deterministic LP dispatch without uncertainty intervals.
2. **B2**: grid-only dispatch with no battery action.
3. **B3**: naive fixed-window battery heuristic.

Canonical DE and US impact percentages are B1-versus-B2 comparisons. Stochastic metrics, by contrast, compare robust and deterministic stochastic formulations within pinned run families rather than B2.

5 Forecasting and Uncertainty Method

5.1 Locked Forecasting Layer

The locked comparison set contains GBM (LightGBM), LSTM, and TCN. The wider training stack also supports N-BEATS, TFT, and PatchTST, but those models are candidate baselines for future release-family reruns rather than part of the canonical dashboard metrics reported in this thesis.

5.2 Training Setup and Feature Engineering

The locked training configuration uses a 24-hour forecast horizon, a 168-hour lookback, 10-fold time-aware cross-validation, and a 24-hour temporal gap. These settings matter twice: they make forecasting comparisons leakage-safe, and they define the input structure that later influences optimization and calibration behavior.

The feature engineering pipeline follows a leakage-safe temporal framing where all lag and rolling features use strictly past data relative to the forecast origin. The feature families are:

1. **Weather features** (40 in DE, 56 in US): Temperature, humidity, precipitation, cloud cover, and wind speed at multiple heights and geographic locations. The US set is larger because it spans three balancing authorities with distinct weather stations.
2. **Lag features** (36 in DE, 42 in US): Lags at 1, 24, and 168 hours for each target and key exogenous variables, plus rolling mean and standard deviation at 24-hour and 168-hour windows. The US pipeline includes additional lagged price and carbon-intensity variables.
3. **Calendar features** (6 in both): Hour-of-day, day-of-week, month, weekend indicator, season, and daylight flag. Holiday encoding (pre/post/current) uses either the `holidays` library or a region-specific CSV.
4. **Domain features**: Ramp signals (Δ_{1h} and Δ_{24h}) for each target, peak-period indicators for morning (7–10h) and evening (17–21h) windows.

The interaction between feature design and model selection is central to the baseline diagnosis (Section 9): these rich tabular features already encode much of the sequential structure that LSTM and TCN would otherwise need to learn, which contributes to GBM's dominance in the locked results.

5.3 CQR and Adaptive Conformal Layer

Each target is wrapped by conformalized quantile regression. The calibration procedure follows Romano et al. [3]: fit lower and upper quantile predictors, compute conformity scores on a calibration slice, and enlarge the raw quantile band by the empirical $(1-\alpha)$ residual quantile. Adaptive conformal logic then adjusts effective coverage behavior online in the style of Gibbs and Candès [4], while time-series adaptation and regime-aware binning are used to acknowledge temporal dependence and volatility segmentation [5, 6].

Table 3: Regime-group CQR coverage and interval width summary.

target	group	picp_90	mean_width	sample_count
load_mw	low	0.852381	1244.838584	840
load_mw	mid	0.883333	937.421883	840
load_mw	high	0.910714	1028.215886	840
wind_mw	low	0.976190	719.719141	840
wind_mw	mid	0.934524	811.954083	840
wind_mw	high	0.900000	969.921806	840
solar_mw	low	0.802381	891.551155	840
solar_mw	mid	0.822485	1016.613362	845
solar_mw	high	0.737725	1206.156144	885

5.4 RAC-Cert Inflation Law

At each step, DC^{3}S computes a telemetry reliability score $w_t \in [0, 1]$ from missingness, staleness, spikes, and ordering penalties. That score, together with a drift flag d_t and a sensitivity probe s_t, widens the base conformal interval:

$$\hat{C}_t^{\mathrm{RAC}}(\alpha) = \hat{C}_t(\alpha) \cdot (1 + \kappa_r(1 - w_t) + \kappa_d d_t + \kappa_s s_t) \tag{5}$$

The inflation factor is clipped below by 1, so the shield never narrows the original calibrated interval in response to degraded telemetry.

5.5 Supporting Proposition and Contribution Boundary

Proposition 1 (Coverage preservation under monotone inflation)**.** *If the base conformal predictor satisfies* $\Pr(Y_t \in \hat{C}_t(\alpha)) \geq 1 - \alpha$ *under the clean distribution, and RAC-Cert only inflates intervals so that* $\hat{C}_t(\alpha) \subseteq \hat{C}_t^{\mathrm{RAC}}(\alpha)$*, then*

$$\Pr(Y_t \in \hat{C}_t^{\mathrm{RAC}}(\alpha)) \geq 1 - \alpha.$$

Proof. The result follows by set inclusion: if the inflated interval contains the base interval pointwise, then the event that Y_t lies inside the base interval is a subset of the event that it lies inside the inflated interval. □

This proposition is intentionally modest. It confirms that monotone inflation does not reduce marginal coverage relative to the base interval, but it does not establish conditional coverage or optimality. The paper's main contribution is therefore empirical and control-theoretic: telemetry-aware interval construction plus safe dispatch behavior under faulted measurements.

5.6 Alternative Inflation Laws

While the locked evaluation uses the linear RAC-Cert law (Equation (5)), the implementation supports two additional inflation formulations for comparison and future study:

FTIT-RO law. The Fault-Tolerant Interval Tracking with Robust Optimization (FTIT-RO) law derives a concentration-inequality-based inflation factor:

$$\kappa_{\mathrm{FTIT}} = 1 + \frac{\sqrt{2\sigma_t^2 \ln(1/(\delta \cdot w_t))}}{2\hat{q}}, \tag{6}$$

where σ_t^2 is an exponentially weighted variance estimate of recent residuals and $\hat{q}$ is the base conformal quantile. This law inflates more aggressively under high variance and low reliability, providing a probabilistic rather than linear scaling.

Ambiguity widening. An optional additive widening can supplement either law:

$$[\ell_t^{\mathrm{wide}}, u_t^{\mathrm{wide}}] = [\ell_t - \lambda_{\mathrm{MW}} \cdot \min(\epsilon_{\max}, \max(0, 1 - w_t)),\ u_t + \lambda_{\mathrm{MW}} \cdot \mathrm{m} \tag{7}$$

where λ_{MW} controls the additive widening magnitude and $\epsilon_{\max}$ caps the maximum additive expansion. This provides a non-multiplicative safety margin for scenarios where the base interval is very narrow.

The locked evaluation uses only the linear law; the FTIT-RO and ambiguity variants are documented for completeness and as candidates for future release-family comparisons.

6 Safe Dispatch and DC3S Shield

6.1 Robust Dispatch

Given RAC-inflated lower and upper trajectories, DC^{3}S solves a two-scenario robust dispatch problem:

$$\min_{a_{1:T}} \max_{Y \in \{\ell^{\mathrm{RAC}}, u^{\mathrm{RAC}}\}} \sum_{t=1}^{T} J(a_t, Y_t), \tag{8}$$



Figure 2: RAC-Cert sensitivity signal versus interval width expansion across controllers. Higher degradation yields larger inflation.

where J is the multi-objective cost from Equation (3). In implementation, this is solved via an epigraph LP/MIP formulation.

6.2 CVaR Comparator

For comparison, the experiments also include a CVaR dispatch baseline using the Rockafellar–Uryasev linearization:

$$\min_{a,\eta} \ \eta + \frac{1}{(1-\beta)S} \sum_{s=1}^{S} u_s, \quad u_s \geq J_s(a) - \eta, \quad u_s \geq 0 \tag{9}$$

6.3 Action Repair

If a candidate dispatch action violates any element of $\mathcal{A}_t$, DC^{3}S projects it to the nearest feasible action:

$$a_t^{\text{safe}} = \arg\min_{a \in \mathcal{A}_t} \|a - a_t^*\|_2. \tag{10}$$

This step is what turns a risk-aware optimizer into a safe controller. Without it, the optimizer can still output commands that are numerically attractive yet physically inadmissible once true state is accounted for.

6.4 Certificate Emission

Each step emits a certificate recording time, reliability score, inflated interval, candidate action, repaired action, solver status, observed SOC, and margin to the nearest active constraint. The certificate chain is persisted so that every safety-relevant control intervention can be audited post hoc.



Figure 3: DC^{3}S runtime step: observe → score → inflate → solve → repair → certify.

6.5 One-Step Algorithm

Algorithm 1 DC^{3}S dispatch step

Require: Telemetry $\tilde{\mathbf{z}}_t$, base interval $\hat{C}_t(\alpha)$, optimizer $\mathcal{O}$
Ensure: Safe action a_t^{safe}, certificate $\mathcal{C}_t$

$w_t \leftarrow \textsc{ReliabilityScore}(\tilde{\mathbf{z}}_t)$
$d_t \leftarrow \textsc{DriftDetect}(\tilde{\mathbf{z}}_t)$
$s_t \leftarrow \textsc{SensitivityProbe}(\tilde{\mathbf{z}}_t)$
$\hat{C}_t^{\text{RAC}} \leftarrow \hat{C}_t(\alpha) \cdot (1 + \kappa_r(1 - w_t) + \kappa_d d_t + \kappa_s s_t)$
$a_t^* \leftarrow \mathcal{O}(\hat{C}_t^{\text{RAC}})$
$a_t^{\text{safe}} \leftarrow \textsc{Project}(a_t^*, \mathcal{A}_t)$
$\mathcal{C}_t \leftarrow \textsc{EmitCert}(t, w_t, \hat{C}_t^{\text{RAC}}, a_t^*, a_t^{\text{safe}})$
return $a_t^{\text{safe}}, \mathcal{C}_t$

6.6 FTIT State Tracking

The Fault-Tolerant Interval Tracking (FTIT) variant maintains a rolling fault-rate estimate that adapts the reliability signal over time rather than computing it from a single telemetry snapshot. At each step t, FTIT updates five fault counters:

$$n_{t+1} = \gamma_d \cdot n_t + 1, \qquad s_{t+1}^{(k)} = \gamma_d \cdot s_t^{(k)} + \mathbb{1}[\text{fault}_k \text{ active}], \tag{11}$$

where $\gamma_d = 0.98$ is the exponential decay factor and $k \in \{\text{dropout, stale, delay_jitter, ooo, spikes}\}$. The empirical fault rate is $p_t^{(k)} = s_t^{(k)} / \max(n_t, \epsilon)$, and the FTIT reliability weight is the product:

$$w_t^{\text{FTIT}} = \prod_k \left[\text{clip}\left(1 - p_t^{(k)},\ \epsilon,\ 1\right)\right]^{\alpha_k}, \tag{12}$$

where $\alpha_k = 1.0$ by default gives equal weight to each fault channel.

FTIT additionally maintains a SOC tube that contracts the feasible envelope when reliability degrades:

$$\gamma_{\mathrm{MW}} = \gamma_{\min} + (1 - w_t)^{\gamma_{\mathrm{pow}}} \cdot (\gamma_{\max} - \gamma_{\min}), \quad (13)$$

where γ_{MW} is the instantaneous tube width that is accumulated as an exponentially weighted margin e_t. The resulting SOC tube $[\mathrm{SOC}_{\min} + e_t,\ \mathrm{SOC}_{\max} - e_t]$ provides a state-dependent safety margin that grows when telemetry quality deteriorates and shrinks when it recovers.

This FTIT mechanism is what distinguishes the DC^{3}S FTIT controller from the base DC^{3}S wrapped variant in the experimental results: the base variant uses single-step reliability, while FTIT uses the rolling estimate.

6.7 DC^{3}S Configuration Detail

The locked DC^{3}S configuration (`configs/dc3s.yaml`) defines the operational parameters of each shield component. Table 4 summarizes the key values.

Several design choices merit comment. First, `k_drift` $= 0$ in the locked run means that drift inflation is disabled in the canonical evaluation; the drift detector still runs (Page-Hinkley with $\delta = 0.01$, $\lambda = 5$) but its signal only affects the reserve SOC margin rather than inflating the conformal interval. This is a conservative choice that isolates the reliability and sensitivity channels as the primary inflation drivers. Second, the reliability floor $w_{\min} = 0.05$ prevents the score from collapsing to zero under extreme degradation, which would cause division instability in downstream calculations. Third, the shrinkage time constant $\tau = 30$ steps (30 hours at hourly resolution) means that after telemetry recovers, the inflation factor decays slowly toward the base width—preventing oscillation between inflated and nominal widths that could destabilize the optimizer.

Table 4: DC^{3}S configuration parameters from the locked `configs/dc3s.yaml`.

Parameter	Value	Role
Inflation law		
$\kappa_{\mathrm{quality}}$ (`k_quality`)	0.2	Reliability-driven inflation
κ_{drift} (`k_drift`)	0.0	Drift-driven inflation (disa
$\kappa_{\mathrm{sensitivity}}$ (`k_sensitivity`)	0.4	Sensitivity-driven inflation
`infl_max`	2.0	Maximum total inflation r
α_0 / $\alpha_{\min}$	0.10 / 0.02	Base / floor miscoverage l
RAC-Cert		
$\beta_{\mathrm{reliability}}$	0.7	Reliability mixing weight
$\beta_{\mathrm{sensitivity}}$	0.5	Sensitivity mixing weight
τ_{shrink} (`qhat_shrink_tau`)	30.0	Shrinkage time constant (
`max_q_multiplier`	3.0	Maximum conformal quan
$\varepsilon_{\mathrm{sens}}$	25.0 MW	Sensitivity probe perturba
Reliability scoring		
λ_{delay}	0.002	Delay penalty per second
β_{spike}	0.25	Spike detection penalty w
γ_{ooo}	0.35	Out-of-order penalty weig
$w_{\min}$	0.05	Reliability score floor
Drift detection		
Detector	Page-Hinkley	Online change-point detec
δ_{PH}	0.01	PH detection threshold
λ_{PH}	5.0	PH forgetting factor
Warmup / cooldown	48 / 24	Steps before/after drift ac
Shield and battery		
Mode	projection	Action repair method
Reserve SOC (drift)	8%	Extra SOC margin during
CVaR β	0.90	CVaR confidence for comp

7 Experimental Protocol

7.1 Forecasting Evaluation

The forecasting layer compares GBM, LSTM, and TCN on the three primary targets: load,

wind, and solar. All use the same 24-hour horizon, 168-hour lookback, and temporal cross-validation framing. This preserves a common data interface while allowing different inductive biases to compete under the same locked evidence policy.

7.2 Fault Injection Benchmark

CPSBench injects six fault families across multiple severity levels. Each fault is parameterized by a rate and magnitude, and multiple faults can be composed in `drift_combo` scenarios. All safety is evaluated on true SOC, not observed SOC.

Table 5: CPSBench fault families and their injection mechanisms. Rates are per-timestep probabilities; magnitudes control severity.

Fault	Mechanism	Default rate	Observable effect
Dropout	Set load/renewables to NaN; forward-fill downstream	8%	Missing values in telemetry vector
Delay-jitter	Shift arrival timestamp by $\mathcal{N}(\mu_d, 0.25\mu_d)$ seconds	30%	Stale or future-dated observations
Out-of-order	Rewind timestamp by 1–3 hours	10%	Temporal misordering in recent window
Spikes	Scale load by $\sim \mathcal{N}(1.35\sigma, \cdot)$, renewables similarly	5%	Large transient deviations from true signal
Stale sensor	Repeat previous values for 4-hour windows	—	Frozen telemetry with no NaN indicator
Covariate drift	Multiply observed renewables by 0.72 after drift step	—	Systematic bias in renewable observations

The distinction between dropout and stale-sensor faults is operationally important: dropout produces NaN values that are detectable by simple missingness checks, while stale-sensor faults repeat valid-looking values that require staleness detection. Similarly, delay-jitter shifts the arrival timestamp but leaves the signal magnitude intact, while spikes corrupt the magnitude but preserve timing. The `drift_combo` scenario composes covariate drift with label drift (true load increases by 1.15× plus a 1,300 MW ramp) to simulate a genuine operating-regime change.

CPSBench maintains separate truth and observed trajectories through a `BatteryPlant` simulator that applies charge/discharge commands to the true SOC state. The plant tracks $\mathrm{SOC}^{\mathrm{true}}$ using the dynamics from Equation (1) *without* clamping, so that violations produce physically meaningful severity measurements rather than being silently clipped.

7.3 Controllers

Five controllers are compared:

1. deterministic LP,
2. robust fixed-interval,
3. CVaR interval,
4. DC^{3}S wrapped, and
5. DC^{3}S FTIT.

7.4 Metrics

The evaluation uses three metric families that correspond to the three system surfaces—forecasting, uncertainty calibration, and control safety.

Forecast metrics. RMSE, MAE, sMAPE, and R^2 are computed on point predictions for each target–region–model combination. sMAPE is reported for completeness but is unreliable for near-zero targets (solar at night-time), where R^2 and RMSE are more informative.

Uncertainty metrics. Prediction interval coverage probability (PICP) at nominal 90% and 95% levels, mean interval width, pinball loss at the $\alpha/2$ and $1-\alpha/2$ quantiles, and the Winkler score that penalizes both width and miscoverage:

$$W_t(\alpha) = (u_t - \ell_t) + \frac{2}{\alpha}(\ell_t - Y_t)\mathbb{1}[Y_t < \ell_t] + \frac{2}{\alpha}(Y_t - u_t)\mathbb{1}[Y_t > u_t]. \tag{14}$$

Control metrics. The primary safety metric is the true-SOC violation rate: the fraction of steps where $\mathrm{SOC}_t^{\mathrm{true}}$ falls outside $[\mathrm{SOC}_{\min}, \mathrm{SOC}_{\max}]$. Violation severity (P95) measures the magnitude of the worst violations

in MWh. The intervention rate is the fraction of steps where the shield modifies the optimizer's candidate action ($\|a_t^{\text{safe}} - a_t^*\| > \epsilon$, with $\epsilon = 10^{-6}$ MW). Additional safety metrics include: unsafe command rate (commands that *would* violate if executed), BMS trip rate (simulated battery management system shutdowns), and grid import violation rate. Economic metrics include total dispatch cost, carbon emissions, peak demand, and the stochastic value metrics VSS and EVPI.

7.5 Statistical Protocol

Randomized experiments use 10 seeds. Safety comparisons are tested with Wilcoxon signed-rank tests at $p < 0.01$, and ablations use both relative-reduction and significance gates. This design is meant to keep the main claims from resting on a single favorable seed or a loosely interpreted ablation delta.

7.6 Evidence Lock

The thesis binds its quantitative claims to the following locked artifacts:

- DE stochastic run: `20260217_165756`
- US stochastic run: `20260217_182305`
- dashboard profile lock timestamp: `2026-02-17T11:15:38.623283`

8 Results

8.1 Forecast Quality Across Model Families

Before evaluating shield behavior, we report the locked forecast baselines that the optimizer consumes. Tables 6 and 7 summarize the three model families across three targets in each region. These are the canonical dashboard-locked metrics; all downstream dispatch and safety results depend on these forecasts.

Interpretation. GBM achieves $R^2 > 0.99$ on all six target–region combinations, with RMSE an order of magnitude below deep baselines. LSTM and TCN show particular weakness on wind and solar, where the signal-to-noise ratio is lower and the precomputed tab-

Table 6: DE forecast baselines (17,377 hourly rows, 93 features). GBM dominates across all targets.

Target	Model	RMSE	MAE	sMAPE (%)	R^2
Load	GBM	267.51	167.49	0.35	0.9991
	LSTM	3,474.78	2,722.50	5.38	0.8498
	TCN	2,668.05	2,031.12	3.94	0.9114
Wind	GBM	183.93	118.19	2.29	0.9993
	LSTM	6,735.07	5,511.23	60.85	0.1545
	TCN	9,196.16	7,167.41	76.67	−0.576
Solar	GBM	251.44	121.22	69.27	0.9992
	LSTM	4,079.38	2,835.74	109.44	0.8007
	TCN	2,702.34	1,583.05	93.76	0.9125

Table 7: US forecast baselines (13,638 hourly rows, 114 features). GBM again dominates; deep baselines show larger degradation on wind and solar.

Target	Model	RMSE	MAE	sMAPE (%)	R^2
Load	GBM	162.89	123.23	0.17	0.9996
	LSTM	4,767.14	3,835.32	5.24	0.6014
	TCN	3,850.49	2,877.31	3.82	0.7399
Wind	GBM	269.23	144.66	1.75	0.9982
	LSTM	6,301.91	5,234.31	42.59	0.0627
	TCN	7,187.54	5,930.74	47.65	−0.219
Solar	GBM	208.92	74.93	45.45	0.9962
	LSTM	1,781.97	1,055.34	136.92	0.7135
	TCN	—	—	—	—

ular features already encode much of the sequential structure that recurrent and convolutional architectures would otherwise learn. The solar sMAPE values are inflated by near-zero nighttime denominators and should not be interpreted as proportional error rates; R^2 and RMSE are more informative for these targets. This GBM dominance is analyzed further in Section 9.

8.2 Safety Under Telemetry Faults

Table 8: Main safety and cost outcomes under telemetry faults.

controller	true_soc_violation_rate_mean	true_soc_violation_rate_ci_low	true_soc_violation_r
cvar_interval	0.255		
dc3s_ftit	0.000		
dc3s_wrapped	0.000		
deterministic_lp	0.039		
robust_fixed_interval	0.255		

The central result is that both DC^{3}S variants maintain zero true-SOC violations across the full fault sweep, while the deterministic baseline violates at 3.9% (CI: [3.0%, 4.8%]) with P95 severity of 333 MWh, and the CVaR baseline violates at 25.6% with P95 severity of 0.28 MWh. The contrast between these two baselines is instructive: the deterministic controller has *infrequent but severe* violations because it makes large dispatch commitments without uncertainty protection, whereas CVaR has *frequent but mild* violations because its scenario sampling does not track true battery state under telemetry degradation.

DC^{3}S FTIT intervenes on only 2.8% of steps (CI: [2.2%, 3.4%]), demonstrating that safety does not require blanket override of the optimizer. In the remaining 97.2% of steps, the optimizer's candidate action already lies within the feasible safe set. The shield activates precisely when telemetry quality deteriorates enough to widen intervals beyond what the optimizer alone can accommodate.

This result answers RQ1 and RQ3: RAC-Cert inflation combined with action repair achieves zero-violation safety without excessive conservatism. The low intervention rate implies that the shield's cost is concentrated in genuinely degraded conditions rather than spread uniformly across all operating states.



Figure 4: True-SOC violation rate versus fault severity. DC^{3}S remains at zero across all severity levels while baseline controllers degrade monotonically with increasing fault intensity.



Figure 5: P95 true-SOC violation severity under the aggregate fault sweep. The deterministic baseline's severity grows superlinearly; DC^{3}S remains at zero.

8.3 Cost–Safety Frontier

The cost–safety frontier visualizes the fundamental tradeoff: the deterministic baseline achieves low cost in some conditions precisely because it is willing to be unsafe under degraded telemetry. The CVaR controller sits at an intermediate position—lower violation rate than deterministic but far above zero, with modest cost improvement. DC^{3}S occupies the dominant position: zero violations with competitive cost.

The mechanism behind this Pareto dominance is conditional conservatism. When telemetry is healthy ($w_t \approx 1$), RAC-Cert applies minimal inflation, and the optimizer operates near the deterministic frontier. When telemetry degrades ($w_t \ll 1$), the inflation factor grows, the robust formulation hedges more



Figure 6: Cost–safety Pareto frontier. DC^{3}S dominates the zero-violation, low-cost region. The deterministic baseline is cheap but unsafe; CVaR achieves moderate cost improvement at unacceptable violation rates.

aggressively, and action repair catches any remaining infeasibility. The cost of this conservatism is concentrated in the 2.8% of steps where the shield intervenes, keeping aggregate cost impact small.

DC^{3}S wrapped shows a -1.9% cost delta (modest cost increase relative to deterministic), while FTIT achieves $+3.0\%$ cost *improvement* due to more conservative scheduling that avoids peak-hour penalties. This is the practical answer to RQ2: uncertainty-aware safe dispatch is not just safer but can be cost-competitive or cost-superior to naive dispatch.

8.4 Locked Region-Level Impact and Stochastic Value

Table 9: Locked region-level decision impact (percentage).

Region	Cost (%)	Carbon (%)	Peak (%)	VSS	Run ID
DE	7.11	0.30	6.13	2,708.61	20260217 _165756
US	0.11	0.13	0.00	297,092.71	20260217 _182305

DE shows substantially stronger direct decision gains than US in the locked artifacts: 7.11% cost savings ($10.997M absolute difference), 0.30% carbon reduction (4.4 Mt), and 6.13% peak shaving (3.2 GW). US remains positive but weak in direct impact: 0.11% cost savings ($0.52M), 0.13% carbon reduction (5.2 Mt), and 0.00% peak shaving (no peak improvement at all).

Table 10: Absolute decision impact: B1 (deterministic LP dispatch) versus B2 (grid-only, no battery). All values from locked artifacts.

Region	Metric	Baseline (B2)	GridPulse (B1)	Δ (abs
DE	Cost ($M)	154.77	143.78	–
	Carbon (Mt)	1,461.6	1,457.2	-
	Peak (GW)	52.17	48.97	-
US	Cost ($M)	461.36	460.84	-
	Carbon (Mt)	3,907.8	3,902.6	-
	Peak (GW)	74.74	74.74	

Table 11: Baseline policy comparison (DE). B1 = deterministic LP, B2 = grid-only, B3 = naive battery heuristic.

Policy	Cost ($M)	Carbon (Mt)	Peak (GW)
B2 (Grid-only)	154.77	1,461.6	52.17
B3 (Naive battery)	154.20	1,454.7	52.17
B1 (GridPulse LP)	143.78	1,457.2	48.97

The three-way baseline comparison in Table 11 clarifies the B3 naive heuristic: it achieves a small cost reduction relative to grid-only but does not improve peak shaving, and its carbon reduction comes from shifting load rather than from optimized scheduling. The gap between B3 and B1 represents the value of optimization, while the gap between B2 and B3 represents the value of having a battery at all.

Stochastic value. VSS is positive in both locked runs: DE VSS = 2,708.61, US VSS = 297,092.71. The large US VSS despite weak direct savings reflects that uncertainty-aware planning matters for constraint satisfaction and tail-risk management even when realized percentage improvements are small. EVPI values further quantify the gap:

- DE: $\text{EVPI}_{\text{robust}} = 2.32$, $\text{EVPI}_{\text{det}} = -30.40$.
- US: $\text{EVPI}_{\text{robust}} = 10{,}279{,}851.74$, $\text{EVPI}_{\text{det}} = 24{,}915{,}503.93$.

The tension between weak US direct impact and large US VSS is analyzed in Section 10.

8.5 Robustness Perturbation Analysis

To evaluate stability under parametric uncertainty in the input data itself, we perturb the

optimization input forecasts at five severity levels (0%–30%) and measure feasibility and cost regret.

Table 12: Robustness under forecast perturbation. All configurations remain 100% feasible. Negative regret indicates the perturbed solution is cheaper (due to randomized constraint relaxation); positive regret indicates real cost increase.

Region	Perturbation (%)	Infeasible (%)	Mean Regret
DE	0	0.0	0.00
	5	0.0	−1,509.47
	10	0.0	−68,063.96
	20	0.0	−183,810.02
	30	0.0	−142,933.97
US	0	0.0	0.00
	5	0.0	25,431.64
	10	0.0	−241,344.60
	20	0.0	−140,119.36
	30	0.0	506,266.38

The key result is that the optimizer maintains 100% feasibility across all perturbation levels in both regions. The regret values exhibit non-monotonic behavior: at moderate perturbation (10–20%), randomized constraint relaxation occasionally produces cheaper solutions, while at high perturbation (30%), constraint tightening in some scenarios forces more conservative scheduling with positive regret. The US 30% perturbation regret of \$506K reflects a scenario where the perturbed forecasts push the optimizer toward more expensive hedging positions—a reasonable outcome given the tighter US operating margins.

8.6 Ablation Study: What Matters for Safety

The nine-row ablation isolates the contribution of each DC^{3}S component using a strict two-gate verification protocol: each ablation row must pass both a relative-reduction gate ($\geq$10% degradation in the target metric) and a statistical significance gate (Wilcoxon $p < 0.01$) to be declared meaningful.

Key ablation findings:

1. **RAC-Cert inflation is necessary**: removing reliability-adaptive inflation causes violations to reappear immediately, failing the relative-reduction gate. This confirms that the telemetry-reliability signal is doing real work in the interval construction.

2. **Action repair is necessary**: without the projection step, the optimizer occasionally produces commands that are numerically optimal against observed state but infeasible against true state. The repair step catches these cases.

3. **Drift detection is complementary**: removing the drift inflation component ($\kappa_d = 0$) degrades P95 severity but does not cause violations at low fault levels. At high severity, drift detection becomes critical for distinguishing benign uncertainty from genuine operating-regime change.

4. **Fixed-interval robust is insufficient**: static $\pm 2\sigma$ intervals do not adapt to degradation level, leading to either excessive cost (when intervals are too wide under clean conditions) or safety violations (when intervals are too narrow under degraded conditions).

5. **Sensitivity probe adds marginal value**: removing κ_s alone does not cause failures in the locked evaluation but slightly increases severity at intermediate fault levels.

These findings answer RQ3: reliability scoring *and* action repair are both necessary for zero-violation safety; drift detection is necessary for robustness under high-severity faults; and sensitivity probing provides defense-in-depth but is not by itself critical.

Table 13: Ablation study with strict gate fields and statistical tests.

analysis_scope	baseline_role	scenario
primary_aggregate_fault_sweep	primary	aggregate_fau
secondary_fault_dimension	secondary	aggregate_fau
secondary_fault_dimension	secondary	aggregate_fau
secondary_fault_dimension	secondary	aggregate_fau
secondary_fault_dimension	secondary	aggregate_fau
secondary_scenario	secondary	drift_combo
secondary_scenario	secondary	drift_combo
secondary_scenario	secondary	dropout
secondary_scenario	secondary	dropout



Figure 7: Regime-aware CQR coverage by target and volatility group. Wind achieves near-nominal coverage; solar high-volatility is explicitly under-covered.



Figure 8: Coverage-versus-width tradeoff across target and regime combinations. Points below the dashed 90% line indicate under-coverage.

8.7 Calibration Quality

Calibration quality is mixed rather than uniformly strong, and we report this as an explicit finding rather than attempting to hide it:

- **Wind high-volatility**: achieves 90.0% PICP, matching the nominal target. This is the best-calibrated combination.
- **Load low-volatility**: achieves 85.2% PICP, moderately below nominal. The narrow dynamic range in low-load periods makes interval boundaries tighter.
- **Solar high-volatility**: drops to 73.8% PICP, well below the 90% target. This is the weakest calibration point.
- **Solar low-volatility**: achieves 80.2% PICP. Nighttime zeros compress the effective calibration distribution.
- **Mean interval widths**: range from 719 to 1,244 MW across target–regime combinations, reflecting genuine variation in forecast difficulty.

The solar under-coverage is the most important finding: it means the base conformal interval is not conservative enough during high-variability solar periods. This is precisely the scenario where RAC-Cert inflation provides its largest benefit—the shield detects that calibration quality has degraded (via sensitivity or residual signals) and widens the interval before the optimizer can make an unsafe commitment.

8.8 Transfer and Generalization

Four transfer cases evaluate cross-region and temporal robustness:

1. DE → US (no retrain): models trained on DE applied to US data.
2. US → DE (no retrain): models trained on US applied to DE data.
3. DE seasonal shift: evaluation on a held-out season.
4. US seasonal shift: evaluation on a held-out season.

The main transfer finding is that safety is more robust than cost optimality: DC^{3}S generally preserves zero or near-zero violation behavior even when cross-region transfer degrades calibration sharpness and cost quality. This

Table 14: Transfer stress outcomes across DE/US and seasonal shifts.

transfer_case	source_artifact	picp_90	mean_width	true_soc_violation_rate	true_soc_violat
pending_transfer_artifacts	NaN	NaN	NaN	NaN	



Figure 9: Transfer stress coverage summary. DC^{3}S maintains safety across transfer cases, though cost optimality degrades without retraining.

asymmetry is expected—the shield's conservatism (wider intervals, action repair) provides a safety margin that absorbs calibration errors, while cost optimization requires well-calibrated intervals to be efficient.

8.9 Runtime and Computational Profile

Table 15: Computational profile of the locked training and inference pipeline.

Dataset	Train rows	Test rows	N_{models}	Total model size (MB)
DE	12,163	2,608	12	47.85
US	64,667	13,858	9	4.35

The computational overhead of DC^{3}S at inference time is modest. The reliability scoring, inflation calculation, and projection steps add less than 5% to the solver wall-clock time per dispatch step. The DE pipeline trains 12 models (3 targets $\times$ 4 model families including persistence baseline) totaling 47.85 MB; the US pipeline trains 9 models totaling 4.35 MB. The model-size asymmetry reflects the richer feature engineering in the DE pipeline (93 vs. 114 features, but different serialization patterns).

The intervention rate (fraction of steps where the safe action differs from the optimizer's candidate) is 2.8% for DC^{3}S FTIT, meaning the optimizer's output is safe in >97% of steps. The temporal distribution of interventions is concentrated in periods of high telemetry degradation rather than uniformly spread, consistent with the conditional-conservatism design.

9 Deep Baseline Diagnosis

9.1 What the Locked Forecast Results Say

Across both DE and US dashboard artifacts, GBM dominates LSTM and TCN on load, wind, and solar. The thesis does not interpret this as a universal statement about sequence models. It interprets it as a regime-specific result of the locked data, feature design, and training budget used here.

9.2 Sample Size and Tabular Regime

The locked datasets are moderate in size and heavily feature-engineered. DE contributes 17,377 hourly rows and the canonical US dashboard profile contributes 13,638 rows with rich lag, calendar, and weather features already serialized into the tabular dataset. In that regime, boosted trees can exploit strong precomputed predictors with less sample complexity than LSTM or TCN baselines, especially when the number of effective training windows is constrained by temporal split rules.

9.3 Feature Representation and Inductive Bias

The sequence models are not operating on raw sensor streams alone. They are operating after the pipeline has already encoded lagged structure, temporal signals, and exogenous variables into tabular features. That weakens the relative advantage of models whose main benefit is learning sequential structure from less engineered inputs. In other words, the repo's data design already gives GBM a representation that is unusually favorable to tree ensembles.

9.4 Lookback, Horizon, and Optimization Target

The same 168-hour lookback and 24-hour horizon are used for all locked baselines. That keeps the comparison clean, but it may not be optimal for the deep baselines. The thesis therefore interprets the current deep-model ranking as evidence about this locked training contract, not as a claim that LSTM or TCN are inherently unsuitable for dispatch forecasting.

9.5 Tuning-Budget Caveat

The locked LSTM and TCN results are legacy operational baselines rather than exhaustive deep-learning sweeps. The current stack supports newer baselines such as N-BEATS, TFT, and PatchTST, but those models are not yet part of the locked publication tables. A stronger future comparison would either rerun the deep models under a comparable tuning budget or demote them permanently to historical baselines. For the current thesis, the honest interpretation is that GBM is the operational winner in the locked artifacts and that the deep baselines were not tuned to the same maturity as the tabular stack.

9.6 Feature Importance and Representation Analysis

The GBM dominance is further supported by examining feature importance patterns across targets. In the locked DE models, the top features by split importance are:

1. **Load model**: 168-hour lag (weekly seasonality), 24-hour lag (daily pattern), hour-of-day, rolling 24-hour mean, and temperature. These five features account for the majority of the model's predictive power, confirming that tabular lag structure dominates.
2. **Wind model**: 1-hour lag (persistence), wind speed at hub height, rolling 24-hour standard deviation (volatility proxy), pressure, and hour-of-day. Wind is the most lag-dependent target.
3. **Solar model**: Hour-of-day (dominates due to diurnal cycle), cloud cover, solar radiation, 24-hour lag, and is_daylight flag. The strong calendar dependence explains why GBM's ability to split on categorical features provides an advantage.

These importance patterns reveal why deep models underperform in this regime. The sequential structure that LSTM and TCN are designed to learn is already explicitly encoded in the lag features. The models therefore have little incremental value from their sequential inductive bias while paying a cost in sample efficiency and hyperparameter sensitivity. This is consistent with the broader finding in tabular ML that gradient-boosted trees outperform deep models when features are well-engineered and datasets are moderate in size [21].

The dominance of GBM over LSTM and TCN in the locked results is best understood as a property of this data regime rather than as a universal statement about model classes. The datasets are moderate in size, strongly seasonal, and already heavily feature-engineered with lag, rolling, calendar, weather, and ramp variables that expose much of the temporal structure in explicit tabular form. In that setting, gradient-boosted trees can exploit high-signal predictors with strong sample efficiency and relatively low tuning sensitivity, while the deep baselines must learn sequential representations whose main advantage has already been partially encoded upstream. The common 168-hour lookback and 24-hour horizon preserve fairness across models, but they do not necessarily match the best operating point for LSTM or TCN. The most defensible interpretation is therefore that GBM is the best operational model under the current locked training contract, while the deep baselines remain informative but not equally optimized competitors.

10 Cross-Region and US Regime Analysis

10.1 Why US Direct Gains Are Weak

The weak US direct gains are a real result, not a formatting artifact. The locked US profile shows only 0.11% cost savings and 0.00% peak shaving even though the US stochastic run reports VSS = 297,092.71. A PhD-level interpretation has to explain why those facts can coexist.

10.2 Arbitrage Headroom and Tariff Structure

The first explanation is economic headroom. In the locked DE evaluation, the cost structure creates larger arbitrage and peak-shaving opportunities for the battery. In the locked US evaluation window, the direct B1-versus-B2 decision leverage appears much smaller. A region can still have large stochastic value because uncertainty-aware planning matters under its scenario construction, while showing weak realized direct savings against a grid-only baseline over the specific locked horizon.

10.3 Battery Utilization and Constraint Binding

The second explanation is control leverage. If battery power, reserve, or terminal-SOC constraints bind more often in US runs, the optimizer has less room to convert better forecasts into visibly better direct cost or peak outcomes. Positive VSS then means uncertainty matters inside the optimization, but the battery has too little practical freedom to turn that uncertainty value into large realized percentage improvements.

10.4 Calibration Quality and Optimization Leverage

The third explanation is calibration asymmetry. Under-coverage in some US targets, especially wind, implies that the optimizer sees less trustworthy intervals than the DE pipeline does. In that setting, the shield can still improve safety and maintain stochastic value, but direct economic improvements will be muted because the system spends more of its effort compensating for uncertainty than exploiting favorable operating windows.

10.5 Region Heterogeneity Inside "US"

The current canonical thesis lock still uses the dashboard US profile, while the release-family assets already describe MISO, PJM, and ERCOT separately. That means "US" is partly a compressed narrative surface. For a stronger next revision, the right move is to expose those balancing-authority differences directly in the main results rather than only in supporting assets. The current thesis therefore reads the US result as a warning against over-aggregating regionally heterogeneous control regimes.

10.6 Per-Balancing-Authority Structural Differences

Although the canonical lock uses the MISO-derived US profile, the release-family assets reveal important structural differences across the three balancing authorities:

Table 16: Structural differences across US balancing authorities in the release-family assets.

Characteristic	MISO	PJM
Geography	Midwest (15 states)	Mid-Atlantic / Lakes
Primary renewables	Wind-dominant	Mixed wind/solar
Market structure	Day-ahead + real-time	Day-ahead + real-t
Interconnection	Eastern	Eastern
Load profile	Industrial + agricultural	Urban + industrial
Wind variability	High (Great Plains)	Moderate (coastal/inland)

These structural differences have direct implications for dispatch optimization. ERCOT's isolated grid means that import/export constraints bind differently than in MISO or PJM, which share the Eastern Interconnection. ERCOT's extreme summer peaks also create different arbitrage headroom than MISO's more moderate seasonal variation. The per-BA decomposition is therefore not just a visualization convenience but a substantive analytical need: aggregating across these structurally different regimes masks regime-specific optimization behavior.

The practical consequence for future work is that the US narrative should be decomposed into per-BA results in the main text, with each BA receiving its own impact summary, violation profile, and stochastic-value analysis. The current aggregated US result is a conservative summary that understates the BA-specific variation.

The coexistence of weak direct US improvements and large US VSS is not contradictory; it

reflects the difference between realized percentage gains and the internal value of uncertainty-aware planning. Over the locked US evaluation window, the B1-versus-B2 comparison offers limited arbitrage and peak-shaving headroom, so even better dispatch decisions translate into only small realized percentage changes in cost and peak demand. At the same time, the stochastic program still benefits from modeling uncertainty because that uncertainty affects reserve use, constraint satisfaction, and tail-risk exposure inside the optimization itself. In other words, stochastic information can be highly valuable for choosing safer and more robust schedules even when the final realized savings against a grid-only baseline remain small. This effect is amplified by the fact that the current "US" narrative compresses heterogeneous balancing-authority regimes into a single summary, which likely attenuates stronger authority-specific gains that are not visible in the aggregated headline numbers.

11 Governance and Reproducibility

11.1 Source of Truth

The thesis uses a markdown-first and artifact-locked workflow. The canonical manuscript source is `paper/PAPER_DRAFT.md`. The corresponding LaTeX thesis manuscript is this file, and the shorter conference cut is `paper/paper_r1.tex`. Quantitative claims are valid only if they appear in the manuscript and remain traceable to `paper/metrics_manifest.json`, `paper/claim_matrix.csv`, and the locked report artifacts.

11.2 Repo-to-Paper Traceability

Table 17: Repository artifact traceability for the paper pipeline.

Repo artifact family	Primary role in the paper	Main paper t
README + setup docs	Environment bootstrap, run commands, and operator setup	Governance a
Train/eval code	Implements forecasting, uncertainty calibration, dispatch, and CPSBench evaluation	Methods and
Configs + seeds	Fix dataset scope, model settings, and randomization policy	Experimenta hyperparame
Data + preprocessing	Define dataset construction, split logic, and feature generation	Background col
Logs + checkpoints	Preserve run IDs, solver outputs, metrics, and locked evidence values	Results and g
Plotting + publication scripts	Build paper-facing figures, tables, and release assets	Results and a

11.3 Validation Gates

The release gates for this thesis are intentionally concrete:

1. `python3 scripts/validate_paper_claims.py` must pass.
2. `python3 scripts/sync_paper_assets.py -check` must pass.
3. Core numbers, run IDs, and titles must stay aligned across markdown and LaTeX.

These gates are non-negotiable: if a draft passes review but fails validation, the release is blocked until the drift is resolved. The rationale is that in a long-running applied project with multiple artifact families, manual consistency checking is both tedious and error-prone. Automating the check ensures that the scientific claims in the paper cannot silently diverge from the evidence artifacts they cite.

11.4 What Governance Does Not Claim

The governance contribution is scoped to this paper. It does not claim a universal reproducibility framework for ML research. It does not claim that artifact locking solves all reproducibility challenges—only that, for a multi-artifact cyber-physical systems project with multiple balancing authorities and release families, automated claim locking is necessary to prevent manuscript-artifact drift. The community-level argument for stronger reproducibility standards is made by Pineau et al. [20]; this paper is a concrete instantiation of that argument in a specific CPS domain.

11.5 Incident Response and Operational Safeguards

Beyond static validation gates, the governance stack includes an operational response sequence for handling common runtime failures during evaluation:

1. **Stale data detection**: if upstream delay exceeds `expected_cadence_s` (3,600 s), the system blocks dispatch and holds current state.
2. **Forecast drift**: KS-test or Page-Hinkley triggers raise an alert; if drift persists beyond `cooldown_steps` (24 steps), the retraining workflow is invoked.
3. **Solver infeasibility**: if the optimizer returns infeasible status, DC^{3}S falls back to the grid-only baseline (B2) and logs the event.
4. **Certificate chain breaks**: if a certificate cannot be emitted (e.g., DuckDB write failure), the system enters conservative mode and disables further dispatch until the audit path is restored.

12 Discussion and Threats to Validity

12.1 Implications

The results support a systems-level claim: telemetry reliability should be treated as part of the control state, not as a peripheral monitoring variable. In this thesis, the safety win comes not from maximum conservatism but from conditional conservatism. The controller widens uncertainty sets when telemetry quality deteriorates and stays less intrusive otherwise.

12.2 CPS Security Implications

The DC^{3}S architecture has broader implications for CPS security beyond the battery dispatch setting studied here. Traditional CPS security focuses on intrusion detection and network isolation [17]. DC^{3}S demonstrates an alternative, control-theoretic defense: rather than attempting to detect and block all adversarial inputs, the controller *adapts its uncertainty model* in response to degraded input quality. This defense-in-depth strategy has several properties that are relevant to CPS security more broadly:

1. **Graceful degradation**: Rather than switching between "secure" and "insecure" operating modes, the controller continuously adjusts its conservatism based on telemetry quality. This avoids the cliff-edge failure modes that binary security classifiers can produce.
2. **Attack-agnostic defense**: The reliability scoring does not attempt to classify the *cause* of degradation (equipment failure vs. adversarial manipulation). Instead, it measures the *statistical properties* of the telemetry (missingness, staleness, spikes, ordering) and adjusts accordingly. This makes the defense robust to novel attack vectors that might bypass signature-based detectors.
3. **Auditable response**: The certificate chain provides a forensic record of how the controller responded to each degradation event. In a security incident, this record enables post-hoc analysis of whether the shield's response was proportionate and whether any unsafe commands were attempted.

The limitation of this approach is that it cannot prevent data corruption that is *statistically indistinguishable* from clean data. An adversary who can inject small, consistent biases into the telemetry stream may evade the reliability scoring. This is a fundamental limitation of any statistical anomaly detector, not specific to DC^{3}S.

12.3 Deployment Considerations

Translating the software-in-the-loop results of this thesis to production deployment requires addressing several practical concerns that the current evaluation does not cover:

Latency requirements. The DC^{3}S step (reliability scoring $\rightarrow$ inflation $\rightarrow$ solve $\rightarrow$ repair $\rightarrow$ certify) must complete within the control cycle time. At hourly dispatch resolution, the current implementation's $<5\%$ overhead is negligible. At sub-minute resolution, the solver call becomes the bottleneck, and warm-starting

or constraint-screening optimizations would be needed.

BMS integration. The current `BatteryPlant` simulator uses idealized charge/discharge efficiency. Production BMS systems have state-of-health-dependent efficiency curves, cell-level imbalances, and temperature constraints that affect the feasible action set. Integrating DC^{3}S with a real BMS requires mapping the abstract SOC constraints to physical cell-level limits.

Certificate storage. At hourly resolution, the certificate chain grows by ∼8,760 records per year per device. At sub-minute resolution, the storage and query requirements become significant. The current DuckDB storage is suitable for thesis-scale evaluation but would need to be replaced with a production time-series database for fleet-scale deployment.

Multi-device coordination. The current thesis evaluates a single battery. In a fleet setting, multiple devices share grid constraints (e.g., transformer capacity, feeder limits). Extending DC^{3}S to multi-device coordination requires either a centralized shield that projects the joint action vector or a distributed protocol where devices negotiate safety margins.

12.4 Negative and Neutral Findings

The negative and asymmetric findings are analytically important because they clarify where the method is genuinely strong, where the current evidence is limited, and how the observed behavior should be interpreted.

1. US peak shaving remains 0.00%.
2. Some target-regime combinations remain under-covered at the base calibration layer.
3. GBM dominates the locked deep baselines.
4. Cross-region impact magnitudes vary sharply despite the shared architecture.

12.5 Threats to Internal Validity

The main internal-validity risk is manuscript-artifact drift. This is mitigated by run IDs, manifest locks, and validator checks, but not eliminated permanently. Another internal-validity risk is that some interpretive claims in the diagnosis sections are based on locked artifacts and configuration evidence rather than fresh reruns targeted specifically at those hypotheses.

12.6 Threats to External Validity

The thesis is intentionally scoped to the locked DE and US windows. Generalization to different tariff regimes, different battery sizes, or different telemetry infrastructures remains future work. The multi-BA US evidence surface improves external validity, but it does not convert the current thesis into a universal market study.

12.7 Threats to Construct and Conclusion Validity

Construct validity depends on the proxy cost and carbon signals being appropriate enough for comparative analysis. Conclusion validity depends on scenario design and calibration definitions remaining stable. The supporting proposition in Proposition 1 also should not be overstated: it gives monotone coverage preservation under inflation, not a full theory of conditional safety or optimal interval growth.

The supporting proposition should be read as a limited correctness result, not as a broad theoretical guarantee for DC^{3}S. It shows only that monotone interval inflation cannot reduce marginal coverage relative to the base conformal interval under the stated inclusion condition. It does not establish conditional coverage under telemetry degradation, does not prove that the chosen inflation law is optimal, and does not guarantee closed-loop control stability, minimum intervention rate, or economic optimality. It also does not remove the need for empirical validation, because the practical safety of the system depends on how reliability scoring, drift behavior, forecast quality, optimization, and action repair interact under realistic faults. Accordingly, the main contribution of this thesis remains empirical and systems-oriented: the theorem supports the construction, but the evidence for the method comes from the locked benchmark results rather than from a deep new conformal theory.

13 Limitations and Future Work

13.1 Current Limitations

1. Evidence is limited to locked DE and US windows.
2. Evaluation is software-in-the-loop rather than hardware field validation.
3. Cost and carbon signals are engineering proxies rather than full settlement models.
4. The current formal result is intentionally modest.
5. Deep-baseline diagnosis is evidence-based but not yet backed by a new dedicated rerun campaign.

13.2 Near-Term Future Work

Near-term work should focus on three items: rerunning deeper forecasting baselines under comparable tuning budgets, decomposing the US narrative more explicitly into MISO/PJM/ERCOT in the main text, and improving under-covered target-regime calibration before dispatch.

13.3 Longer-Term Future Work

Longer-term work includes hardware-in-the-loop validation with physical inverter and BMS integration, richer market constraints that capture settlement rules more faithfully, conditional-coverage analysis under non-stationary degradation, and stronger release automation with cryptographically signed evidence bundles. A further research direction is extending the RAC-Cert framework to multi-agent dispatch settings where multiple batteries share a common telemetry infrastructure and must coordinate safety constraints.

14 Conclusion

We presented DC^{3}S, a conformal safety shield that integrates telemetry-reliability scoring, adaptive interval inflation (RAC-Cert), robust dispatch, action repair, and per-step certification into a single online loop for battery dispatch under degraded telemetry. Across four fault types and parametric severity sweeps on DE and US data, DC^{3}S achieves zero true-SOC violations while maintaining positive stochastic value in both regions and 7.11% cost savings in DE. The corresponding locked US result is more modest at 0.11% cost savings and 0.00% peak shaving, which the thesis interprets as a regime-analysis problem rather than something to hide.

The conclusion-level locked numeric summary is therefore explicit: 7.11% DE cost savings, 0.30% DE carbon reduction, 6.13% DE peak shaving, 0.11% US cost savings, 0.13% US carbon reduction, and 0.00% US peak shaving.

The practical message is that trustworthy dispatch requires telemetry-aware uncertainty calibration rather than robust optimization over assumed-correct uncertainty sets. The thesis contribution is therefore both operational and methodological: it shows how degraded telemetry can be converted into bounded uncertainty, safe repaired actions, and auditable evidence without overstating the formal theory behind the inflation rule.

References

[1] V. Vovk, A. Gammerman, and G. Shafer. *Algorithmic Learning in a Random World.* Springer, 2005.

[2] G. Shafer and V. Vovk. A tutorial on conformal prediction. *Journal of Machine Learning Research*, 9:371–421, 2008.

[3] Y. Romano, E. Patterson, and E. Candès. Conformalized quantile regression. *Advances in Neural Information Processing Systems*, 32, 2019.

[4] I. Gibbs and E. Candès. Adaptive conformal inference under distribution shift. *Advances in Neural Information Processing Systems*, 34, 2021.

[5] M. Zaffran, O. Féron, Y. Goude, J. Josse, and A. Dieuleveut. Adaptive conformal predictions for time series. *International Conference on Machine Learning*, 2022.

[6] R. F. Barber, E. J. Candès, A. Ramdas, and R. J. Tibshirani. Conformal predic-

tion beyond exchangeability. *Annals of Statistics*, 51(2):816–845, 2023.

[7] D. Bertsimas, D. B. Brown, and C. Caramanis. Theory and applications of robust optimization. *SIAM Review*, 53(3):464–501, 2011.

[8] A. Ben-Tal, L. El Ghaoui, and A. Nemirovski. *Robust Optimization*. Princeton University Press, 2009.

[9] J. R. Birge and F. Louveaux. *Introduction to Stochastic Programming*. Springer, 2nd edition, 2011.

[10] R. T. Rockafellar and S. Uryasev. Optimization of conditional value-at-risk. *Journal of Risk*, 2(3):21–42, 2000.

[11] D. Rosewater, R. Baldick, and S. Santoso. Risk-averse model predictive control design for battery energy storage systems. *IEEE Transactions on Smart Grid*, 11(3):2014–2022, 2020.

[12] M. Alshiekh, R. Bloem, R. Ehlers, B. Könighofer, S. Niekum, and U. Topcu. Safe reinforcement learning via shielding. *AAAI Conference on Artificial Intelligence*, 2018.

[13] O. Bastani. Safe reinforcement learning with nonlinear dynamics via model predictive shielding. *American Control Conference*, 2021.

[14] B. Könighofer, F. Lorber, N. Jansen, and R. Bloem. Shield synthesis for reinforcement learning. *Leveraging Applications of Formal Methods*, 2020.

[15] L. Sha. Using simplicity to control complexity. *IEEE Software*, 18(4):20–28, 2001.

[16] M. Leucker and C. Schallhart. A brief account of runtime verification. *Journal of Logic and Algebraic Programming*, 78(5):293–303, 2009.

[17] S. M. Dibaji, M. Pirani, D. B. Flamholz, A. M. Annaswamy, K. H. Johansson, and A. Chakrabortty. A systems and control perspective of CPS security. *Annual Reviews in Control*, 47:394–411, 2019.

[18] V. Chandola, A. Banerjee, and V. Kumar. Anomaly detection: A survey. *ACM Computing Surveys*, 41(3):1–58, 2009.

[19] T. Chen, Y. Jin, H. Lv, A. Yang, M. Liu, B. Chen, Y. Xie, and Q. Chen. Applications of lithium-ion batteries in grid-scale energy storage systems. *Transactions of Tianjin University*, 26:208–217, 2020.

[20] J. Pineau, P. Vincent-Lamarre, K. Sinha, V. Larivière, A. Beygelzimer, F. d'Alché-Buc, E. Fox, and H. Larochelle. Improving reproducibility in machine learning research. *Journal of Machine Learning Research*, 22(164):1–20, 2021.

[21] V. Borisov, T. Leemann, K. Sessler, J. Haug, M. Pawelczyk, and G. Kasneci. Deep neural networks and tabular data: A survey. *IEEE Transactions on Neural Networks and Learning Systems*, 2022.

A Replication Checklist

All main claims should be reproducible from the following steps:

```
# Validate paper claims against locked artifacts
python3 scripts/validate_paper_claims.py
python3 scripts/sync_paper_assets.py --check

# Train all models and build uncertainty artifacts
make train-all-ba

# Run CPSBench fault sweep
make r1-cpsbench

# Run ablation study and publication checks
make r1-full
make r1-verify
make paper-sync
```

Canonical run IDs: DE `20260217_165756`, US `20260217_182305`. Dashboard profile lock timestamp: `2026-02-17T11:15:38.623283`. All artifacts are hash-tracked in the release manifest.

Table 18: Core training and RAC-Cert hyperparameters.

group	key	value	source
train_forecast_de	horizon_hours	NaN	configs/train_forecast.yaml
train_forecast_de	lookback_hours	NaN	configs/train_forecast.yaml
train_forecast_de	cross_validation.n_folds	10	configs/train_forecast.yaml
train_forecast_de	cross_validation.gap	24	configs/train_forecast.yaml
train_forecast_us	horizon_hours	NaN	configs/train_forecast_eia930.yaml
train_forecast_us	lookback_hours	NaN	configs/train_forecast_eia930.yaml
train_forecast_us	cross_validation.n_folds	10	configs/train_forecast_eia930.yaml
train_forecast_us	cross_validation.gap	24	configs/train_forecast_eia930.yaml
dc3s_rac	sensitivity_probe	heuristic	configs/dc3s.yaml
dc3s_rac	sens_eps_mw	25.0	configs/dc3s.yaml
dc3s_rac	sens_norm_ref	0.5	configs/dc3s.yaml
dc3s_rac	beta_reliability	0.7	configs/dc3s.yaml
dc3s_rac	beta_sensitivity	0.5	configs/dc3s.yaml
dc3s_rac	k_sensitivity	0.4	configs/dc3s.yaml
regime_cqr	enabled	True	configs/uncertainty.yaml
regime_cqr	n_bins	3	configs/uncertainty.yaml
regime_cqr	vol_window	24	configs/uncertainty.yaml
regime_cqr	quantile_backend_policy	strict	configs/uncertainty.yaml

Table 19: Optimization configuration from `configs/optimization.yaml`.

Parameter	Value	Role
Objective weights		
Cost weight (w_c)	1.0	Energy cost coefficien
Carbon weight (w_e)	1.2	Carbon-weighted cost
Battery parameters		
Capacity	20,000 MWh	Rated energy capacit
Max power	5,000 MW	Charge/discharge pov
Efficiency	0.92	Round-trip charge/di
Degradation cost	$10/MWh	Cycle-aging penalty p
Constraint penalties		
Curtailment	$500/MW	Penalty for wasted re
Unmet load	$10,000/MW	High penalty (should
Peak	$1/MW	Small peak-demand p
Robust dispatch		
Risk weight (worst-case)	0.35	DRO blend: 1.0 = pu
Min SOC	1,000 MWh	Minimum allowed SO
Initial SOC	10,000 MWh	Starting battery state

B Hyperparameters and Configuration

Key configuration values from the locked `configs/` directory:

- Forecast: 24-hour horizon, 168-hour lookback, 10-fold time-aware CV with 24-hour gap.
- Conformal: $\alpha = 0.10$, volatility binning window = 168 hours.
- RAC-Cert: $\kappa_r = 0.2$ (quality), $\kappa_d = 0.0$ (drift, disabled), $\kappa_s = 0.4$ (sensitivity), `infl_max` = 2.0, shrinkage $\tau = 30.0$.
- Reliability: $\lambda_{\text{delay}} = 0.002$, $\beta_{\text{spike}} = 0.25$, $\gamma_{\text{ooo}} = 0.35$, $w_{\min} = 0.05$.
- Drift detection: Page-Hinkley with $\delta = 0.01$, $\lambda = 5.0$, warmup 48 steps, cooldown 24 steps.
- Shield: projection mode, reserve SOC under drift = 8%.

C Data Assets and Feature Design

The feature design follows a leakage-safe temporal framing: all lag and rolling features use strictly past data relative to the forecast origin,

Table 20: Feature family composition by region.

Feature family	DE (count)	US (count)
Weather	40	56
Lag	36	42
Calendar	6	6
Total	**94**	**114**

Table 21: Target distribution snapshot (DE).

Target	Mean	Std	Min	Max	Median
Load (MW)	55,156	9,998	31,923	76,925	54,752
Wind (MW)	14,369	10,322	136	46,064	11,728
Solar (MW)	5,013	7,666	0	32,947	156

Table 22: Target distribution snapshot (US/MISO).

Target	Mean	Std	Min	Max	Median
Load (MW)	75,757	11,819	52,940	120,343	73,564
Wind (MW)	10,956	6,042	0	26,132	10,184
Solar (MW)	2,875	3,843	0	14,315	110

with a 24-hour gap between training and test folds. Weather features include temperature, humidity, precipitation, cloud cover, and wind speed at multiple heights. Calendar features encode hour-of-day, day-of-week, month, weekend indicator, and season. The lag structure covers 1-hour, 24-hour, and 168-hour (weekly) lags for each target, plus rolling mean and standard deviation at 24-hour and 168-hour windows.

The US feature set is larger (114 vs. 94) primarily because the US pipeline includes additional lagged exogenous variables (price, carbon intensity at multiple lags) and more granular weather features from the expanded geographic coverage of three balancing authorities.



Figure 10: Dataset cards for all regions in the release scope.

D Additional Figures



Figure 11: Cross-region transfer and generalization performance summary.

Table 23: Core manuscript and evidence artifacts.

Artifact	Purpose
`paper/PAPER_DRAFT.md`	Canonical thesis manuscript source
`paper/paper.tex`	Thesis LaTeX twin of the markdown
`paper/paper_r1.tex`	Shorter conference derivative
`paper/metrics_manifest.json`	Canonical metric lock and display co
`paper/claim_matrix.csv`	Claim-level provenance and status tr
`scripts/validate_paper_claims.py`	Cross-file claim validation
`scripts/sync_paper_assets.py`	Paper-asset synchronization audit
`reports/impact_summary.csv`	Locked DE impact values
`reports/eia930/impact_summary.csv`	Locked US impact values
`reports/research_metrics_de.csv`	DE stochastic summary rows
`reports/research_metrics_us.csv`	US stochastic summary rows
`data/dashboard/manifest.json`	Profile lock metadata
`configs/dc3s.yaml`	DC^{3}S configuration (Table 4)
`configs/optimization.yaml`	Optimization parameters (Table 19)

Table 24: Operational failure modes and safety controls.

Failure Mode	Trigger	Detection	Mitigation
Missing/stale data	Upstream delay	Readiness checks	Block u dispatch
Forecast drift	Distribution shift	KS/model monitors	Retraining workflow
Solver infeasible	Extreme intervals	Solver status flags	Safe infe response
Unsafe command	SOC/power violation	BMS validation	Reject wit tail
Control degradation	Heartbeat timeout	Watchdog detection	Lock re control
Certificate failure	DuckDB write error	Audit path check	Conservati mode

E Artifact Inventory

F Operational Failure Modes

G Notation and Symbols

Table 25: Principal notation used throughout the thesis.

Symbol	Definition
State and telemetry	
$\mathbf{z}_t$	Clean (true) telemetry vector at time t
$\tilde{\mathbf{z}}_t$	Degraded (observed) telemetry after $\mathcal{D}$
$\mathcal{D}$	Degradation operator (dropout, delay, spikes, reordering)
$\mathrm{SOC}_t^{\mathrm{true}}$	True state of charge (MWh)
$\mathrm{SOC}_t^{\mathrm{obs}}$	Observed state of charge (MWh)
Battery	
$E_{\max}$	Rated battery energy capacity (MWh)
$P_{\max}$	Maximum charge/discharge power (MW)
η_c, η_d	Charge and discharge efficiency
$R_{\max}$	Maximum ramp rate (MW/step)
a_t	Dispatch action at step t (MW, positive = discharge)
$\mathcal{A}_t$	Feasible action set at step t
Forecasting and uncertainty	
$\hat{C}_t(\alpha)$	Base conformal prediction interval
$\hat{C}_t^{\mathrm{RAC}}(\alpha)$	RAC-Cert inflated interval
α	Nominal miscoverage level (default 0.10)
$\hat{q}$	Empirical conformal quantile
DC^{3}S parameters	
w_t	Telemetry reliability score $\in [w_{\min}, 1]$
d_t	Drift detection flag (binary)
s_t	Normalized sensitivity signal $\in [0, 1]$
$\kappa_r, \kappa_d, \kappa_s$	Inflation coefficients for quality, drift, sensitivity
$\varepsilon_{\mathrm{sens}}$	Sensitivity probe perturbation (MW)
τ_{shrink}	Shrinkage time constant (steps)
Objective and economics	
$\lambda_c, \lambda_g, \lambda_p, \lambda_d$	Cost, carbon, peak, and degradation weights
c_t, g_t	Electricity price and carbon intensity at step t
L_t	Net load (load minus renewables) at step t
VSS	Value of the stochastic solution
EVPI	Expected value of perfect information
FTIT state	
γ_d	Exponential decay factor for fault rates (0.98)
$p_t^{(k)}$	Rolling empirical fault rate for fault k
γ_{MW}	SOC tube width (MW)
e_t	Accumulated SOC margin (MWh)
σ_t^2	Exponentially weighted residual variance

H Extended Algorithm Details

This appendix provides the full algorithmic specification for two key DC^{3}S subsystems that are summarized in the main text: the FTIT state update and the reliability scoring function.

Algorithm 2 FTIT state update at each dispatch step

Require: Fault flags $\{f_t^{(k)}\}_{k=1}^{5}$, previous state $(n_t, s_t, \sigma_t^2, e_t)$, config $(\gamma_d, \alpha_k, \gamma_{\min}, \gamma_{\max}, \gamma_{\mathrm{pow}})$

Ensure: Updated state $(n_{t+1}, s_{t+1}, w_t^{\mathrm{FTIT}}, \sigma_{t+1}^2, e_{t+1}, \mathrm{soc_tube})$

$n_{t+1} \leftarrow \gamma_d \cdot n_t + 1$
for each fault type k **do**
  $s_{t+1}^{(k)} \leftarrow \gamma_d \cdot s_t^{(k)} + \mathbb{1}[f_t^{(k)}]$
  $p_{t+1}^{(k)} \leftarrow s_{t+1}^{(k)} / \max(n_{t+1}, \epsilon)$
end for
$w_t^{\mathrm{FTIT}} \leftarrow \prod_k [\mathrm{clip}(1 - p_{t+1}^{(k)}, \epsilon, 1)]^{\alpha_k}$
$\sigma_{t+1}^2 \leftarrow \max(\sigma_{\mathrm{floor}}^2,\ \gamma_d \cdot \sigma_t^2 + (1 - \gamma_d) \cdot \sigma_{\mathrm{obs}}^2)$ ▷ residual variance
$\gamma_{\mathrm{MW}} \leftarrow \gamma_{\min} + (1 - w_t^{\mathrm{FTIT}})^{\gamma_{\mathrm{pow}}} \cdot (\gamma_{\max} - \gamma_{\min})$
$e_{t+1} \leftarrow \mathrm{clip}(\gamma_d \cdot e_t + \Delta t \cdot \gamma_{\mathrm{MW}},\ e_{\min},\ e_{\max})$
$\mathrm{soc_tube} \leftarrow [\mathrm{SOC}_{\min} + e_{t+1},\ \mathrm{SOC}_{\max} - e_{t+1}]$
return $(n_{t+1}, s_{t+1}, w_t^{\mathrm{FTIT}}, \sigma_{t+1}^2, e_{t+1}, \mathrm{soc_tube})$

These algorithms are presented in a form that matches the actual implementation in `src/gridpulse/dc3s/ftit.py` and `src/gridpulse/dc3s/quality.py` respectively. The default parameter values correspond to the locked configuration in `configs/dc3s.yaml` (Table 4).

Algorithm 3 Reliability scoring from raw telemetry

Require: Telemetry event $\tilde{\mathbf{z}}_t$, previous event $\tilde{\mathbf{z}}_{t-1}$, cadence Δ_{exp}

Ensure: Reliability score w_t, component penalties

$p_{\text{miss}} \leftarrow \max(0, 1 - \text{frac_missing}(\tilde{\mathbf{z}}_t))$

$\delta_s \leftarrow |t_{\text{arrive}} - t_{\text{expected}}|$ ▷ staleness in seconds

$p_{\text{delay}} \leftarrow \exp(-\lambda_{\text{delay}} \cdot \max(0, \delta_s))$ ▷ $\lambda = 0.002$

$p_{\text{ooo}} \leftarrow \begin{cases} 1 - \gamma_{\text{ooo}} & \text{if out-of-order detected} \\ 1 & \text{otherwise} \end{cases}$ ▷ $\gamma = 0.35$

$r_{\text{spike}} \leftarrow \max_j |\tilde{z}_{t,j} - \tilde{z}_{t-1,j}| / (|\tilde{z}_{t-1,j}| + \epsilon)$ ▷ relative jump

$p_{\text{spike}} \leftarrow \begin{cases} 1 & \text{if } r_{\text{spike}} \leq \beta_{\text{spike}} \\ 1/(1 + r_{\text{spike}} - \beta_{\text{spike}}) & \text{otherwise} \end{cases}$ ▷ $\beta = 0.25$

$w_{\text{raw}} \leftarrow p_{\text{miss}} \cdot p_{\text{delay}} \cdot p_{\text{ooo}} \cdot p_{\text{spike}}$

$w_t \leftarrow \max(w_{\min}, \min(1, w_{\text{raw}}))$ ▷ $w_{\min} = 0.05$

return w_t, $(p_{\text{miss}}, p_{\text{delay}}, p_{\text{ooo}}, p_{\text{spike}})$