

Feeder Reliability Summary — feeder-049-0003

Reliability summary for feeder feeder-049-0003, a 12.0 kV distribution circuit rated 370 A, served from substation sub-samuelhaven-049 in the Northeast region. Current feeder status: energized.

Customer base: this feeder serves 2 metered service points — 1 industrial, 1 residential. Only active and inactive meters count toward customers-affected figures in reliability reporting; disconnected services are excluded.

Outage history over the trailing twelve months: 2 recorded events (P3: 1, P4: 1). Average restoration time was 244 minutes across 2 restored events, for a total of approximately 1,509,724 customer-minutes of interruption on this feeder.

Cause breakdown: animal contact — 1 event(s); planned maintenance — 1 event(s). No single failure mode dominates this feeder's outage history.