

Feeder Reliability Summary — feeder-016-0055

Reliability summary for feeder feeder-016-0055, a 25.0 kV distribution circuit rated 825 A, served from substation sub-portjesseville-016 in the Southwest region. Current feeder status: energized.

Customer base: this feeder serves 0 metered service points — . Only active and inactive meters count toward customers-affected figures in reliability reporting; disconnected services are excluded.

Outage history over the trailing twelve months: 6 recorded events (P1: 1, P2: 1, P3: 3, P4: 1). Average restoration time was 146 minutes across 5 restored events, for a total of approximately 2,020,887 customer-minutes of interruption on this feeder.

Cause breakdown: equipment failure — 2 event(s); vegetation contact — 1 event(s); storm damage — 1 event(s); overload — 1 event(s); animal contact — 1 event(s). No single failure mode dominates this feeder's outage history.