

Feeder Reliability Summary — feeder-040-0083

Reliability summary for feeder feeder-040-0083, a 12.0 kV distribution circuit rated 444 A, served from substation sub-newstephanie-040 in the Southwest region. Current feeder status: energized.

Customer base: this feeder serves 0 metered service points — . Only active and inactive meters count toward customers-affected figures in reliability reporting; disconnected services are excluded.

Outage history over the trailing twelve months: 2 recorded events (P4: 2). Average restoration time was 113 minutes across 2 restored events, for a total of approximately 540,662 customer-minutes of interruption on this feeder.

Cause breakdown: equipment failure — 1 event(s); overload — 1 event(s). No single failure mode dominates this feeder's outage history.