

Substation Operating Profile — sub-cassandraton-011

Substation sub-cassandraton-011 is a transmission substation located in the Pacific region, operating at a 500 kV voltage class. It was commissioned in January 2020 and its current operating status is in_service.

The substation serves 7 distribution feeders, of which 6 are currently energized. Installed transformer capacity across 8 units totals 199.91 MVA. The largest single unit is XFMR-00064 at 43.41 MVA.

Feeder inventory for sub-cassandraton-011: feeder-011-0052 (4.0 kV, 490 A, energized); feeder-011-0063 (25.0 kV, 660 A, energized); feeder-011-0075 (25.0 kV, 1141 A, energized); feeder-011-0085 (34.5 kV, 821 A, maintenance); feeder-011-0123 (12.0 kV, 377 A, energized); feeder-011-0240 (34.5 kV, 250 A, energized); feeder-011-0360 (25.0 kV, 625 A, energized).

Over the trailing twelve months, sub-cassandraton-011 recorded 6 outage events across its feeders, including 0 classified P1. Average restoration time (MTTR) across restored events was 311 minutes. The most frequent reported cause was overload (4 events).

Operational notes: switching at sub-cassandraton-011 must be coordinated with the control center under the standard switching-order procedure. As this is a transmission-class facility, all switching orders require verification by a second qualified person before execution.