

Substation Operating Profile — sub-juliechester-028

Substation sub-juliechester-028 is a switching substation located in the Midwest region, operating at a 138 kV voltage class. It was commissioned in April 2022 and its current operating status is in_service.

The substation serves 6 distribution feeders, of which 5 are currently energized. Installed transformer capacity across 7 units totals 233.86 MVA. The largest single unit is XFMR-00060 at 48.81 MVA.

Feeder inventory for sub-juliechester-028: feeder-028-0042 (34.5 kV, 723 A, energized); feeder-028-0106 (34.5 kV, 538 A, energized); feeder-028-0250 (34.5 kV, 614 A, energized); feeder-028-0253 (4.0 kV, 449 A, energized); feeder-028-0445 (34.5 kV, 588 A, energized); feeder-028-0487 (12.0 kV, 309 A, de-energized).

Over the trailing twelve months, sub-juliechester-028 recorded 5 outage events across its feeders, including 0 classified P1. Average restoration time (MTTR) across restored events was 228 minutes. The most frequent reported cause was unknown (3 events).

Operational notes: switching at sub-juliechester-028 must be coordinated with the control center under the standard switching-order procedure. Distribution-class switching may be executed by a single qualified operator once the switching order is approved.