

Transformer Inspection Report — XFMR-00353

Asset inspection record for transformer XFMR-00353, a 12.02 MVA unit manufactured by Siemens and installed in 2017 (9 years in service). The unit is connected to feeder feeder-009-0226 at substation sub-ericmouth-009 and its current status is in_service.

Visual inspection findings: oil level and condition — slight discoloration, within spec. Bushings — clean, gasket intact. Cooling fans and radiators were cycling correctly under load. Grounding connections were verified intact. Inspection performed by a Asset Inspector under weather conditions: ice accumulation.

SCADA alarm history for XFMR-00353 over the trailing twelve months shows 2 recorded alarms: communication loss (1), voltage sag (1). 1 of these remain unresolved.

Thermal alarm count (0) is below the capacity-upgrade-review threshold. No loading study is required at this time.

Recommended follow-up: re-inspect at the standard interval; no defects requiring intervention were found.