				1.1, 2.2 vs FR-6 - how anyone is told	FR-7 lets a user acknowledge an alert. What does acknowledging actually do - silence it, close it, assign it to someone, or just record it?	

				Appendix A and C vs FR-12 - configurable thresholds	SET-UP: Appendix C states that your motor temperature limits, all the pump bearing, current and vibration values, and every backup power supply value are team-selected and pending equipment-specific validation. But no requirement anywhere says a threshold can be changed - FR-12 gives the administrator 'system configuration' without defining what that covers, and Appendix A reads as a table of fixed values. QUESTION: When a real motor turns out to have a 110 degree limit rather than 150, does that take a settings change or a code change - and which requirement makes that true?	Sees the implication immediately: if the values are explicitly provisional then configurability is mandatory, not optional, and the requirement is missing. Writes it - thresholds settable per equipment class and per parameter by an authorised role, with validation of the entered values. The strongest answers go further and say that changing a safety threshold needs an audit record of who changed it and when, and that fault records must retain the threshold that was in force at the time, or historical faults become uninterpretable once the limits move.

				FR-10, FR-12, FR-13 - security	SET-UP: FR-13 requires authentication and FR-12 restricts configuration to administrators. FR-10 provides a remote-range connection mode. Beyond those two requirements, this document contains no security requirement at all: no encryption, no password rules, no session timeout, no audit log. QUESTION: Name the three security requirements this system most needs - and tell me what record exists of who acknowledged a critical fault.	For an industrial system reachable remotely: transport encryption named to a version, credential storage and password policy with session timeout, and audit logging. On the second half, recognises that FR-7 allows acknowledgement without defining what acknowledgement records, so after an incident there is no evidence of who saw the alert or when - which in an industrial safety context is precisely the record an investigation would ask for. Strong answers connect this to threshold changes too, and note that the team specified verification methods in detail but never asked how the system defends itself.

				NFR-4, NFR-6, NFR-10 - sampling rate	SET-UP: NFR-4 requires a measurement to appear on the dashboard within 2 seconds of the processing component receiving it. NFR-10 requires 30 days of retention. NFR-6 allows at most 1% of data to be lost across a connection interruption. But nothing in this document says how often a measurement is taken. QUESTION: How many records is 30 days for you - and how long an interruption can your local buffer survive before it breaches that 1% figure?	Sees that without a sampling rate none of those three requirements can be sized, tested or designed for - the data volume, the buffer capacity and the meaning of 1% all depend on it. Picks sensible rates per parameter, noting that vibration and current need far faster sampling than temperature, and works through records per day across three equipment types to an approximate storage figure. Then derives the buffer capacity implied by the 1% ceiling and observes that NFR-6 is only meaningful relative to a stated interruption duration, which the requirement does not give.

				2.3 vs 3.1.1 - the role model	SET-UP: Section 2.3 defines four user categories and 3.1.1 gives their permissions. In that matrix the Machine Operator, the Maintenance Technician and the Management Supervisor have identical permissions - only the System Administrator differs. Section 2.3 also says the maintenance engineer may require access to diagnostic and configuration functions, which the matrix denies. QUESTION: Why define four roles when the system only distinguishes two - and should a maintenance engineer be able to change a threshold?	Recognises that the role model does not follow from the user characteristics that precede it, and picks one of two honest resolutions: collapse to two roles and say so plainly, or differentiate properly so that technicians can run diagnostics and adjust thresholds, operators can view and acknowledge, and management receives reports without operational controls. Resolves the 2.3 contradiction explicitly. Strong answers argue that whoever may change a safety threshold should be separated from whoever acknowledges the resulting alerts, and tie that back to the audit requirement missing from the document.

				Sections 3, 4, 5 vs the issued structure; no diagrams	NFR-3 allows 60 seconds between a critical fault occurring and the alert appearing. Justify a minute for a motor above 150 degrees - against what consequence did you choose that number?	

				NFR-5, FR-10, Appendix C - product versus demonstration	SET-UP: NFR-5 requires 95% uptime 'during the demonstration, excluding planned restarts'. FR-10 says the final demonstration shall provide a selectable simulated mode for each connection type. Appendix C records that no classification model has been trained yet. QUESTION: Which of your requirements describe the product and which describe your coursework demonstration - and what would NFR-5 say for a factory running this system for a year?	Separates deliverable-scoped statements from product requirements and understands why the distinction matters: a client reading NFR-5 learns nothing about the availability they are buying. Rewrites it as a real availability requirement with a measurement window and stated maintenance exclusions. On FR-10, notices that the simulated mode switch is already recorded correctly in Appendix B as a design decision, so the requirement itself should state the outcome - local and remote access supported - and leave the simulation to the appendix. Credit is due for the candour about the untrained model; the answer should defend that choice rather than apologise for it.

				1.4 and Appendix A - sourcing the numbers	FR-7 lets a user acknowledge an alert. What does acknowledging actually do - silence it, close it, assign it to someone, or just record it?	