Structural & Waterproofing Inspection Checklist

Editable, fillable checklist for assessing structural integrity and waterproofing performance

Property / Site:

Address:

Inspector: **Date:**

Weather (last 72 hrs):

Building Age / Type:

Mark each item OK / Issue / N-A and add notes. Photograph and log measurements for every item flagged as an Issue.

1. Site & Drainage

ITEM	OK	Issue	N/A	NOTES
Grading slopes away from foundation (min. 6 in. over 10 ft)	☐	☐	☐	
Gutters and downspouts intact, unobstructed, and discharging away from foundation	☐	☐	☐	
No ponding water within 10 ft of structure after rain	☐	☐	☐	
Splash blocks / extensions present at downspout outlets	☐	☐	☐	
Window wells free of debris and fitted with covers	☐	☐	☐	
Vegetation and irrigation kept clear of foundation walls	☐	☐	☐	
Paved surfaces (driveway, walkways) sloped away from building	☐	☐	☐	

2. Foundation & Substructure

ITEM	OK	Issue	N/A	NOTES
No visible cracking in foundation walls (note width, length, pattern)	☐	☐	☐	
No stair-step cracking in masonry/block foundations	☐	☐	☐	
No horizontal bowing or bulging of foundation walls	☐	☐	☐	
Foundation-to-wall connections intact, no separation	☐	☐	☐	
Crawlspace / basement free of standing water or damp soil	☐	☐	☐	
Sump pump (if present) operational, discharge line routed away from house	☐	☐	☐	
Support posts, piers, and beams free of rot, rust, or crushing	☐	☐	☐	
No signs of differential settlement (uneven floors, sticking doors/windows)	☐	☐	☐	

3. Structural Frame & Envelope

ITEM	OK	Issue	N/A	NOTES
Load-bearing walls plumb, no visible lean or racking	☐	☐	☐	
Floor joists / beams free of sagging, splitting, or excessive deflection	☐	☐	☐	
Roof framing (rafters/trusses) intact, no sagging ridge line	☐	☐	☐	
Connections (joist hangers, hurricane ties, anchors) properly fastened	☐	☐	☐	
No active insect (termite/carpenter ant) or wood-rot damage	☐	☐	☐	
Exterior cladding secure, no delamination or missing sections	☐	☐	☐	
Masonry veneer/brick free of cracking, efflorescence, or spalling	☐	☐	☐	

4. Roof & Roof Waterproofing

ITEM	OK	Issue	N/A	NOTES
Roof covering intact, no missing, cracked, or curling shingles/tiles	☐	☐	☐	
Flashing intact at valleys, chimneys, skylights, and roof-wall junctions	☐	☐	☐	
Roof penetrations (vents, pipes) properly sealed	☐	☐	☐	
No ponding water on flat or low-slope roof areas	☐	☐	☐	
Membrane / built-up roofing free of blisters, tears, or open seams	☐	☐	☐	
Gutters free of granule buildup, rust, or sagging sections	☐	☐	☐	
Attic free of daylight gaps, water stains, or active leaks	☐	☐	☐	
Attic insulation dry and evenly distributed; ventilation unobstructed	☐	☐	☐	

5. Below-Grade & Basement Waterproofing

ITEM	OK	Issue	N/A	NOTES
Foundation walls free of moisture staining, efflorescence, or mineral deposits	☐	☐	☐	
No musty odor or visible mold/mildew growth	☐	☐	☐	
Waterproof/damp-proof coating on exterior foundation intact (where visible)	☐	☐	☐	
Interior drainage system (French drain/weeping tile) functioning, outlets clear	☐	☐	☐	
Vapor barrier present and intact on crawlspace floor	☐	☐	☐	

Window well drains clear and functioning	☐	☐	☐	
Moisture meter readings within acceptable range (record values)	☐	☐	☐	

6. Exterior Walls, Windows & Doors

ITEM	OK	Issue	N/A	NOTES
Sealant/caulking intact around window and door perimeters	☐	☐	☐	
Weep holes in masonry veneer clear and unobstructed	☐	☐	☐	
Flashing above windows, doors, and horizontal trim present and lapped correctly	☐	☐	☐	
No cracking or gaps at siding/trim joints	☐	☐	☐	
Deck and balcony ledger flashing intact, no rot at attachment point	☐	☐	☐	
Exterior stairs and railings structurally sound and securely anchored	☐	☐	☐	

7. Plumbing-Related Moisture Sources

ITEM	OK	Issue	N/A	NOTES
No active leaks at visible supply or drain lines	☐	☐	☐	
Water heater and connections free of corrosion or leakage	☐	☐	☐	
Hose bibs and irrigation lines free of leaks, backflow preventer present	☐	☐	☐	
Under-sink and appliance supply lines dry, no staining on cabinetry	☐	☐	☐	

8. Interior Signs of Water Intrusion

ITEM	OK	Issue	N/A	NOTES
Ceilings and walls free of water staining or discoloration	☐	☐	☐	
No bubbling, peeling paint, or bulging drywall/plaster	☐	☐	☐	
Flooring free of cupping, warping, or staining near exterior walls	☐	☐	☐	
No visible mold growth in closets, corners, or behind furniture	☐	☐	☐	
Relative humidity in living space within normal range (30-50%)	☐	☐	☐	

9. Overall Condition Rating

RATING	DESCRIPTION
Good	No deficiencies observed; routine maintenance only
Fair	Minor deficiencies noted; monitor or schedule non-urgent repair
Poor	Significant deficiency; repair recommended within 6-12 months
Critical	Safety or active water-intrusion concern; immediate action required

Summary of Priority Items

1. _____

2. _____

3. _____

4. _____

5. _____

Inspector Signature: _____ **Date:** _____

This checklist is a general field aid and does not replace evaluation by a licensed structural engineer or waterproofing specialist. Items flagged as Issue or Critical should be documented with photographs and referred for professional assessment.