# SITE FEASIBILITY | CLIENT SUMMARY

Nandi Housing - preliminary feasibility test | Prepared 2026-11-03 | Early-stage review

**Blocked: At least one check fails. This scheme cannot proceed as entered.**

### Current position: possible rule found, confirmation still needed

The selected configured table gives a maximum FAR candidate of 2.5. This is a rule-based starting point, not a sanctioned entitlement. Confirm the jurisdiction, official land-use zone, road width and current rule before relying on it.

| PLOT AREA | ROAD WIDTH PROVIDED | PROPOSED PROJECT | SITE SHAPE |
|---|---|---|---|
| 2,200 m² | 18.50 m | Residential apartments | Irregular / non-rectangular |

## What this means in everyday language

The selected rule profile identifies a maximum FAR candidate of **2.50**, which gives a preliminary benchmark of **5,500 m²** of floor area using the plot area of **2,200 m²**. This is a rule-based candidate, not an approval. Confirm the exact jurisdiction, official zone, road width and operative notification before relying on it. All 3 concept options currently exceed that working target. Option 01 is the closest, at 432 m² above it. The FAR rule must be confirmed before deciding whether to reduce floor area or test a different permitted scenario.

| | |
|---|---|
| Site location | Southern Bengaluru (map pin supplied by user) \| Open map |
| Planning zone entered | Residential (Main) (must be checked against the official map) |
| Building height options | 12 m, 15 m, 18 m |

## Recommended next steps

**1.** Confirm which planning authority and official land-use zone apply to this exact parcel.

**2.** Get the authority to clarify the applicable FAR for the entered plot area and road width.

**3.** Use an authenticated site survey to check the irregular boundary, road edge and any overlays before fixing a building footprint.

# COMPARE THE DESIGN OPTIONS

The figures below are based on the footprints, floor counts and FAR scenarios entered by the project team. They are for comparison, not a statement of approved development rights.

Comparison benchmark: **5,500 m²** of floor area (FAR 2.50; rule-derived FAR candidate). Confirm the rule before using this figure as a project limit.

| Option | Height / floors | Ground footprint | Approx. floor area* | Compared with working target | Preliminary setback distances |
|---|---|---|---|---|---|
| Option 01 | 12 m / 4 floors | 1,483 m² | 5,932 m² | 432 m² above target | Front 8.16 m; rear 5.44 m; sides 2.64 / 2.64 m |
| Option 02 | 15 m / 5 floors | 1,271 m² | 6,355 m² | 855 m² above target | 5.00 m on all sides |
| Option 03 | 18 m / 6 floors | 1,106 m² | 6,636 m² | 1,136 m² above target | 6.00 m on all sides |

## How to read this table

- **Ground footprint** is the area covered by the building at ground level.
- **Approx. floor area** is footprint × floor count. It assumes similar floor area on each level; it does not model exclusions, terraces, service areas or changes to individual floors.
- **FAR ratio basis** is shown where the selected source table uses a configured net calculation area after a specified reservation/deduction. The area figure above remains the gross concept estimate (footprint × floors); the FAR ratio denominator follows the configured rule profile and needs confirmation.
- **Setbacks** are open spaces between the building and the plot boundary. The distances shown are rule-profile calculations only. Because this plot is irregular, the actual boundary must be surveyed and the distances applied to its real geometry.

## Setback rule basis used for each option

| Option | Basis used in this study | What still needs checking |
|---|---|---|
| Option 01 | **Building:** Percentage method (nominal distances): Front 8.16 m; rear 5.44 m; side 2.64/2.64 m<br>**Basement:** Basement: not proposed | Confirm height definition, stilt condition, current applicable table, road-facing edge and surveyed boundary. |
| Option 02 | **Building:** Height-band rule (preliminary): 5.00 m on all sides<br>**Basement:** Basement: not proposed | Confirm height definition, stilt condition, current applicable table, road-facing edge and surveyed boundary. |
| Option 03 | **Building:** Height-band rule (preliminary): 6.00 m on all sides<br>**Basement:** Basement: not proposed | Confirm height definition, stilt condition, current applicable table, road-facing edge and surveyed boundary. |

*Approximate floor area is not the final FAR-counted area. Applicable exclusions and authority-approved calculations may change the result.

# WHAT NEEDS TO BE CHECKED NEXT

These are the decisions and documents needed before the options can be treated as reliable design feasibility.

| Check | Why it matters | Next action | Status |
|---|---|---|---|
| Planning jurisdiction and boundary | Which authority approves this exact site? | Confirm the parcel boundary, corporation/planning authority and sanctioning route from official records. | To confirm |
| Official land-use zone / selected rule category | Confirm the official land-use classification against the relevant notified map. The selected category drives this FAR lookup. | Review with the project team and relevant authority. | To confirm |
| Maximum FAR lookup | The table's road-width FAR is 2.50; the plot-area FAR cap is 3.00. SiteIQ uses the lower value, 2.50, following the source's road-width and plot-area limit notes. Confirm the zone and operative table before design freeze. | Review with the project team and relevant authority. | Candidate Match Requires Verification |
| Survey geometry / boundary | Where exactly can the building sit? | Obtain an authenticated survey for the irregular boundary and verify the stated site area. | To confirm |
| Building and basement setbacks | Compare the selected rule and each option's building and basement setbacks; special geometry and frontage remain to be checked. | Review with the project team and relevant authority. | Calculated Candidate |
| Lake, drain, HT line, road widening and other overlays | Are there restrictions affecting the buildable area? | Check the official overlays for water bodies, drains, high-tension lines, flood-prone areas and road widening. | To confirm |
| Parking, accessibility, structure and services | Can the concept work safely and functionally? | Check dwelling mix, parking, access, accessible routes, fire strategy, structure and services. | Design review |
| Fire NOC trigger | What fire approvals and design provisions are required? | Confirm the applicable threshold and current procedure with the fire authority and fire consultant. | Nbc Band Requires Confirmation |

## A few terms in simple language

| | |
|---|---|
| **FAR** | A ratio used to limit the floor area counted under the regulations compared with the plot area. |
| **Setback** | The open space required between the building and the plot boundary. |
| **Footprint** | The area the building covers at ground level. |
| **Working FAR target** | A comparison assumption only. It is not a confirmed permission until the applicable rule is verified. |

**Survey note:** the entered frontage × depth equals 2,244.00 m², compared with the stated plot area of 2,200.00 m². The difference is 2.00%. Because the site is irregular, this is only a consistency check; the authenticated survey area and boundary should be used for design.

**Still open:** 3 failed, 18 need information and 15 need confirming. Your architect holds the full register.