SITE FEASIBILITY | CLIENT SUMMARY

Nandi Housing - preliminary feasibility test | Prepared 2026-11-02 | Early-stage review

Blocked: At least one check fails. This scheme cannot proceed as entered.

Current position: possible rule found, confirmation still needed

The selected configured table gives a maximum FAR candidate of 2.5. This is a rule-based starting point, not a sanctioned entitlement. Confirm the jurisdiction, official land-use zone, road width and current rule before relying on it.

PLOT AREA	ROAD WIDTH PROVIDED	PROPOSED PROJECT	SITE SHAPE
2,200 m²	18.50 m	Residential apartments	Irregular / non-rectangular

What this means in everyday language

The selected rule profile identifies a maximum FAR candidate of **2.50**, which gives a preliminary benchmark of **5,500 m²** of floor area using the plot area of **2,200 m²**. This is a rule-based candidate, not an approval. Confirm the exact jurisdiction, official zone, road width and operative notification before relying on it. All 3 concept options currently exceed that working target. Option 01 is the closest, at 432 m² above it. The FAR rule must be confirmed before deciding whether to reduce floor area or test a different permitted scenario.

Site location	Southern Bengaluru (map pin supplied by user) | Open map
Planning zone entered	Residential (Main) (must be checked against the official map)
Building height options	12 m, 15 m, 18 m

Recommended next steps

1. Confirm which planning authority and official land-use zone apply to this exact parcel.

2. Get the authority to clarify the applicable FAR for the entered plot area and road width.

3. Use an authenticated site survey to check the irregular boundary, road edge and any overlays before fixing a building footprint.

COMPARE THE DESIGN OPTIONS

The figures below are based on the footprints, floor counts and FAR scenarios entered by the project team. They are for comparison, not a statement of approved development rights.

Comparison benchmark: **5,500 m²** of floor area (FAR 2.50; rule-derived FAR candidate). Confirm the rule before using this figure as a project limit.

Option	Height / floors	Ground footprint	Approx. floor area*	Compared with working target	Preliminary setback distances
Option 01	12 m / 4 floors	1,483 m²	5,932 m²	432 m² above target	Front 8.16 m; rear 5.44 m; sides 2.64 / 2.64 m
Option 02	15 m / 5 floors	1,271 m²	6,355 m²	855 m² above target	5.00 m on all sides
Option 03	18 m / 6 floors	1,106 m²	6,636 m²	1,136 m² above target	6.00 m on all sides

How to read this table

- **Ground footprint** is the area covered by the building at ground level.
- **Approx. floor area** is footprint × floor count. It assumes similar floor area on each level; it does not model exclusions, terraces, service areas or changes to individual floors.
- **FAR ratio basis** is shown where the selected source table uses a configured net calculation area after a specified reservation/deduction. The area figure above remains the gross concept estimate (footprint × floors); the FAR ratio denominator follows the configured rule profile and needs confirmation.
- **Setbacks** are open spaces between the building and the plot boundary. The distances shown are rule-profile calculations only. Because this plot is irregular, the actual boundary must be surveyed and the distances applied to its real geometry.

Setback rule basis used for each option

Option	Basis used in this study	What still needs checking
Option 01	**Building:** Percentage method (nominal distances): Front 8.16 m; rear 5.44 m; side 2.64/2.64 m **Basement:** Basement: not proposed	Confirm height definition, stilt condition, current applicable table, road-facing edge and surveyed boundary.
Option 02	**Building:** Height-band rule (preliminary): 5.00 m on all sides **Basement:** Basement: not proposed	Confirm height definition, stilt condition, current applicable table, road-facing edge and surveyed boundary.
Option 03	**Building:** Height-band rule (preliminary): 6.00 m on all sides **Basement:** Basement: not proposed	Confirm height definition, stilt condition, current applicable table, road-facing edge and surveyed boundary.

*Approximate floor area is not the final FAR-counted area. Applicable exclusions and authority-approved calculations may change the result.

WHAT NEEDS TO BE CHECKED NEXT

These are the decisions and documents needed before the options can be treated as reliable design feasibility.

Check	Why it matters	Next action	Status
Planning jurisdiction and boundary	Which authority approves this exact site?	Confirm the parcel boundary, corporation/planning authority and sanctioning route from official records.	To confirm
Official land-use zone / selected rule category	Confirm the official land-use classification against the relevant notified map. The selected category drives this FAR lookup.	Review with the project team and relevant authority.	To confirm
Maximum FAR lookup	The table's road-width FAR is 2.50; the plot-area FAR cap is 3.00. SiteIQ uses the lower value, 2.50, following the source's road-width and plot-area limit notes. Confirm the zone and operative table before design freeze.	Review with the project team and relevant authority.	Candidate Match Requires Verification
Survey geometry / boundary	Where exactly can the building sit?	Obtain an authenticated survey for the irregular boundary and verify the stated site area.	To confirm
Building and basement setbacks	Compare the selected rule and each option's building and basement setbacks; special geometry and frontage remain to be checked.	Review with the project team and relevant authority.	Calculated Candidate
Lake, drain, HT line, road widening and other overlays	Are there restrictions affecting the buildable area?	Check the official overlays for water bodies, drains, high-tension lines, flood-prone areas and road widening.	To confirm
Parking, accessibility, structure and services	Can the concept work safely and functionally?	Check dwelling mix, parking, access, accessible routes, fire strategy, structure and services.	Design review
Fire NOC trigger	What fire approvals and design provisions are required?	Confirm the applicable threshold and current procedure with the fire authority and fire consultant.	Nbc Band Requires Confirmation

A few terms in simple language

FAR	A ratio used to limit the floor area counted under the regulations compared with the plot area.
Setback	The open space required between the building and the plot boundary.
Footprint	The area the building covers at ground level.
Working FAR target	A comparison assumption only. It is not a confirmed permission until the applicable rule is verified.

Survey note: the entered frontage × depth equals 2,244.00 m², compared with the stated plot area of 2,200.00 m². The difference is 2.00%. Because the site is irregular, this is only a consistency check; the authenticated survey area and boundary should be used for design.

Still open: 3 failed, 20 need information and 18 need confirming. Your architect holds the full register.