SITE FEASIBILITY | CLIENT SUMMARY

Nandi Housing - preliminary feasibility test | Prepared 2026-11-02 | Early-stage review

Blocked: At least one check fails. This scheme cannot proceed as entered.

Current position: possible rule found, confirmation still needed

The selected configured table gives a maximum FAR candidate of 2.5. This is a rule-based starting point, not a sanctioned entitlement. Confirm the jurisdiction, official land-use zone, road width and current rule before relying on it.

PLOT AREA	ROAD WIDTH PROVIDED	PROPOSED PROJECT	SITE SHAPE
2,200 m²	18.50 m	Residential apartments	Irregular / non-rectangular

What this means in everyday language

The selected rule profile identifies a maximum FAR candidate of **2.50**, which gives a preliminary benchmark of **5,500 m²** of floor area using the plot area of **2,200 m²**. This is a rule-based candidate, not an approval. Confirm the exact jurisdiction, official zone, road width and operative notification before relying on it. All 3 concept options currently exceed that working target. Option 01 is the closest, at 432 m² above it. The FAR rule must be confirmed before deciding whether to reduce floor area or test a different permitted scenario.

Site location	Southern Bengaluru (map pin supplied by user) | Open map
Planning zone entered	Residential (Main) (must be checked against the official map)
Building height options	12 m, 15 m, 18 m

Recommended next steps

1. Confirm which planning authority and official land-use zone apply to this exact parcel.

2. Get the authority to clarify the applicable FAR for the entered plot area and road width.

3. Use an authenticated site survey to check the irregular boundary, road edge and any overlays before fixing a building footprint.

COMPARE THE DESIGN OPTIONS

The figures below are based on the footprints, floor counts and FAR scenarios entered by the project team. They are for comparison, not a statement of approved development rights.

Comparison benchmark: **5,500 m²** of floor area (FAR 2.50; rule-derived FAR candidate). Confirm the rule before using this figure as a project limit.

Option	Height / floors	Ground footprint	Approx. floor area*	Compared with working target	Preliminary setback distances
Option 01	12 m / 4 floors	1,483 m²	5,932 m²	432 m² above target	Front 8.16 m; rear 5.44 m; sides 2.64 / 2.64 m
Option 02	15 m / 5 floors	1,271 m²	6,355 m²	855 m² above target	5.00 m on all sides
Option 03	18 m / 6 floors	1,106 m²	6,636 m²	1,136 m² above target	6.00 m on all sides

How to read this table

- **Ground footprint** is the area covered by the building at ground level.
- **Approx. floor area** is footprint × floor count. It assumes similar floor area on each level; it does not model exclusions, terraces, service areas or changes to individual floors.
- **FAR ratio basis** is shown where the selected source table uses a configured net calculation area after a specified reservation/deduction. The area figure above remains the gross concept estimate (footprint × floors); the FAR ratio denominator follows the configured rule profile and needs confirmation.
- **Setbacks** are open spaces between the building and the plot boundary. The distances shown are rule-profile calculations only. Because this plot is irregular, the actual boundary must be surveyed and the distances applied to its real geometry.

Setback rule basis used for each option

Option	Basis used in this study	What still needs checking
Option 01	**Building:** Percentage method (nominal distances): Front 8.16 m; rear 5.44 m; side 2.64/2.64 m **Basement:** Basement: not proposed	Confirm height definition, stilt condition, current applicable table, road-facing edge and surveyed boundary.
Option 02	**Building:** Height-band rule (preliminary): 5.00 m on all sides **Basement:** Basement: not proposed	Confirm height definition, stilt condition, current applicable table, road-facing edge and surveyed boundary.
Option 03	**Building:** Height-band rule (preliminary): 6.00 m on all sides **Basement:** Basement: not proposed	Confirm height definition, stilt condition, current applicable table, road-facing edge and surveyed boundary.

*Approximate floor area is not the final FAR-counted area. Applicable exclusions and authority-approved calculations may change the result.

WHAT NEEDS TO BE CHECKED NEXT

These are the decisions and documents needed before the options can be treated as reliable design feasibility.

Check	Why it matters	Next action	Status
Planning jurisdiction and boundary	Which authority approves this exact site?	Confirm the parcel boundary, corporation/planning authority and sanctioning route from official records.	To confirm
Official land-use zone / selected rule category	Confirm the official land-use classification against the relevant notified map. The selected category drives this FAR lookup.	Review with the project team and relevant authority.	To confirm
Maximum FAR lookup	The table's road-width FAR is 2.50; the plot-area FAR cap is 3.00. SiteIQ uses the lower value, 2.50, following the source's road-width and plot-area limit notes. Confirm the zone and operative table before design freeze.	Review with the project team and relevant authority.	Candidate Match Requires Verification
Survey geometry / boundary	Where exactly can the building sit?	Obtain an authenticated survey for the irregular boundary and verify the stated site area.	To confirm
Building and basement setbacks	Compare the selected rule and each option's building and basement setbacks; special geometry and frontage remain to be checked.	Review with the project team and relevant authority.	Calculated Candidate
Lake, drain, HT line, road widening and other overlays	Are there restrictions affecting the buildable area?	Check the official overlays for water bodies, drains, high-tension lines, flood-prone areas and road widening.	To confirm
Parking, accessibility, structure and services	Can the concept work safely and functionally?	Check dwelling mix, parking, access, accessible routes, fire strategy, structure and services.	Design review
Fire NOC trigger	What fire approvals and design provisions are required?	Confirm the applicable threshold and current procedure with the fire authority and fire consultant.	Nbc Band Requires Confirmation

A few terms in simple language

FAR	A ratio used to limit the floor area counted under the regulations compared with the plot area.
Setback	The open space required between the building and the plot boundary.
Footprint	The area the building covers at ground level.
Working FAR target	A comparison assumption only. It is not a confirmed permission until the applicable rule is verified.

Survey note: the entered frontage × depth equals 2,244.00 m², compared with the stated plot area of 2,200.00 m². The difference is 2.00%. Because the site is irregular, this is only a consistency check; the authenticated survey area and boundary should be used for design.

TECHNICAL REFERENCES & ASSUMPTIONS

This appendix keeps the calculation trail visible without making the client summary difficult to read.

Rule references used by this report

Rule / topic	Document and exact reference	Status / link
Revised Master Plan 2015 - Zoning of Land Use and Regulations, Table 10 (Residential Main) Chapter 4, Regulation 4.1.2, Table 10	BBMP 2015.pdf (provided by user) PDF page 28; printed page 27	provided_source; older base document; applicability must be checked against amendments Open source / authority page
Zonal Regulations of the Revised Master Plan 2015 of Bengaluru and Greater Bengaluru (Amendment) Regulations 2025 Chapter 3, Regulation 3.1 Tables 8-9; Regulation 3.9 basement; Regulation 3.10 ramps; Chapter 4 amendments including Table 16 and Mutation Corridors	UDD 235 MNJ 2025(E) Amendment 01.pdf (provided by user) PDF pages 2-6; printed pages 2-6	final notification in user-supplied document; subsequent updates/applicability still need verification Open source / authority page
Zonal Regulations of Revised Master Plan 2015 of Bengaluru (Amendment) Regulations 2025 - Single Plot Approval / Chapter 6-A Definitions, Regulation 3.9 basement setback and Chapter 6-A	UDD 272 MNJ 2025(E) Amendment 05.pdf (provided by user) PDF pages 2-5; printed pages 2-5	final notification in user-supplied document; applicability and grandfather clause must be checked Open source / authority page
Karnataka Fire Force (Amendment) Act, 2023 Section 13: high-rise definition / Fire NOC trigger at 21 metres or above	Karnataka Act No. 24 of 2023 Amendment 03.pdf (provided by user) PDF pages 1-3	provided primary legislation; current administrative procedure and other fire provisions need review Open source / authority page
Revised Master Plan 2015 - Zoning of Land Use and Regulations, Tables 10-19 Chapter 4, Regulations 4.1-4.10, Tables 10-19; Chapter 3, Regulation 3.4(iii)-(iv)	BBMP 2015.pdf (provided by user) PDF pages 28-37; printed pages 27-36	provided base source; apply supplied subsequent amendments and verify current operative text Open source / authority page
Revised Master Plan 2015 Vol. III, Zoning of Land Use and Regulations (G.O. UDD 540 BEM AA SE 2004, 22-06-2007) Definitions 18 and 40; Regulations 3.4 and 3.9; Tables 10, 12, 14 and 23; Chapter 7	Public copy hosted by OpenCity	Tables 10, 12 and 14 and Table 23 compared with this copy on 2026-11-02. Later amendments may change them. Open source / authority page
UDD 235 MNJ 2025(E), 05-01-2026 Tables 8 and 16; Table 9 notes; Regulations 3.9 and 3.10; Table 10 notes (b) and (c)	UDD 235 MNJ 2025(E) Public scan hosted by OpenCity Pages 2-6	Pages 2-6 compared with the configured rules on 2026-11-02. Open source / authority page
Premium FAR amendment effective 5 February 2026, as described in commentary on the June 2026 High Court judgment Additional FAR by road width	Cyril Amarchand Mangaldas blog, July 2026	Secondary source. The notification itself has not been read. Open source / authority page

Optional additional FAR scenario — not included in the base benchmark

Optional additional FAR up to 0.6× base FAR may be available through a Premium FAR/TDR combination under the cited scheme. This is not included in the base benchmark and is not an entitlement; charges, mix and eligibility are not calculated.
Status: premium far plus tdr candidate
Illustrative total FAR ceiling: 4.00
Illustrative total floor area: 8,800 m²
Open source reference

Location auto-identification record

Field	Result	Status / provenance
Coordinates	12.8710030, 77.5699190	illustrative sample only
Authority / rules profile	Bengaluru / Greater Bengaluru RMP 2015 profile	Provisional Geocoder Candidate Illustrative location candidate only; current planning boundary is not established. Source

Field	Result	Status / provenance
Land-use zone	Not verified	Layer Not Installed No official land-use polygon match is claimed in this sample.
Approval route	Not sure / needs confirmation	Suggestion Only Confirm official jurisdiction, land-use zone and the applicable approval path.

Indicative only: geocoder results do not establish legal jurisdiction or zoning. A confirmed status requires a current official-source polygon match.

Official map and planning-source links

Source	What it can establish	Link / status
Greater Bengaluru Authority GIS Viewer	Official interactive viewer for city corporation/ward context. It is not treated by SiteIQ as a verified planning-authority or land-use API.	Open official page Reference page; not a verified geometry match
Greater Bengaluru Authority — official portal	Use for current notifications and corporate/jurisdiction information; verify the parcel against the notified planning boundary.	Open official page Reference page; not a verified geometry match
Bangalore Development Authority — RMP 2015 maps and zoning regulations	Contains published RMP map sheets and regulations. A PDF map sheet is a reference, not automatically a georeferenced zoning polygon.	Open official page Reference page; not a verified geometry match

Important: This is a preliminary feasibility aid, not a sanction report or confirmation of development rights. Verify operative regulations and authority interpretation before commercial commitments or submission.

CALCULATION TRACE

Option	Floors	Gross floor area	Excluded	Counted for FAR	FAR	Remaining	Envelope	Footprint from
Option 01	4	5,932 m²	0 m²	5,932 m²	2.70	-432 m²	—	As entered
Option 02	5	6,355 m²	0 m²	6,355 m²	2.89	-855 m²	—	As entered
Option 03	6	6,636 m²	0 m²	6,636 m²	3.02	-1,136 m²	—	As entered

COMPLIANCE REGISTER

3 fail · 20 needs input · 15 confirm · 3 not configured · 10 pass

Status	Check	Option	Finding	Source
Fail	FAR capacity	Option 01	This option exceeds the FAR capacity by 432 m². Premium FAR and TDR are not counted.	—
Fail	FAR capacity	Option 02	This option exceeds the FAR capacity by 855 m². Premium FAR and TDR are not counted.	—
Fail	FAR capacity	Option 03	This option exceeds the FAR capacity by 1,136 m². Premium FAR and TDR are not counted.	—
Needs input	Planning authority	All	No official boundary evidence supports this authority. Check the notified planning area, then mark it as confirmed.	—
Needs input	Site location	All	The location was not identified. Run the location lookup or import a georeferenced boundary.	—
Needs input	Land-use zone	All	Check the category against the official land-use map, then mark it as confirmed.	—
Needs input	Surveyed boundary	All	No boundary is applied, so the area is as typed and no envelope can be drawn.	—
Needs input	Road width source	All	Record where the road width came from: notified, surveyed or measured.	—
Needs input	Land conversion	All	Record whether the land has been converted for non-agricultural use.	—
Needs input	Earlier sanctions	All	Record whether an earlier sanction or layout exists on this land.	—
Needs input	Lake or tank	All	Check the official maps and record whether this affects the site. SiteIQ has no official layer for it.	—
Needs input	Drain or rajakaluve	All	Check the official maps and record whether this affects the site. SiteIQ has no official layer for it.	—
Needs input	High-tension power line	All	Check the official maps and record whether this affects the site. SiteIQ has no official layer for it.	—
Needs input	Airport height zone	All	Check the official maps and record whether this affects the site. SiteIQ has no official layer for it.	—
Needs input	Protected monument	All	Check the official maps and record whether this affects the site. SiteIQ has no official layer for it.	—
Needs input	Railway land	All	Check the official maps and record whether this affects the site. SiteIQ has no official layer for it.	—
Needs input	Defence establishment	All	Check the official maps and record whether this affects the site. SiteIQ has no official layer for it.	—
Needs input	National or state highway	All	Check the official maps and record whether this affects the site. SiteIQ has no official layer for it.	—
Needs input	Flood-prone or low-lying land	All	Check the official maps and record whether this affects the site. SiteIQ has no official layer for it.	—
Needs input	Road widening or master-plan road	All	Check the official maps and record whether this affects the site. SiteIQ has no official layer for it.	—
Needs input	Parking	Option 01	Enter the number of dwelling units and their average floor area to calculate parking.	Revised Master Plan 2015 Vol. III, Zoning of Land Use and Regulations (G.O. UDD 540 BEM AA SE 2004, 22-06-2007)
Needs input	Parking	Option 02	Enter the number of dwelling units and their average floor area to calculate parking.	Revised Master Plan 2015 Vol. III, Zoning of Land Use and Regulations (G.O. UDD 540 BEM AA SE 2004, 22-06-2007)
Needs input	Parking	Option 03	Enter the number of dwelling units and their average floor area to calculate parking.	Revised Master Plan 2015 Vol. III, Zoning of Land Use and Regulations (G.O. UDD 540 BEM AA SE 2004, 22-06-2007)
Confirm	Rule profile	All	This profile is compared with the published source documents, but not independently reviewed. Do not freeze a design on it. Bengaluru / Greater Bengaluru RMP 2015 - selected rules, 2026 update	—
Confirm	FAR table match	All	The table's road-width FAR is 2.50; the plot-area FAR cap is 3.00. SiteIQ uses the lower value, 2.50, following the source's road-width and plot-area limit notes. Confirm the zone and operative table before design freeze.	Revised Master Plan 2015 - Zoning of Land Use and Regulations, Tables 10-19
Confirm	Close to a rule threshold	All	A plot area of 2,189.00 m² gives no FAR, against 2.50 now. Confirm the exact legal figure before relying on this.	—
Confirm	Close to a rule threshold	All	A plot area of 2,211.00 m² gives no FAR, against 2.50 now. Confirm the exact legal figure before relying on this.	—
Confirm	Close to a rule threshold	All	A road width of 18.25 m gives no FAR, against 2.50 now. Confirm the exact legal figure before relying on this.	—

Status	Check	Option	Finding	Source
Confirm	Close to a rule threshold	All	A road width of 18.75 m gives no FAR, against 2.50 now. Confirm the exact legal figure before relying on this.	—
Confirm	Building setbacks	Option 01	Front 8.16 / Rear 5.44 / Sides 2.64, 2.64 m. Table 8: above 250 m² up to 4,000 m²; percentage setbacks use site depth and width at varying points. Nominal dimensions alone do not define an irregular-site envelope.	UDD 235 MNJ 2025(E)
Confirm	Building setbacks	Option 02	5.00 m all sides. Height-band reading from the supplied Table 9; confirm the applicable row and definition with the authority.	UDD 235 MNJ 2025(E)
Confirm	Fire NOC	Option 02	From 15 m up to 21 m, NBC 2016 Part 4 treats the building as high-rise and the 2026 Bengaluru amendment requires NBC fire compliance. A 2011 notification set the NOC at 15 m, so confirm with the local fire station whether an NOC applies.	Karnataka Act No. 24 of 2023
Confirm	Building setbacks	Option 03	6.00 m all sides. All-round setback from supplied Table 9; confirm exact height definition and applicable row.	UDD 235 MNJ 2025(E)
Confirm	Fire NOC	Option 03	From 15 m up to 21 m, NBC 2016 Part 4 treats the building as high-rise and the 2026 Bengaluru amendment requires NBC fire compliance. A 2011 notification set the NOC at 15 m, so confirm with the local fire station whether an NOC applies.	Karnataka Act No. 24 of 2023
Confirm	FAR exclusions	Option 01	No exclusions were entered, so all floor area counts towards FAR. Enter parking and core areas where the rule allows them.	—
Confirm	FAR exclusions	Option 02	No exclusions were entered, so all floor area counts towards FAR. Enter parking and core areas where the rule allows them.	—
Confirm	FAR exclusions	Option 03	No exclusions were entered, so all floor area counts towards FAR. Enter parking and core areas where the rule allows them.	—
Confirm	RERA registration	All	RERA section 3(2)(a) exempts small projects, but regulators read the 500 m² and 8-apartment limits differently. Confirm registration with Karnataka RERA.	Real Estate (Regulation and Development) Act 2016, section 3(2)(a)
Not configured	Accessibility	All	Detailed accessibility standards are not configured. Check the applicable building bye-laws and NBC 2016.	—
Not configured	Services and utilities	All	Water, sewerage, STP, rainwater harvesting and transformer rules are not configured for this case. Confirm them with the local agencies.	—
Not configured	Multiple blocks	All	Building separation is not configured for this authority. Each option is assessed as a single block.	—
Pass	Height and floors	Option 01	3.00 m per floor is plausible.	—
Pass	Ground coverage	Option 01	The configured amendment does not apply a coverage limit at this plot size.	UDD 235 MNJ 2025(E)
Pass	Fire NOC	Option 01	Below 15 m the high-rise triggers are not met. Ordinary fire and access provisions still apply.	Karnataka Act No. 24 of 2023
Pass	Environmental clearance	Option 01	About 5,932 m² built up, below the 20,000 m² trigger.	EIA Notification 2006, Schedule item 8(a)
Pass	Height and floors	Option 02	3.00 m per floor is plausible.	—
Pass	Ground coverage	Option 02	The configured amendment does not apply a coverage limit at this plot size.	UDD 235 MNJ 2025(E)
Pass	Environmental clearance	Option 02	About 6,355 m² built up, below the 20,000 m² trigger.	EIA Notification 2006, Schedule item 8(a)
Pass	Height and floors	Option 03	3.00 m per floor is plausible.	—
Pass	Ground coverage	Option 03	The configured amendment does not apply a coverage limit at this plot size.	UDD 235 MNJ 2025(E)
Pass	Environmental clearance	Option 03	About 6,636 m² built up, below the 20,000 m² trigger.	EIA Notification 2006, Schedule item 8(a)