

CHANGE LOG - Job ON1012P263841 (GMV-5809)

SHEET	FIELD	BEFORE	AFTER
S1.1 Technical Data	CAPACITY lb [kg]	2300 [1043]	2500 [1134]
S1.1 Technical Data	NO. OF FLOORS	4	2
S1.1 Technical Data	NO. OF OPENINGS	FRONT: 4 / REAR: 0	FRONT: 2 / REAR: 0
S1.1 Technical Data	CAB DIMENSIONS	58.5 [1486] W x 68 [1727] D x 90 [2286] H	81 [2057] W x 51 [1295] D x 90 [2286] H
S1.1 Technical Data	SYSTEM	TWIN 1:1 DIRECT ACTING HYDRAULIC	1:1 DIRECT ACTING HYDRAULIC
S1.1 Technical Data	CAB LIGHT	DIFFUSER PANEL	LED
S1.2 Elevation View	Floor label, row 1	*G TO 1	*G TO 2
S1.2 Elevation View	Floor-to-floor distance, row 1	162"	125"
S1.2 Elevation View	Floor label, row 2 (unused with 2 stops)	1 TO 2	-
S1.2 Elevation View	Floor label, row 3 (unused with 2 stops)	2 TO 3	-
S1.2 Elevation View	Floor-to-floor distance, row 2	126"	-
S1.2 Elevation View	Floor-to-floor distance, row 3	120"	-
S1.5 Cab Detail	CAB REVEALS - Black Powder Coat mark	-	X
S1.5 Cab Detail	CAB REVEALS - Satin Stainless mark	X	-
S1.5 Cab Detail	ENTRANCE size (layer 2500lbs F)	42" [1065] WIDE X 85" [2150] HIGH	42" [1065] WIDE X 84 5/8" [2150] HIGH
S1.7 COP Detail	OPENINGS	4	2
S1.7 COP Detail	FLOOR MARKINGS	*G / 1 / 2 / 3	*G / 2
S1.7 COP Detail	CAPACITY (layer 2500lbs F)	2500lb / 1136kg	2500lb / 1134kg
S1.8 Hall Fixture	Top floor label	FLOOR - 3	FLOOR - 2
S1.7 COP Detail	TELEPHONE	INSIDE COMPARTMENT, CALL WITH PUSHBUTTON	PUSH BUTTON, BRAILLE TAG, CALL ACK. INDICATOR

LAYERS: "2500lbs F" turned ON (was off) | "2500lbs F&R" left OFF | new OFF layer "CLAUDE_HIDDEN_2300_ORIGINALS" holds 4 superseded 2300 lb texts (nothing deleted).

Geometry, footers and title-block fields were NOT changed. Viewport drawings do not render in these previews (text/table fields only).

S1.1 - ENG CALCS - BEFORE (standard template)

GENERAL	CAR ID	1	CAB	CAB CONFIGURATION	FRONT ONLY			
	CODE COMPLIANCE ASME A17.1/CSA B44	2019		DIMENSIONS	58.5 [1486] W x 68 [1727] D x 90 [2286] H			
	CLASSIFICATION	EDGE		ENCLOSURE MATERIAL	16GA STEEL			
	SYSTEM	TWIN 1:1 DIRECT ACTING HYDRAULIC		DOOR OPERATOR	GMV 2 SPEED - CSA#1172862			
	CAPACITY lb [kg]	2300 [1043]		INTERLOCK	CONTACT ONLY			
	NOMINAL CAR SPEED FPM [m/s]	100 [0.50]		DOOR RE-OPENING	FULL LENGTH CURTAIN + 3D DEVICE			
	NO. OF FLOORS	4		DOOR SILL	SATIN BRUSHED ALUMINUM			
	NO. OF OPENINGS	FRONT: 4 / REAR: 0		COP FINISH	SATIN STAINLESS STEEL			
	POWER SUPPLY	208 3PH 60HZ		CAB LIGHT	DIFFUSER PANEL			
	FULL LOAD AMPERAGE	84		CEILING	STAINLESS STEEL REVEAL			
MACHINE	OPERATION	SELECTIVE COLLECTIVE	CARFRAME & PLATFORM	HAND RAIL	FLAT BRUSHED STAINLESS STEEL			
	HOISTWAY CONSTRUCTION	MASONRY		WALL PANELS	HANG ON LAMINATED WALL PANELS			
	BUFFER TYPE AND STROKE in [mm]	2X BUFFER, ACLA 300401F4, 2.83 [72]		DOOR PANEL FINISH	BRUSHED STAINLESS STEEL			
	RAIL WEIGHT lb/ft	8		FINISHED FLOOR MATERIAL	UNFINISHED PLYWOOD			
	CONTROLLER	360 CONTROLLER - CSA#1511880		FINISHED FLOOR FIRE RATING	FIRE RATING SPECIFICATION - CLASS 1			
	DRIVE	GMV TYPE 3		JOISTS/STRINGERS	16GA FORMED STEEL			
	CONTROL VALVE	GMV 3010S - CSA#1032097		CROSSHEAD	7GA 8 X 2 FORMED STEEL			
	PUMP TYPE	3 SPINDLE SCREW		STILE	7GA 7 X 2½ FORMED STEEL			
	FEED FLOW GPM [LPM]	67 [254]		PLANK	7GA 7 X 2 FORMED STEEL			
	FULL LOAD STATIC PRESSURE psi [bar]	408 [27.73]		LANDING ENTRANCE	LANDING ENTRANCE CONSTRUCTION	MASONRY		
FULL LOAD DYNAMIC PRESSURE psi [bar]	448 [30.86]	DOOR TYPE	2 SPEED					
RELIEF PRESSURE psi [bar]	530 [36.53]	DOOR SIZE in [mm]	42" [1065] W x 84 ⅝" [2150] H					
MOTOR SIZE HP [kW]	25 [18.4] 60Hz - CSA#1095178	DOOR INTERLOCK	GMV - CSA#200342					
FEED LINE in [mm]	2 [50.8] SCHED. 40 A53-B/A106-B	FIRE RATING	UL 1½ HR - UL#R21049					
MACHINE HEAT OUTPUT PER 25 STARTS/HR BTU/HR [W]	14927 [1480]	MANUFACTURER	GMV					
ITEM	WEIGHT lb [kg]	DOOR SAFETY RETAINER	INCLUDED					
EQUIPMENT WEIGHTS	CAB	898 [407.3]	OTHER		BATTERY LOWERING	☒	EMERGENCY POWER	☐
	HANG ON PANELS	186 [84.4]			SEISMIC REQUIREMENT	☐	DOOR OPERATOR NUDGING	☒
	HAND RAILS	49 [22.2]			CERTIFICATE FRAME	☐	PIT SHUT OFF VALVE	☒
	TOC	7.7 [3.49]		INCLUDE LINE RUPTURE VALVE	☐			
	COP	42 [19.0]						
	TOE GUARD	47.5 [21.5]						
	CAB DOOR PANELS	90 [40.8]						
	DOOR OPERATOR	100 [45.4]						
	DROP DOWN CEILING	55 [24.9]						
	CAR FRAME	617 [280]						
FINISH FLOOR ALLOWANCE	400 [181]							
TOTAL	2492 [1132]							
HYDRAULIC JACK (2 JACK SYSTEM)	JACK MODEL	TCS-3Y TELESCOPIC JACK						
	PLUNGER 1	ØOD in [mm]	2.4 [60.5]					
		WALL THK in [mm]	0.2 [4.3]					
		LENGTH in [mm]	150 [3809.9]					
		WEIGHT lb [kg]	78.2 [35.5]					
	PLUNGER 2	ØOD in [mm]	3.0 [75.5]					
		WALL THK in [mm]	0.2 [4.3]					
		LENGTH in [mm]	147.2 [3739.9]					
		WEIGHT lb [kg]	84.1 [38.1]					
	PLUNGER 3	ØOD in [mm]	3.6 [90.5]					
WALL THK in [mm]		0.2 [4.3]						
LENGTH in [mm]		147.2 [3739.9]						
WEIGHT lb [kg]		107.2 [48.6]						
CYLINDER	ØOD in [mm]	4.2 [106.0]						
	WALL THK in [mm]	0.2 [4.5]						
	LENGTH in [mm]	143.7 [3649.9]						
	WEIGHT lb [kg]	133 [60.6]						
TOTAL PLUNGER WEIGHT lb [kg]	324.8 [147.3]							

S1.1 - ENG CALCS - AFTER (changes in green)

GENERAL	CAR ID	1	CAB	CAB CONFIGURATION	FRONT ONLY			
	CODE COMPLIANCE ASME A17.1/CSA B44	2019		DIMENSIONS	81 [2057] W x 51 [1295] D x 90 [2286] H			
	CLASSIFICATION	EDGE		ENCLOSURE MATERIAL	16GA STEEL			
	SYSTEM	1:1 DIRECT ACTING HYDRAULIC		DOOR OPERATOR	GMV 2 SPEED - CSA#1172862			
	CAPACITY lb [kg]	2500 [1134]		INTERLOCK	CONTACT ONLY			
	NOMINAL CAR SPEED FPM [m/s]	100 [0.50]		DOOR RE-OPENING	FULL LENGTH CURTAIN + 3D DEVICE			
	NO. OF FLOORS	2		DOOR SILL	SATIN BRUSHED ALUMINUM			
	NO. OF OPENINGS	FRONT: 2 / REAR: 0		COP FINISH	SATIN STAINLESS STEEL			
	POWER SUPPLY	208 3PH 60HZ		CAB LIGHT	LED			
	FULL LOAD AMPERAGE	84		CEILING	STAINLESS STEEL REVEAL			
OPERATION	SELECTIVE COLLECTIVE	HAND RAIL	FLAT BRUSHED STAINLESS STEEL					
HOISTWAY CONSTRUCTION	MASONRY	WALL PANELS	HANG ON LAMINATED WALL PANELS					
BUFFER TYPE AND STROKE in [mm]	2X BUFFER, ACLA 300401F4, 2.83 [72]	DOOR PANEL FINISH	BRUSHED STAINLESS STEEL					
RAIL WEIGHT lb/ft	8	FINISHED FLOOR MATERIAL	UNFINISHED PLYWOOD					
MACHINE	CONTROLLER	360 CONTROLLER - CSA#1511880	CARFRAME & PLATFORM	FINISHED FLOOR FIRE RATING	FIRE RATING SPECIFICATION - CLASS 1			
	DRIVE	GMV TYPE 3		JOISTS/STRINGERS	16GA FORMED STEEL			
	CONTROL VALVE	GMV 3010S - CSA#1032097		CROSSHEAD	7GA 8 X 2 FORMED STEEL			
	PUMP TYPE	3 SPINDLE SCREW		STILE	7GA 7 X 2½ FORMED STEEL			
	FEED FLOW GPM [LPM]	67 [254]		PLANK	7GA 7 X 2 FORMED STEEL			
	FULL LOAD STATIC PRESSURE psi [bar]	408 [27.73]		LANDING ENTRANCE	LANDING ENTRANCE CONSTRUCTION	MASONRY		
	FULL LOAD DYNAMIC PRESSURE psi [bar]	448 [30.86]			DOOR TYPE	2 SPEED		
	RELIEF PRESSURE psi [bar]	530 [36.53]			DOOR SIZE in [mm]	42" [1065] W x 84 ⅝" [2150] H		
	MOTOR SIZE HP [kW]	25 [18.4] 60Hz - CSA#1095178			DOOR INTERLOCK	GMV - CSA#200342		
	FEED LINE in [mm]	2 [50.8] SCHED. 40 A53-B/A106-B			FIRE RATING	UL 1½ HR - UL#R21049		
MACHINE HEAT OUTPUT PER 25 STARTS/HR BTU/HR [W]	14927 [1480]	MANUFACTURER	GMV					
EQUIPMENT WEIGHTS	ITEM	WEIGHT lb [kg]	OTHER	DOOR SAFETY RETAINER	INCLUDED			
	CAB	898 [407.3]		BATTERY LOWERING	☒ Y	EMERGENCY POWER	☐ I	
	HANG ON PANELS	186 [84.4]		SEISMIC REQUIREMENT	☐	DOOR OPERATOR NUDGING	☒	
	HAND RAILS	49 [22.2]		CERTIFICATE FRAME	☐	PIT SHUT OFF VALVE	☒	
	TOC	7.7 [3.49]		INCLUDE LINE RUPTURE VALVE	☐			
	COP	42 [19.0]						
	TOE GUARD	47.5 [21.5]						
	CAB DOOR PANELS	90 [40.8]						
	DOOR OPERATOR	100 [45.4]						
	DROP DOWN CEILING	55 [24.9]						
CAR FRAME	617 [280]							
FINISH FLOOR ALLOWANCE	400 [181]							
TOTAL	2492 [1132]							
HYDRAULIC JACK (2 JACK SYSTEM)	JACK MODEL	TCS-3Y TELESCOPIC JACK						
	PLUNGER 1	ØOD in [mm]	2.4 [60.5]					
		WALL THK in [mm]	0.2 [4.3]					
		LENGTH in [mm]	150 [3809.9]					
		WEIGHT lb [kg]	78.2 [35.5]					
	PLUNGER 2	ØOD in [mm]	3.0 [75.5]					
		WALL THK in [mm]	0.2 [4.3]					
		LENGTH in [mm]	147.2 [3739.9]					
		WEIGHT lb [kg]	84.1 [38.1]					
	PLUNGER 3	ØOD in [mm]	3.6 [90.5]					
WALL THK in [mm]		0.2 [4.3]						
LENGTH in [mm]		147.2 [3739.9]						
WEIGHT lb [kg]		107.2 [48.6]						
CYLINDER	ØOD in [mm]	4.2 [106.0]						
	WALL THK in [mm]	0.2 [4.5]						
	LENGTH in [mm]	143.7 [3649.9]						
	WEIGHT lb [kg]	133 [60.6]						
TOTAL PLUNGER WEIGHT lb [kg]	324.8 [147.3]							
REACTION FORCES		FORCE	REACTION					
		PIT (R) lb [kN]	16100 [71.62]					
		F1 lb [kN]	375 [1.67]					
		F2 lb [kN]	180 [0.80]					
		REACTION FORCES ARE DOUBLED FOR IMPACT (PIT)						
		PROJECT NAME:	HARVEST CHURCH OF NEW YORK		DRAWN BY: TL			
		PROJECT NUMBER	NY1922P263798		CHECKED BY: AL			
		LOCATION	54-47 LITTLE NEAK, FLUSHING NY		DATE:			
		ELEVATOR COMPANY	K & J LIFT INC.		8/27/2026			
		GENERAL CONTRACTOR	-		SCALE: NTS REV: 0			
		ARCHITECT	-		SHEET: S1-P1/9			
		DRAWING:	TECHNICAL DATA					

S1.2 - ELEVATION VIEW - AFTER (changes in green)

NOTE:
HOISTWAY BEAM SUITABLE FOR SUPPORT OF
FALL PROTECTION. 5000LBS CAPACITY.
LEAVE A 2" GAP (MIN.) BETWEEN THE
UNDERSIDE OF THE FINISHED CEILING AND
THE BEAM.

SECTION 1 NOT TO BE USED FOR BUILDING CONSTRUCTION

SECTION 1 NOT TO BE USED FOR BUILDING CONSTRUCTION

RAIL MAX BRACKET
SPACING 64" [1625mm]

HOISTWAY SECTION VIEW

FLOORS	DISTANCE (INCH)
*G TO 2	125"
1	1
2	2

		PROJECT NAME:	HARVEST CHURCH OF NEW YORK	DRAWN BY: TL
		PROJECT NUMBER	NY1922P263798	CHECKED BY: AL
		LOCATION	54-47 LITTLE NEAK, FLUSHING NY	DATE:
		ELEVATOR COMPANY	K & J LIFT INC.	8/27/2026
		GENERAL CONTRACTOR	-	SCALE: NTS REV: 0
		ARCHITECT	-	SHEET: S1-P3/9
DRAWINGS FOR REVIEW		DRAWING:	ELEVATION VIEW	

S1.5 - CAB DETAIL - BEFORE (standard template)

SECTION 1 NOT TO BE USED FOR BUILDING CONSTRUCTION

GENERAL	PLATFORM SIZE	61.75" (1568 mm) W X 77.5" (1969 mm) D		
	ENTRANCE	BRUSHED STAINLESS STEEL		
	INSIDE CAB SIZE	58.5" (1486 mm) W X 68" (1727 MM) D		
	EMERGENCY LIGHT	ON CAR OPERATING PANEL		
	PAD HOOKS	X	YES	- NO
	PROTECTION PADS	-	YES	X NO
	EXHAUST FAN	2 SPEED		
	CAB LIGHT	4 X LED BARS		
	CEILING PANELS	X	POLYCARBONATE	- 6 SS PANELS
	HANDRAIL TYPE	X	FLAT	- ROUND
FINISHES	HANDRAIL FINISH	BRUSHED STAINLESS STEEL		
	CAB SILL	EXTRUDED ALUMINUM		
	CERTIFICATE FRAME	BRUSHED STAINLESS STEEL		
	CAB ENTRANCE	BRUSHED STAINLESS STEEL		
	CEILING FRAME	-	BLACK POWDER COAT	X SATIN STAINLESS STEEL
	CAB REVEALS	-	BLACK POWDER COAT	X SATIN STAINLESS STEEL

		PROJECT NAME:	HARVEST CHURCH OF NEW YORK	DRAWN BY:	TL
		PROJECT NUMBER	NY1922P263798	CHECKED BY:	AL
LOCATION		54-47 LITTLE NEAK, FLUSHING NY		DATE:	
ELEVATOR COMPANY		K & J LIFT INC.		8/27/2026	
GENERAL CONTRACTOR		-		SCALE:	NTS REV: 0
ARCHITECT		-		SHEET: S1-P6/9	
DRAWINGS FOR REVIEW		DRAWING: CAB DETAIL			

S1.5 - CAB DETAIL - AFTER (changes in green)

SECTION 1 NOT TO BE USED FOR BUILDING CONSTRUCTION

GENERAL	PLATFORM SIZE	83.5" [2121] WIDE X 60.6" [1539] DEEP		
	ENTRANCE	42" [1065] WIDE X 84 5/8" [2150] HIGH		
	INSIDE CAB SIZE	81" [2057] WIDE X 51" [1295] DEEP		
	EMERGENCY LIGHT	ON CAR OPERATING PANEL		
	PAD HOOKS	X	YES	- NO
	PROTECTION PADS	-	YES	X NO
	EXHAUST FAN	2 SPEED		
	CAB LIGHT	4 X LED BARS		
	CEILING PANELS	X	POLYCARBONATE	- 6 SS PANELS
	HANDRAIL TYPE	X	FLAT	- ROUND
FINISHES	HANDRAIL FINISH	BRUSHED STAINLESS STEEL		
	CAB SILL	EXTRUDED ALUMINUM		
	CERTIFICATE FRAME	BRUSHED STAINLESS STEEL		
	CAB ENTRANCE	BRUSHED STAINLESS STEEL		
	CEILING FRAME	-	BLACK POWDER COAT	X SATIN STAINLESS STEEL
	CAB REVEALS	X	BLACK POWDER COAT	- SATIN STAINLESS STEEL

		PROJECT NAME:	HARVEST CHURCH OF NEW YORK	DRAWN BY:	TL
		PROJECT NUMBER	NY1922P263798	CHECKED BY:	AL
LOCATION		54-47 LITTLE NEAK, FLUSHING NY		DATE:	
ELEVATOR COMPANY		K & J LIFT INC.		8/27/2026	
GENERAL CONTRACTOR		-		SCALE:	NTS REV: 0
ARCHITECT		-		SHEET: S1-P6/9	
DRAWINGS FOR REVIEW		DRAWING: CAB DETAIL			

S1.7 - COP DETAIL - BEFORE (standard template)

SECTION 1 NOT TO BE USED FOR BUILDING CONSTRUCTION

X2 KEY LOCKS

FIRE FIGHTER INDICATOR LIGHT

EMERGENCY LIGHT

ENGRAVING PLATE

DIGITAL DIRECTION POSITION INDICATOR

TWO-WAY VISUAL COMMUNICATION SYSTEM

CALL ACKNOWLEDGED

PHASE II FIRE SERVICE BEHIND LOCKED PANEL, ALL FIRE SERVICE KEYED TO FEOK1

DIRECTION INDICATOR ON CAB STRIKE JAMB

SS REVEAL

LED ILLUMINATED RINGS

SS CENTER

FLOOR WITH BRAILLE DESIGNATION

VISUAL COMMUNICATION ACKNOWLEDGE

FRONT DOOR OPEN

ALARM

IN CAR STOP

ACCESS SWITCH

FLOOR BUTTON

VISUAL COMMUNICATION DECLINE

FRONT DOOR CLOSE

HANDS FREE PHONE

INDEPENDENT SERVICE

NOTE:
-STANDARD STYLE PUSH BUTTONS
-FINISH IS SATIN STAINLESS STEEL
-STANDARD ASME/A17.1 FIRE SERVICE UNLESS OTHERWISE NOTED (WHEN FIRE SERVICE IS PROVIDED)

COVER MATERIAL	BRUSHED STAINLESS STEEL		
PUSH BUTTONS	STANDARD		
OPENINGS	4		
FLOOR MARKINGS	*G / 1 / 2 / 3		
KEY SWITCHES	X	STANDARD	- ACCESS OFF/ON
	X	LIGHT (AUTO)	- DOOR HOLD
	X	FAN (AUTO)	- MED EMERG. LIGHT
	X	INDEPENDENT SERV.	- OTHER
STOP SWITCH	KEY SWITCH		
FIRE SERVICE	X	YES	- NO
TELEPHONE	INSIDE COMPARTMENT, CALL WITH PUSHBUTTON		
ENGRAVING	2300 [1043]		
NUDGING BUZZED	X	YES	- NO
SMARTVIEW SYSTEM	X	YES	- NO

PROJECT NAME:	HARVEST CHURCH OF NEW YORK		DRAWN BY: TL
PROJECT NUMBER	NY1922P263798		
LOCATION	54-47 LITTLE NEAK, FLUSHING NY		CHECKED BY: AL
ELEVATOR COMPANY	K & J LIFT INC.		DATE:
GENERAL CONTRACTOR	-		8/27/2026
ARCHITECT	-		SCALE: NTS
DRAWING:			REV: 0
			SHEET: S1-P8/9

DRAWINGS FOR REVIEW

CAR OPERATING PANEL

S1.7 - COP DETAIL - AFTER (changes in green)

SECTION 1 NOT TO BE USED FOR BUILDING CONSTRUCTION

X2 KEY LOCKS

FIRE FIGHTER INDICATOR LIGHT

EMERGENCY LIGHT

ENGRAVING PLATE

DIGITAL DIRECTION POSITION INDICATOR

TWO-WAY VISUAL COMMUNICATION SYSTEM

CALL ACKNOWLEDGED

PHASE II FIRE SERVICE BEHIND LOCKED PANEL, ALL FIRE SERVICE KEYED TO FEOK1

DIRECTION INDICATOR ON CAB STRIKE JAMB

SS REVEAL

LED ILLUMINATED RINGS

SS CENTER

FLOOR WITH BRAILLE DESIGNATION

VISUAL COMMUNICATION ACKNOWLEDGE

FRONT DOOR OPEN

ALARM

IN CAR STOP

ACCESS SWITCH

FLOOR BUTTON

VISUAL COMMUNICATION DECLINE

FRONT DOOR CLOSE

HANDS FREE PHONE

INDEPENDENT SERVICE

NOTE:
-STANDARD STYLE PUSH BUTTONS
-FINISH IS SATIN STAINLESS STEEL
-STANDARD ASME/A17.1 FIRE SERVICE UNLESS OTHERWISE NOTED (WHEN FIRE SERVICE IS PROVIDED)

COVER MATERIAL	BRUSHED STAINLESS STEEL		
PUSH BUTTONS	STANDARD		
OPENINGS	2		
FLOOR MARKINGS	*G / 2		
KEY SWITCHES	X	STANDARD	- ACCESS OFF/ON
	X	LIGHT (AUTO)	- DOOR HOLD
	X	FAN (AUTO)	- MED EMERG. LIGHT
	X	INDEPENDENT SERV.	- OTHER
STOP SWITCH	KEY SWITCH		
FIRE SERVICE	X	YES	- NO
TELEPHONE	PUSH BUTTON, BRAILLE TAG, CALL ACK. INDICATOR		
ENGRAVING	2500lb / 1134kg		
NUDGING BUZZED	X	YES	- NO
SMARTVIEW SYSTEM	X	YES	- NO

PROJECT NAME:	HARVEST CHURCH OF NEW YORK		DRAWN BY: TL
PROJECT NUMBER	NY1922P263798		
LOCATION	54-47 LITTLE NEAK, FLUSHING NY		CHECKED BY: AL
ELEVATOR COMPANY	K & J LIFT INC.		DATE:
GENERAL CONTRACTOR	-		8/27/2026
ARCHITECT	-		SCALE: NTS
DRAWING:			REV: 0
			SHEET: S1-P8/9

DRAWINGS FOR REVIEW

CAR OPERATING PANEL

S1.8 - HALL FIXTURE - BEFORE (standard template)

SECTION 1 NOT TO BE USED FOR BUILDING CONSTRUCTION

FIRE RECALL SWITCH

COMMUNICATION RESET SWITCH

FLOOR LOCKOUT SWITCH

LED ILLUMINATED BUTTON

HOISTWAY ACCESS SWITCH

FLOOR LOCKOUT SWITCH

FLOOR - *G

FLOOR - 1/2

FLOOR - 3

HALL PI / DI
ALL FLOORS

NOTE:
-STANDARD STYLE PUSH BUTTONS
-FINISH IS SATIN STAINLESS STEEL
-STANDARD ASME/A17.1 FIRE SERVICE
UNLESS OTHERWISE NOTED (WHEN FIRE
SERVICE IS PROVIDED)
-STANDARD 13" X 4" HALL STATION
COVERS REQUIRE 12.125" HIGH X 3.125"
WIDE X 3" DEEP CUT-OUT

PROJECT NAME:

HARVEST CHURCH OF NEW YORK

PROJECT NUMBER

NY1922P263798

LOCATION

54-47 LITTLE NEAK, FLUSHING NY

ELEVATOR COMPANY

K & J LIFT INC.

GENERAL CONTRACTOR

-

ARCHITECT

-

DRAWN BY: TL

CHECKED BY: AL

DATE:
8/27/2026

SCALE: NTS | REV: 0

SHEET: S1-P9/9

DRAWINGS FOR REVIEW

HALL FIXTURE

S1.8 - HALL FIXTURE - AFTER (changes in green)

SECTION 1 NOT TO BE USED FOR BUILDING CONSTRUCTION

FIRE RECALL SWITCH

COMMUNICATION RESET SWITCH

FLOOR LOCKOUT SWITCH

LED ILLUMINATED BUTTON

HOISTWAY ACCESS SWITCH

FLOOR LOCKOUT SWITCH

FLOOR - *G

FLOOR - 1/2

FLOOR - 2

HALL PI / DI
ALL FLOORS

NOTE:
-STANDARD STYLE PUSH BUTTONS
-FINISH IS SATIN STAINLESS STEEL
-STANDARD ASME/A17.1 FIRE SERVICE
UNLESS OTHERWISE NOTED (WHEN FIRE
SERVICE IS PROVIDED)
-STANDARD 13" X 4" HALL STATION
COVERS REQUIRE 12.125" HIGH X 3.125"
WIDE X 3" DEEP CUT-OUT

PROJECT NAME:

HARVEST CHURCH OF NEW YORK

PROJECT NUMBER

NY1922P263798

LOCATION

54-47 LITTLE NEAK, FLUSHING NY

ELEVATOR COMPANY

K & J LIFT INC.

GENERAL CONTRACTOR

-

ARCHITECT

-

DRAWN BY: TL

CHECKED BY: AL

DATE:
8/27/2026

SCALE: NTS | REV: 0

SHEET: S1-P9/9

DRAWINGS FOR REVIEW

HALL FIXTURE