

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

File no. SSS/UJS/DLWQTML/2025-26

Date: 18/07/25

It is certified that an inspection team headed by DR. VIKASH KANDARI [CHIEF CHEMIST]

(Name of the officer with designation) from UTTARAKHAND JAL SANSTHAN PHED

inspected SHRI GURU NANAK DOON VALE SCHOOL, RACE COURSE, DEHRADUN on 14/07/25

(Date of inspection) and on the basis of Water test report (attached) bearing no. 898/UJS/DLWQTML/25-26

dated 18/07/25 of DISTRICT WATER TESTING LAB (Name of PHED Lab)

certified that the SHRI GURU NANAK DOON VALE SCHOOL, RACE COURSE, DEHRADUN has safe drinking water facilities for the students and members of staff of the school. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt.

The above is valid for a period of as per Govt. Rule.

Signature with Seal :

Name : DR. VIKASH KANDARI

Designation : TECHNICAL MANAGER

Name and Address of Department / Office : UJS LAB, DEHRADUN

Technical Manager
DLWQTML
Uttarakhand Jal Sansthan
Dehradun

To,

SHRI GURU NANAK DOON VALE SCHOOL,
RACE COURSE, DEHRADUN

H. N. Singh
Principal
G. N. DOON VALE SCHOOL
Race Course, Dehra Dun
Tel: 0135-2727732

Jagmeet Singh
Manager
Shri Guru Nanak Doon Vale School
Race Course, Dehradun





कार्यालय नगर निगम, देहरादून।




(का०- 0135-2714074:फैक्स- 0135-2651060: ई-मेल- (nagarnigam.ddn@gmail.com)

पत्रांक:-.....13.2...CH1


दिनांक:-...21.04.25

प्रमाण-पत्र

प्रमाणित किया जाता है, कि "SHRI GURU NANAK DOON VALE SCHOOL" स्थित- रेसकोर्स, देहरादून में पीने के पानी एवं शौचालय/मूत्रालय का सफाई सम्बन्धित निरीक्षण क्षेत्रीय सफाई निरीक्षक द्वारा दिनांक 21.04.2025 को किया गया। स्कूल में सफाई व्यवस्था सही पायी गयी। सफाई सम्बन्धित कोई आपत्ति नहीं हैं तथा सफाई सम्बन्धित अनापत्ति प्रमाण पत्र जारी किया जाता है, जिसकी वैधता 31 मार्च, 2026 तक होगी।


मुख्य नगर स्वास्थ्य अधिकारी,
नगर निगम, देहरादून।


Principal
S.G.N. DOON VALE SCHOOL
Race Course, Dehra Dun
Tel: 0135-2727732


JAGMEET SINGH
Manager
Shri Guru Nanak Doon Vale School
Race Course, Dehradun



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun

TEST REPORT

Name and Address of Organization/ Customer	Shri Guru Nanak Doon Vale School, Race Course, Dehradun, Uttarakhand.		
Test Report ID	898A/UJS/DLWQTML/2025-26	Reporting Date	18/07/2025
		Sample Location	Race Course, Dehradun, Uttarakhand
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-898		
Date of Start of Analysis:	14/07/2025		
Date of End of Analysis:	17/07/2025		
Date and Time of Sample Received:	14/07/25 & 04: 34 PM		


SN	Parameters	Test Method	Results	Acceptable Limit As per (IS: 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
(D) General Parameters Concerning Substances					
1	Fluoride, mg/L, Max	APHA 23rd Ed. 4500-F-D: 2023: SPADNS Method	0.13	1.0	1.5
2	Nitrate, mg/L, Max	APHA 23rd Ed. 4500-NO ₃ -B:2023: Ultraviolet Spectrophotometric Screening Method	2.12	45	No Relaxation
3	Sulfate, mg/L, Max	APHA 23rd Ed. 4500-SO ₄ ²⁻ E:2023:Turbidimetric Method	4.86	200	400

Note:-


1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample in received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer


**** End of Report****

Review and Authorized By


Dr.akash Namtari
Technical Manager, Lab

Technical Manager
DLWQTML
Uttarakhand Jal Sansthan
Dehradun


Principal
S.G.N. DOON VALE SCHOOL
Race Course, Dehra Dun
Tel: 0135-2727732


JAGMEET SINGH
Manager
Shri Guru Nanak Doon Vale School
Race Course, Dehradun





District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun



TC-13625

TEST REPORT

Name and Address of Organization/ Customer	Shri Guru Nanak Doon Vale School, Race Course, Dehradun, Uttarakhand.		
Test Report ID	898/UJS/DLWQTML/2025-26	Reporting Date	18/07/2025
ULR No.	TC13625250000000000301F	Sample Location	Race Course, Dehradun, Uttarakhand
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/2025-898		
Date of Start of Analysis:	14/07/2025		
Date of End of Analysis:	17/07/2025		
Date and Time of Sample Received:	14/07/25 & 04: 34 PM		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
(A) Organoleptic and Physical Parameters					
1.	pH at 25°C	IS 3025 (Part 11) 2022	7.34	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C, mg/L	IS 3025 (Part 10), 2023	142	500 Max	2000 Max
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.62	1 Max	5 Max
4.	Colour, Hazen	IS 3025 (Part 4): 2021	Less than 01	5 Max	15 Max
5.	Odour	IS 3025 (Part 5): 2018	Agreeable	Agreeable	Agreeable
(B) General Parameters Concerning Substances					
6.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23), 2023	64	200 Max	600 Max
7.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21), 2009	116	200 Max	600 Max
8.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	14.4	75 Max	200 Max
9.	Chloride, mg/L	IS 3025 (Part 32), 2019	11	250 Max	1000 Max
10.	Magnesium as Mg, mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	19.44	30 Max	100 Max
(C) Microbiological Parameters					
Parameters		Test method	Results	Requirements as per IS 10500:2012	
11.	Total Coliform (in 100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml sample	
12.	E. coli, (in 100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml sample	

Note -

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By

Dr. Vikash Khandari
Technical Manager, Lab

Technical Manager
DLWQTML
Uttarakhand Jal Sansthan
Dehradun

Format No. UJS/LMS/TRC-01

Principal
SHRI GURU NANAK DOON VALE SCHOOL
Race Course, Dehra Dun
Tel: 0135-2727732

JAGMEET SINGH
Manager
Shri Guru Nanak Doon Vale School
Race Course, Dehradun

