

Using your Air Quality Sensor




The exclamation point means: The sensor has recently been started or reset, the CO₂ value will not be stable yet and no alarm will sound.

The 4 states of operation:

CO ₂ ppm	Alarm	Action item
400 - 799	none	Vent!
800 - 1199	single beep	Vent more and better!
1200+	siren	Vent and leave the room!
---	maybe	Contact IT


All alarms will sound once a minute.

The sensor node will update itself automatically. If your version is lower than another room's for more than one day or the date and time (shown in UTC) are wrong, contact IT.




Correct ventilation means doors and windows on opposite walls are open. Also, vent often and for short bursts to avoid equalizing the room to the outside temperature!

Kipplüften



Querlüften



Since the sensor needs to run at all times to calibrate correctly, never unplug the sensor node!

If you really need to turn off the alarm for 20 minutes, press this button and be extra careful. But it's better to vent sufficiently before the alarm starts!